

ALL INTRA STATE ENTITIES ARE REQUESTED TO GIVE THEIR READINESS FOR AVAILING SHUTDOWN ON D-3 BASIS ELSE THE SHUTDOWN MAY BE TREATED AS DEEMED CANCEL .

ALL APPROVED OCCM SHUTDOWN AVAILABLE AT SLDC & WRPC WEB-SITE.

SUB :- APPROVED SHUT DOWN OF TRANSMISSION ELEMENTS FOR THE PERIOD FROM 01.08.18 TO 31.08.18, APPROVED IN 509th OCC MEETING TO BE HELD ON 17.07.18 AT WRPC, MUMBAI

**Approved Shut down of 400 KV Transmission elements
(01.08.18 to 31.08.18)**

Sr. No	KV	Line	From		To		Basis	Reason	System	Agency	Type
			Date	Time	Date	Time					
A 400KV TRANSFORMER											
NIL											
B 400 KV REACTORS											
NIL											
C 400 KV FEEDER & BAYS OF 400 KV- S/S.											
1	400	400KV BDTCL 1 Main CB at 400KV S/s Bhopal	1-Aug-18	9:00	13-Aug-18	18:00	Continue	For replacement of 400Kv CB and 3No. 400Kv CTs under PSDF Scheme. Line will remain charged through Tie CB, (however on dtd 13.08.18 line will be kept off for charging of new CT.)	MPPTCL	MPPTCL	R
2	400	400KV BHOPAL-I (TIE C.B.) at 400KV S/s Bina	1-Aug-18	8:00	10-Aug-18	17:00	Continue	For replacement of TIE CB (Line should be charged through Main CB)	MPPTCL	MPPTCL	R
3	400	400KV Seoni (PGCIL)-Bhilai LINE	1-Aug-18	9:00	14-Aug-18	17:00	Continue	For LILO WORK OF 400KV KIRANAPUR S/S .	MPPTCL	MPPTCL	R
4	400	400KV Indore (PGCIL Hanuniya)-Pithampur-I	03-Aug-18	10:00	03-Aug-18	17:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
5	400	400KV Nagda - Rajgharh-I	06-Aug-18	8:00	07-Aug-18	18:00	Continue	For replacement of disc insulators & line mainenance work	MPPTCL	MPPTCL	R
6	400	400KV Seoni (PGCIL)-Bhilai	6-Aug-18	9:00	6-Aug-18	18:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
7	400	400KV Indore (PGCIL Hanuniya)-Pithampur-II	06-Aug-18	10:00	06-Aug-18	17:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
8	400	400KV Damoh (PGCIL)-Katni	08-Aug-18	9:00	08-Aug-18	18:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
9	400	400KV Main Bus I at 400KV S/s Indore	09-Aug-18	9:00	11-Aug-18	18:00	Continue	For ICT-I PG Isolator Replacement & ICT-I will be TBC	MPPTCL	MPPTCL	R
10	400	400KV Nagda - Rajgharh-II	9-Aug-18	8:00	9-Aug-18	18:00	Daily	For replacement of disc insulators & line mainenance work	MPPTCL	MPPTCL	R
11	400	400KV Main Bus -I at 400KV S/s Nagda	12-Aug-18	8:00	14-Aug-18	18:00	Continue	For replacement of disc insulators	MPPTCL	MPPTCL	R
12	400	400KV Bhopal-BDTCL 1	13-Aug-18	9:00	13-Aug-18	18:00	Daily	Testing work after replacement of CB. Line will be under shutdown	MPPTCL	MPPTCL	R
13	400	400KV Main Bus -II at 400KV S/s Nagda	15-Aug-18	8:00	17-Aug-18	18:00	Continue	For replacement of disc insulators	MPPTCL	MPPTCL	R
14	400	400KV Itarsi 1 Main CB at 400KV S/s Bhopal	17-Aug-18	9:00	30-Aug-18	18:00	Continue	For replacement of 400Kv CB and 3No. 400Kv CTs under PSDF Scheme. Line will remain charged through Tie CB .(however line will be kept off on dt 30.08.18 for charging of new CT)	MPPTCL	MPPTCL	R
15	400	400KV BHOPAL-I (MAIN C.B.) at 400KV S/s Bina	17-Aug-18	8:00	27-Aug-18	17:00	Continue	For replacement of main CB (Line should be charged through Tie CB)	MPPTCL	MPPTCL	R

16	400	400KV Seoni (PGCIL)-Sarni	21-Aug-18	9:00	21-Aug-18	18:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
17	400	400KV ISP- Nagda	22-Aug-18	8:00	22-Aug-18	18:00	Daily	Grading Capacitor replacement work	NHDC	NHDC	R
18	400	400KV Main Bus I at 400KV S/s ISP	23-Aug-18	8:00	23-Aug-18	18:00	Daily	For Extension of Bus up to Shunt Reactor Bay & CVT replacement work	NHDC	NHDC	R
19	400	400KV Main Bus II at 400KV S/s ISP	24-Aug-18	8:00	24-Aug-18	18:00	Daily	For Extension of Bus up to Shunt Reactor Bay & CVT replacement work	NHDC	NHDC	R
20	400	400KV Main Bus I at 400KV S/s Indore	25-Aug-18	9:00	26-Aug-18	18:00	Continue	For replacement of 2 No CVTs (400KV Asoj II will be on TBC)	MPPTCL	MPPTCL	R
21	400	400KV Main Bus II at 400KV S/s Indore	28-Aug-18	9:00	29-Aug-18	18:00	Continue	For replacement of CVT (400 KV Asoj II will be on TBC)	MPPTCL	MPPTCL	R
22	400	400KV Bhopal-Itarsi 1	30-Aug-18	9:00	30-Aug-18	18:00	Daily	Testing work after replacement of CB. Line will be under shutdown	MPPTCL	MPPTCL	R
23	400	400KV Main Bus I at 400KV S/s Indore	31-Aug-18	9:00	01-Sep-18	18:00	Continue	For 400KV Nagda P.G Isolator Replacement (400 KV Nagda will be on TBC)	MPPTCL	MPPTCL	R
D. 220 KV LINES											
1	220	220KV Mehgaon-Adani feeder	03-Aug-18	9:00	03-Aug-18	17:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
2	220	220KV Bhanpura-Modak	04-Aug-18	9:00	04-Aug-18	18:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
3	220	220KV Badod-Sakatpura(Kota)	05-Aug-18	9:00	05-Aug-18	18:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
4	220	220KV Gwalior(PGCIL)-Malanpur-I	07-Aug-18	9:00	07-Aug-18	17:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
5	220	220KV Mahalgaon- PGCIL Ckt I	08-Aug-18	9:00	08-Aug-18	17:00	Daily	For replacement of 220KV Isolator under PSDF Scheme at Sub station	MPPTCL	MPPTCL	R
6	220	220KV Gwalior(PGCIL)-Malanpur-II	09-Aug-18	9:00	09-Aug-18	17:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
7	220	220KV Mahalgaon- PGCIL Ckt I	10-Aug-18	9:00	10-Aug-18	17:00	Daily	For replacement of 220KV Isolator under PSDF Scheme at Sub station	MPPTCL	MPPTCL	R
8	220	220KV Mahalgaon- PGCIL Ckt II	16-Aug-18	9:00	16-Aug-18	17:00	Daily	For replacement of 220KV Isolator under PSDF Scheme at Sub station	MPPTCL	MPPTCL	R
9	220	220KV Mahalgaon- PGCIL Ckt II	17-Aug-18	9:00	17-Aug-18	17:00	Daily	For replacement of 220KV Isolator under PSDF Scheme at Sub station	MPPTCL	MPPTCL	R
10	220	220KV Khandwa (PGCIL)-Neenanagar	20-Aug-18	10:00	20-Aug-18	18:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
11	220	220KV Malanpur-Aouriya	24-Aug-18	9:00	24-Aug-18	17:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
12	220	220KV Mahagaon-Aouriya	25-Aug-18	9:00	25-Aug-18	17:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
13	220	220KV Annapur-Kotmikala-I	27-Aug-18	10:00	27-Aug-18	17:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
14	220	220KV Bina(PGCIL)-Shivpuri	28-Aug-18	9:00	28-Aug-18	17:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R
15	220	220KV Annapur-Kotmikala-II	31-Aug-18	10:00	31-Aug-18	17:00	Daily	For Line maintenance work	MPPTCL	MPPTCL	R