

ALL INTRA STATE ENTITIES ARE REQUESTED TO GIVE THEIR READINESS FOR AVAILING SHUTDOWN ON D-3 BASIS ELSE THE SHUTDOWN MAY BE TREATED AS DEEMED CANCEL .  
ALL APPROVED OCCM SHUTDOWN AVAILABLE AT SLDC & WRPC WEB-SITE.

SUB :- APPROVED SHUT DOWN OF TRANSMISSION ELEMENTS FOR THE PERIOD FROM 01.12.18 TO 31.12.18, APPROVED IN 513th OCC MEETING TO BE HELD ON 19.11.18 AT WRPC, MUMBAI

Approved Shut down of 400 KV Transmission elements  
( 01.12.18 to 31.12.18 )

Sr. No	KV	Line	From		To		Basis	Reason	System	Agency	Type
			Date	Time	Date	Time					
<b>A 400KV TRANSFORMER</b>											
<b>B 400 KV REACTORS</b>											
1	400	125 MVR Bus Reactor (BHEL)at Nagda 400KV S/s Nagda	11-Dec-18	08:00	12-Dec-18	17:00	Continue	For general maintenance & jumper replacement work	MPPTCL	MPPTCL	R
<b>C 400 KV FEEDER &amp; BAYS OF 400 KV- S/S.</b>											
1	400	400 Kv Bhopal- Bina 1 Line at 400KV S/s Bhopal	1-Dec-18	09:00	1-Dec-18	18:00	Daily	Testing work of Tie CB. Line will be under shutdown	MPPTCL	MPPTCL	R
2	400	400KV Bina 1 Main CB of 400KV S/s Bhopal	3-Dec-18	09:00	15-Dec-18	18:00	Continue	Replacement of 400 Kv CB and 3 No 400Kv CTs under PSDF Scheme. Line will remain charge through Tie CB	MPPTCL	MPPTCL	R
3	400	400KV Bina-Bhopal-I	4-Dec-18	09:00	4-Dec-18	17:00	Daily	For post monsoon maintenance / Testing work	MPPTCL	MPPTCL	R
4	400	400KV Seoni-Sarni	5-Dec-18	09:00	5-Dec-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
5	400	400KV Katni-Damoh	9-Dec-18	09:00	9-Dec-18	17:00	Daily	For post monsoon maintenance / Testing work	MPPTCL	MPPTCL	R
6	400	400KV Nagda-Rajgarh-I	10-Dec-18	09:00	10-Dec-18	17:00	Daily	Tightening/removing of loose vibration damper & other line maintenance work	MPPTCL	MPPTCL	R
7	400	400KV Bhopal-Itarsi-I	11-Dec-18	09:00	11-Dec-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
8	400	400KV Bhopal-Itarsi-II	12-Dec-18	09:00	12-Dec-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
9	400	400KV Bhilai-Seoni line	14-Dec-18	09:00	29-Dec-18	17:00	Continue	LILO work of 400KV Bhilai-Seoni line at 400/132KV S/s Kirnapur	MPPTCL	MPPTCL	R
10	400	400 Kv Bhopal- Bina 1 Line at 400KV S/s Bhopal	15-Dec-18	09:00	15-Dec-18	18:00	Daily	Testing work after replacement of CB. Line will be under shutdown	MPPTCL	MPPTCL	R
11	400	400KV Nagda-JSP	15-Dec-18	09:00	15-Dec-18	17:00	Daily	Tightening/removing of loose vibration damper & other line maintenance work	MPPTCL	MPPTCL	R
12	400	400KV Bina-Bhopal-II	16-Dec-18	09:00	16-Dec-18	17:00	Daily	For post monsoon maintenance / Testing work	MPPTCL	MPPTCL	R
13	400	400KV Nagda-Rajgarh-II	17-Dec-18	09:00	17-Dec-18	17:00	Daily	Tightening/removing of loose vibration damper & other line maintenance work	MPPTCL	MPPTCL	R
14	400	400KV Bina -Bhopal-1 Feeder	17-Dec-18	09:00	19-Dec-18	17:00	Continue	For replacement of line CVTs	MPPTCL	MPPTCL	R
15	400	400KV Bhopal 1 Main CB of PG Itarsi at 400KV S/s Bhopal	18-Dec-18	09:00	29-Dec-18	18:00	Continue	Replacement of 400 Kv CB and 3 No 400Kv CTs under PSDF Scheme. Line will remain charge through Tie CB	MPPTCL	MPPTCL	R
16	400	400KV Seoni-Bhilai	20-Dec-18	09:00	20-Dec-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
17	400	400KV Rajgarh-SSP-I	28-Dec-18	09:00	28-Dec-18	17:00	Daily	Tightening/removing of loose vibration damper & other line maintenance work	MPPTCL	MPPTCL	R
18	400	400KV Bhopal 1 Tie CB of PG Itarsi at 400KV S/s Bhopal	29-Dec-18	09:00	29-Dec-18	18:00	Daily	Testing work after replacement of CB. Line will be under shutdown	MPPTCL	MPPTCL	R
19	400	400KV Rajgarh-SSP-II	29-Dec-18	09:00	29-Dec-18	17:00	Daily	Tightening/removing of loose vibration damper & other line maintenance work	MPPTCL	MPPTCL	R

D. 220 KV LINES											
1	220	220KV Mehgaon -Malanpur	03-Dec-18	09:00	03-Dec-18	17:00	Daily	For post monsoon maintenance / Testing work	MPPTCL	MPPTCL	R
2	220	220KV Gwalior(PGCIL)-Malanpur-I	04-Dec-18	09:00	04-Dec-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
3	220	220 KV ICT II at 220KV S/s Sukha	04-Dec-18	9:00	05-Dec-18	17:00	Continue	For post monsoon maintenance / Testing work	MPPTCL	MPPTCL	R
4	220	220KV Gwalior(PGCIL)-Malanpur-II	05-Dec-18	09:00	05-Dec-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
5	220	220KV Bhanpura-Kota (Sakatpur)	06-Dec-18	09:00	06-Dec-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
6	220	220KV Bhanpura-Modak	07-Dec-18	09:00	07-Dec-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
7	220	220KV Damoh-Katni	08-Dec-18	10:00	08-Dec-18	17:00	Daily	For post monsoon maintenance / Testing work	MPPTCL	MPPTCL	R
8	220	220 KV ICT I at 220KV S/s Sukha	09-Dec-18	9:00	10-Dec-18	17:00	Continue	For Isolator replacement work.	MPPTCL	MPPTCL	R
9	220	220KV Gwalior(PGCIL)-Mahalgaon-I	11-Dec-18	09:00	11-Dec-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
10	220	220KV Gwalior(PGCIL)-Mahalgaon-II	12-Dec-18	09:00	12-Dec-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
11	220	220KV Malanpur-Auriya	18-Dec-18	09:00	18-Dec-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
12	220	220KV Mahegaon-Auriya	19-Dec-18	09:00	19-Dec-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
13	220	220KV Pandhurna-Kamleshwar	21-Dec-18	09:00	21-Dec-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
14	220	220KV Malanpur-Adani	21-Dec-18	09:00	21-Dec-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
15	220	220KV Mahgaon-Adani	22-Dec-18	09:00	22-Dec-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
16	220	220KV Annupur-Kotmikala-I	26-Dec-18	10:00	26-Dec-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
17	220	220KV Annupur-Kotmikala-II	31-Dec-18	10:00	31-Dec-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R