

APPROVED SHUT DOWN OF TRANSMISSION ELEMENTS FOR THE PERIOD FROM 01.01.19 TO 31.01.19, PROPOSED IN 514th OCC MEETING TO BE HELD ON 12.12.18 AT WRPC, MUMBAI												
Approved Shut down of 400 KV Transmission elements (01.01.19 to 31.01.19)												
Sr. No	KV	Line	From		To		Basis	Reason	System	Agency	Type	
			Date	Time	Date	Time						
A 400KV TRANSFORMER												
1	400	315 MVA xmer 1 at 400KV S/s Bhopal	02-Jan-19	8:00	2-Jan-19	18:00	Daily	Testing of Main and Tie CB after replacement of CB and CT under PSDF scheme	MPPTCL	MPPTCL	R	
B 400 KV REACTORS												
1	400	80 MVAR Reactor 1 at 400KV S/s Bhopal	21-Jan-19	8:00	28-Jan-19	18:00	Continue	For rectification of oil leakage problem and maintenance work	MPPTCL	MPPTCL	R	
2	400	80 MVAR Reactor 2 at 400KV S/s Bhopal	29-Jan-19	08:00	02-Feb-19	18:00	Continue	For rectification of oil leakage problem and maintenance work	MPPTCL	MPPTCL	R	
C 400 KV FEEDER & BAYS OF 400 KV- S/S.												
1	400	400KV Nagda-Rajgarh-I	3-Jan-19	09:00	3-Jan-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
2	400	400KV Bhopal-PGCIL Itarsi-II	4-Jan-19	08:00	4-Jan-19	18:00	Daily	Testing of Main and Tie CB after replacement of CB and CT under PSDF scheme. Lie will be under shutdown.	MPPTCL	MPPTCL	R	
3	400	400KV Sarni-Seoni	4-Jan-19	09:00	4-Jan-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
4	400	400KV Nagda-Rajgarh-II	4-Jan-19	09:00	4-Jan-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
5	400	400KV Bhopal-II Tie CB at PG Itarsi	7-Jan-19	09:00	17-Jan-19	18:00	Continue	Replacement of 400 Kv CB and 3 400 Kv CT under PSDF Scheme. Line will remain charged through Tie CB	MPPTCL	MPPTCL	R	
6	400	400KV Nagda-ISP	15-Jan-19	08:00	16-Jan-19	17:00	Continue	Replacement of Wave Trap & Relay Testing Work	MPPTCL	MPPTCL	R	
7	400	400KV Seoni-Bhilai	15-Jan-19	09:00	15-Jan-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
8	400	400KV Rajgarh-SSP-I	15-Jan-19	09:00	15-Jan-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
9	400	400KV Rajgarh-SSP-II	16-Jan-19	09:00	16-Jan-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
10	400	400KV Indore-ISP-II	17-Jan-19	09:00	17-Jan-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
11	400	400KV Bhopal-II Tie CB at PG Itarsi	18-Jan-19	09:00	18-Jan-19	18:00	Daily	Testing work after replacement of CB. Line will be under shutdown	MPPTCL	MPPTCL	R	
12	400	400KV Indore-ISP-II	19-Jan-19	09:00	19-Jan-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
13	400	400KV Bhopal-BDTCL-I	21-Jan-19	08:00	21-Jan-19	18:00	Daily	Testing of Main and Tie CB after replacement of CB and CT under PSDF scheme. Lie will be under shutdown.	MPPTCL	MPPTCL	R	
14	400	400KV Sarni-Seoni	22-Jan-19	07:00	22-Jan-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
15	400	400KV Nagda-ISP	28-Jan-19	09:00	28-Jan-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
16	400	400KV Nagda-ISP	29-Jan-19	09:00	29-Jan-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	

D. 220 KV LINES											
1	220	220KV ICT-I at 220KV S/s Sukha	03-Jan-19	9:00	04-Jan-19	17:00	Continue	For maintnace work.	MPPTCL	MPPTCL	R
2	220	220KV Gwalior(PGCIL)-Malanpur-I	03-Jan-19	09:00	03-Jan-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
3	220	220KV Gwalior(PGCIL)-Malanpur-II	05-Jan-19	09:00	05-Jan-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
4	220	220KV ICT-II at 220KV S/s Sukha	08-Jan-19	9:00	10-Jan-19	17:00	Continue	For breaker replacement work.	MPPTCL	MPPTCL	R
5	220	220KV Mahalgaon-Gwalior PGCIL-I	09-Jan-19	09:00	09-Jan-19	17:00	Daily	Bay Maintenance work & Main bus Isolator replacement work under PSDF Scheme	MPPTCL	MPPTCL	R
6	220	220KV Pandhurna-Kamleshwar	09-Jan-19	09:00	09-Jan-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
7	220	220KV Mahalgaon-Gwalior PGCIL-II	11-Jan-19	09:00	11-Jan-19	17:00	Daily	Bay Maintenance work & Main bus Isolator replacement work under PSDF Scheme	MPPTCL	MPPTCL	R
8	220	220KV Chhegaon-Khandwa (PGCIL)-I	14-Jan-19	10:00	14-Jan-19	18:00	Daily	Pre-monsoon maintenance work.	MPPTCL	MPPTCL	R
9	220	220KV Malanpur-Aouriya	15-Jan-19	09:00	15-Jan-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
10	220	220KV Mahalgaon-Bina	16-Jan-19	09:00	16-Jan-19	17:00	Daily	Bay Maintenance work & Main bus Isolator replacement work under PSDF Scheme	MPPTCL	MPPTCL	R
11	220	220KV Mahegaon-Aouriya	16-Jan-19	09:00	16-Jan-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
12	220	220KV Chhegaon-Khandwa (PGCIL)-II	16-Jan-19	10:00	16-Jan-19	18:00	Daily	Pre-monsoon maintenance work.	MPPTCL	MPPTCL	R
13	220	220KV Mahalgaon-Datia	18-Jan-19	09:00	18-Jan-19	17:00	Daily	Bay Maintenance work & Main bus Isolator replacement work under PSDF Scheme	MPPTCL	MPPTCL	R
14	220	220KV Malanpur-Adani	22-Jan-19	09:00	22-Jan-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
15	220	220KV Mahgaon-Adani	23-Jan-19	09:00	23-Jan-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
16	220	220KV Annupur-Kotmikala-I	28-Jan-19	10:00	28-Jan-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
17	220	220KV Annupur-Kotmikala-II	31-Jan-19	10:00	31-Jan-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R