

SUB :- APPROVED SHUT DOWN OF TRANSMISSION ELEMENTS FOR THE PERIOD FROM 01.06.19 TO 30.06.19, APPROVED IN 519th OCC MEETING TO BE HELD ON DT 15.05.19 AT WRPC, MUMBAI												
Approved Shut down of 400 KV Transmission elements (01.06.19 to 30.06.19)												
Sr. No	KV	Line	From		To		Basis	Reason	System	Agency	Type	
			Date	Time	Date	Time						
A 400KV TRANSFORMER/REACTORS/FEEDERS												
1	400	400KV Indore-ISP-II reactor at 400KV S/s Indore	1-Jun-19	9:00	3-Jun-19	18:00	Continue	For replacement of Line Isolator of 400KV ISP-II Reactor. Line will be kept OFF	MPPTCL	MPPTCL	R	
2	400	400KV Damoh-Katni	3-Jun-19	9:00	3-Jun-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
3	400	400KV Rajgarh-SSP-I	4-Jun-19	8:00	4-Jun-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
4	400	400KV Seoni-Kimapur	4-Jun-19	9:00	4-Jun-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
5	400	400KV Rajgarh-SSP-II	5-Jun-19	8:00	5-Jun-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
6	400	315MVA Transformer-IV at 400KV S/s Bhopal	10-Jun-19	8:00	12-Jun-19	18:00	Continue	For attending oil leakage from transformer by M/s BHEL and attending problem of 33KV Tertiary isolator	MPPTCL	MPPTCL	R	
7	400	400KV Main Bus - I at 400KV S/s Nagda	10-Jun-19	8:00	12-Jun-19	18:00	Continue	For replacement of disc insulator strings	MPPTCL	MPPTCL	R	
8	400	315MVA ICT-I at 400KV S/s Indore	13-Jun-19	9:00	16-Jun-19	18:00	Continue	For pre monsoon maintenance and testing of transformer . replacement of 400KV isolator under PSDF (transformer-I will be OFF) and completion of balance OLTC and conservator work by M/s BHEL	MPPTCL	MPPTCL	R	
9	400	400KV Main Bus-I at 400KV S/s Bina	13-Jun-19	8:00	21-Jun-19	17:00	Continue	For replacement of PG isolator & circuit breaker	MPPTCL	MPPTCL	R	
10	400	400KV ISP-Indore I	13-Jun-19	9:00	13-Jun-19	18:00	Daily	Annual Maintenance work & Relay Testing work	NHDC	NHDC	R	
11	400	400KV Main Bus - II at 400KV S/s Nagda	13-Jun-19	8:00	15-Jun-19	18:00	Continue	For replacement of disc insulator strings	MPPTCL	MPPTCL	R	
12	400	400KV ISP-Indore II	14-Jun-19	8:00	14-Jun-19	18:00	Daily	Annual Maintenance work & Relay Testing work	NHDC	NHDC	R	
13	400	400KV ISP-Sami	15-Jun-19	8:00	15-Jun-19	18:00	Daily	Annual Maintenance work & Relay Testing work	NHDC	NHDC	R	
14	400	400KV Nagda-Indore	16-Jun-19	8:00	16-Jun-19	18:00	Daily	For replacement of disc insulator strings	MPPTCL	MPPTCL	R	
15	400	400KV Bhopal-Bina-I	16-Jun-19	9:00	16-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
16	400	400KV ISP-Nagda	17-Jun-19	9:00	17-Jun-19	18:00	Daily	Annual Maintenance work & Relay Testing work	NHDC	NHDC	R	
17	400	400KV Pithampur-PGCL-I	17-Jun-19	10:00	17-Jun-19	17:00	Daily	For bay equipment maintenance and testing work	MPPTCL	MPPTCL	R	
18	400	400KV Bhopal-Bina-II	18-Jun-19	9:00	18-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
19	400	400KV Main Bus-I at 400KV S/s ISP	18-Jun-19	8:00	18-Jun-19	18:00	Daily	Annual Maintenance work & Relay Testing work	NHDC	NHDC	R	
20	400	400KV Pithampur-PGCL-II	18-Jun-19	10:00	18-Jun-19	17:00	Daily	For bay equipment maintenance and testing work	MPPTCL	MPPTCL	R	
21	400	400KV Main Bus-II at 400KV S/s ISP	19-Jun-19	8:00	19-Jun-19	18:00	Daily	Annual Maintenance work & Relay Testing work	NHDC	NHDC	R	
22	400	400KV Bhopal-Itarsi (PGCL)-I	19-Jun-19	7:00	19-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
23	400	400KV Sami-Seoni	19-Jun-19	7:00	19-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
24	400	400KV Main bus -II at 400KV S/s Indore	20-Jun-19	9:00	22-Jun-19	18:00	Continue	For replacement of bus-II PG isolator, Main bus II will be kept OFF	MPPTCL	MPPTCL	R	
25	400	400KV ICT -III at 400KV S/s Indore	20-Jun-19	9:00	22-Jun-19	18:00	Continue	For replacement of bus-II P-G isolator of ICT-III, ICT-III will be on TBC	MPPTCL	MPPTCL	R	
26	400	400KV Bhopal-Itarsi (PGCL)-II	20-Jun-19	7:00	20-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
27	400	400KV ICT -IV at 400KV S/s Indore	23-Jun-19	9:00	25-Jun-19	18:00	Continue	For replacement of bus I P-G isolator of ICT IV, ICT IV will be on TBC	MPPTCL	MPPTCL	R	
28	400	400KV Main bus -I at 400KV S/s Indore	23-Jun-19	9:00	25-Jun-19	18:00	Continue	For replacement of bus I P-G isolator of ICT IV, Main bus I will be kept OFF	MPPTCL	MPPTCL	R	
29	400	400KV Main Bus-II at 400KV S/s Bina	24-Jun-19	8:00	29-Jun-19	17:00	Continue	For replacement of PG isolator	MPPTCL	MPPTCL	R	
30	400	400KV Indore-Nagda	24-Jun-19	9:00	27-Jun-19	18:00	Continue	For replacement of Line Isolators of 400 KV Nagda, Line will be kept OFF	MPPTCL	MPPTCL	R	
31	400	400KV Bina- Satna(PGCL) -III	25-Jun-19	8:00	30-Jun-19	18:00	Continue	For LLO arrangement at newly constructed 400KV S/s Sagar	MPPTCL	MPPTCL	C	

Approved Shut down of 400 KV Transmission elements (01.06.19 to 30.06.19)												
Sr.No	KV	Line	From		To		Basis	Reason	System	Agency	Type	
			Date	Time	Date	Time						
B 220KV FEEDERS												
1	220	220KV Gwalior(PGCIL)-Malanpur-I	3-Jun-19	9:00	3-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
2	220	220KV ICT 1 at 220KV S/s Sukha	3-Jun-19	9:00	4-Jun-19	17:00	Continue	For bay equipment maintenance and testing work	MPPTCL	MPPTCL	R	
3	220	220KV Gwalior(PGCIL)-Malanpur-II	4-Jun-19	9:00	4-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
4	220	220KV Gwalior(PGCIL)-Mahalgaon-I	7-Jun-19	9:00	7-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
5	220	220KV Gwalior(PGCIL)-Mahalgaon-II	8-Jun-19	9:00	8-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
6	220	220KV Sabalgarh-Adani	11-Jun-19	9:00	11-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
7	220	220KV Malanpur-Aauriya	14-Jun-19	9:00	14-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
8	220	220KV Pandhurna-Kamleshwar	14-Jun-19	9:00	14-Jun-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
9	220	220KV Mehegoan-Aauriya	15-Jun-19	9:00	15-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
10	220	220KV Annupur-Kotmikala-I	26-Jun-19	10:00	26-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
11	220	220KV Bhanpura-Ranpur(Kola)	27-Jun-19	8:00	27-Jun-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
12	220	220KV Bhanpura-Modak	28-Jun-19	8:00	28-Jun-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
13	220	220KV Malanpur-Adani	28-Jun-19	9:00	28-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
14	220	220KV Mahgaon-Adani	29-Jun-19	9:00	29-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
15	220	220KV Annupur-Kotmikala-II	29-Jun-19	10:00	29-Jun-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	