

SUB :- APPROVED SHUT DOWN OF TRANSMISSION ELEMENTS FOR THE PERIOD FROM 01.03.19 TO 31.03.19, APPROVED IN 515th OCC MEETING TO BE HELD on DT 11.02.19 AT WRPC, MUMBAI											
Approved Shut down of 400 KV Transmission elements ( 01.03.19 to 31.03.19 )											
Sr. No	KV	Line	From		To		Basis	Reason	System	Agency	Type
			Date	Time	Date	Time					
<b>A 400KV TRANSFORMER</b>											
1	400	315MVA ICT-IV at 400KV S/s Indore	5-Mar-19	9:00	8-Mar-19	18:00	Continue	Transformer maintenacne work and replacement of line isoaltor under PSDF ICT-IV will be off	MPPTCL	MPPTCL	R
2	400	315MVA CGL-III Transformer at 400KV S/s Bina	11-Mar-19	9:00	14-Mar-19	17:00	Continue	For pre monsoon maintenance and attending oil leakage	MPPTCL	MPPTCL	R
3	400	315MVA ICT-III at 400KV S/s Indore	15-Mar-19	9:00	18-Mar-19	18:00	Continue	Transformer maintenacne work and replacement of line isoaltor under PSDF ICT-III will be off	MPPTCL	MPPTCL	R
4	400	315MVA ICT-II at 400KV S/s Indore	26-Mar-19	9:00	29-Mar-19	18:00	Continue	Transformer maintenacne work and replacement of line isoaltor under PSDF ICT-II will be off	MPPTCL	MPPTCL	R
<b>B 400 KV REACTORS</b>											
1	400	80MVAr Reactor 1 at 400KV S/s Bhopal	22-Mar-19	8:00	30-Mar-19	18:00	Continue	For attending oil leakage	MPPTCL	MPPTCL	R
2	400	50MVAr Badnawar-II Line Reactor at 400KV S/s Nagda	27-Mar-19	8:00	27-Mar-19	17:00	Daily	For attending oil leakage	MPPTCL	MPPTCL	R
<b>C 400 KV FEEDER &amp; BAYS OF 400 KV- S/S.</b>											
1	400	400KV Bhopal-II Tie CB at PG Itarsi	04-Mar-19	8:00	20-Mar-19	8:00	Continue	Replacement of Tie CB and Tie CT under PSDF Scheme.	MPPTCL	MPPTCL	R
2	400	400KV Nagda-Rajgarh-I	11-Mar-19	9:00	11-Mar-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
3	400	400KV Katni-Damoh-I	12-Mar-19	9:00	12-Mar-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
4	400	400KV Nagda-Rajgarh-II	12-Mar-19	9:00	12-Mar-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
5	400	400KV Rajgarh-SSP-II	14-Mar-19	9:00	14-Mar-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
6	400	400KV Rajgarh-SSP-I	15-Mar-19	9:00	15-Mar-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
7	400	400KV Seoni-Bhilai S/C	15-Mar-19	9:00	15-Mar-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
8	400	400KV ISP-Nagda	16-Mar-19	9:00	16-Mar-19	18:00	Daily	For line maintenance work	MPPTCL	NHDC	R
9	400	400KV Bhopal-II Line at PG Itarsi	20-Mar-19	8:00	20-Mar-19	18:00	Daily	Testing work after replacement of CB and CT. Line will be under shutdown	MPPTCL	MPPTCL	R
10	400	400KV Indore-ISP-II	22-Mar-19	9:00	25-Mar-19	18:00	Continue	For replacement of line side isolator under PSDF, ISP-II line will be kept OFF	MPPTCL	MPPTCL	R
11	400	400KV ISP-Nagda	27-Mar-19	10:00	29-Mar-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R

D. 220 KV LINES											
1	220	220KV Gwalior(PGCIL)-Mahalgaon-I	07-Mar-18	9:00	7-Mar-18	17:00	Daily	For bay equipment maintenance and testing work	MPPTCL	MPPTCL	R
2	220	220KV Ujjain- Indore PGCIL-I	5-Mar-19	9:00	5-Mar-19	17:00	Daily	For bay equipment maintenance and testing work	MPPTCL	MPPTCL	R
3	220	220KV Ujjain- Indore PGCIL-I	6-Mar-19	9:00	6-Mar-19	17:00	Daily	For bay equipment maintenance and testing work	MPPTCL	MPPTCL	R
4	220	220KV Gwalior(PGCIL)-Malanpur-II	6-Mar-19	9:00	6-Mar-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
5	220	220KV ICT-I at 220KV S/s Sukha	6-Mar-19	9:00	8-Mar-19	17:00	Continue	For maintenance and testing work	MPPTCL	MPPTCL	R
6	220	220KV Gwalior(PGCIL)-Mahalgaon-II	8-Mar-19	9:00	8-Mar-19	17:00	Daily	For bay equipment maintenance and testing work	MPPTCL	MPPTCL	R
7	220	220KV Damoh-Katni	11-Mar-19	9:00	11-Mar-19	17:00	Daily	For bay equipment maintenance and testing work	MPPTCL	MPPTCL	R
8	220	220KV ICT-II at 220KV S/s Sukha(Jabalpur)	12-Mar-19	9:00	14-Mar-19	17:00	Continue	For maintenance and testing work	MPPTCL	MPPTCL	R
9	220	220KV Malanpur-Aouriya	19-Mar-19	9:00	19-Mar-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
10	220	220KV Pandhurna-Kamleshwar	19-Mar-19	9:00	19-Mar-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
11	220	220KV Mahegaon-Aouriya	20-Mar-19	9:00	20-Mar-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
12	220	220KV Annupur-Kotmikala-I	25-Mar-19	10:00	25-Mar-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
13	220	220KV Malanpur-Adani Morena	28-Mar-19	9:00	28-Mar-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
14	220	220KV Mahgaon-Morena(Adani)	29-Mar-19	9:00	29-Mar-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
15	220	220KV Annupur-Kotmikala-II	29-Mar-19	10:00	29-Mar-19	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R