

WRPC 497th OCC APPROVED SHUTDOWNS FOR AUGUST 2017

**ALL INTRA STATE ENTITIES ARE REQUESTED TO GIVE THEIR READINESS FOR AVAILING SHUTDOWN ON D-3 BASIS
ELSE THE SHUTDOWN MAY BE TREATED AS DEEMED CANCEL**

Sr No	KV	Line / Element	From	To	Basis	Reason	System	Agency	Type		
1	400	400 KV BHOPAL 315MVA X'mer-III & Itarsi-I Tie CB	01.08.17	9:00	04.08.17	17:00	cont.	For replacement of 6 NO. TIE CT	MPPTCL	MPPTCL	R
2	400	400KV NAGDA Main CB of ICT-III X'mer	02.08.17	8:00	11.08.17	18:00	cont.	For replacement of CB	MPPTCL	MPPTCL	R
3	220	220KV Rajgarh(PGCIL) -Rajgarh I/C-I	03.08.17	9:00	03.08.17	16:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
4	220	220KV Damoh-Sagar (PGCIL) -II	03.08.17	8:00	03.08.17	18:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
5	220	220KV Rajgarh(PGCIL) -Rajgarh I/C-II	04.08.17	9:00	04.08.17	16:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
6	400	400 KV JULWANIA 315MVA X'mer-II (EMCO)	04.08.17	9:00	04.08.17	18:00	daily	For commissioning Of NIFPS System of transformer	MPPTCL	MPPTCL	R
7	400	400KV Bus Tie at 400 KV s/s Julwania	05.08.17	9:00	05.08.17	18:00	daily	FOR PMM Work	MPPTCL	MPPTCL	R
8	220	220KV Dhar - Rajgarh(PGCIL)	05.08.17	9:00	05.08.17	16:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
9	400	400KV Main CB of Itarsi -I at 400 kv S/S Bhopal	08.08.17	9:00	09.08.17	17:00	cont.	FOR 3 NO MAIN CT REPLACEMENT WORK	MPPTCL	MPPTCL	R
10	0	220KV Pithampur - Rajgarh(PGCIL) -II	08.08.17	9:00	08.08.17	16:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
11	220	220KV Seoni (PGCIL)-Chhindwara -I	08.08.17	9:00	08.08.17	18:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
12	400	400KV Birsinghpur-Katni -II	09.08.17	8:00	09.08.17	18:00	daily	FOR LINE / BAY MAINTENANCE WORK	MPPTCL	MPPTCL	R
13	220	220KV Badod-Kota	09.08.17	9:00	09.08.17	18:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
14	220	220KV Gwalior(PGCIL)-Malanpur -I	09.08.17	9:00	09.08.17	17:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
15	400	400 KV JULWANIA 315MVA X'mer-I (CGL)	09.08.17	9:00	12.08.17	17:00	cont.	For replacement of transformer Aircell	MPPTCL	MPPTCL	R
16	220	220KV Badod-Modak	10.08.10	9:00	10.08.17	18:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
17	220	220KV Seoni (PGCIL)-Chhindwara II	10.08.17	9:00	10.08.17	18:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
18	220	220KV Gwalior(PGCIL)-Malanpur II	10.08.17	9:00	10.08.17	17:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
19	220	220KV Gwalior(PGCIL)-Mahalgaon -I	11.08.17	9:00	11.08.17	17:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
20	400	400KV I.S.P. - Nagda	11.08.17	8:00	11.08.17	17:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
21	400	400KV NAGDA ICT-III X'mer	11.08.17	8:00	11.08.17	17:00	daily	For new CB testing work	MPPTCL	MPPTCL	R
22	220	220KV Gwalior(PGCIL)-Mahalgaon -II	12.08.17	9:00	12.08.17	17:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
23	400	400KV Indore- Nagda	14.08.17	7:00	14.08.17	18:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
24	400	400 KV NAGDA Tie CB of 400KV ICT-III & 400KV Indore line	16.08.17	8:00	26.08.17	18:00	cont.	For replacement of CB	MPPTCL	MPPTCL	R
25	400	400 KV BHOPAL 315MVA X'mer-I & BDTCL-1 Tie CB	16.08.17	9:00	19.08.17	17:00	cont.	For replacement of 6 NO. TIE CT	MPPTCL	MPPTCL	R
26	400	400KV S.S.P.-Rajgarh(PGCIL) -I	17.08.17	7:00	17.08.17	19:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
27	400	400KV Seoni(PGCIL)-Sarni	17.08.17	9:00	17.08.17	18:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R

28	220	220KV Seoni (PGCIL) –Seoni -I	17.08.17	10:00	17.08.17	16:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
29	220	220KV Malanpur-Auriya	17.08.17	9:00	17.08.17	17:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
30	400	400KV S.S.P.-Rajgarh(PGCIL)-II	18.08.17	7:00	18.08.17	19:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
31	220	220KV Seoni (PGCIL) –Seoni -II	18.08.17	10:00	18.08.17	16:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
32	220	220KV Damoh-Tikamgarh (PGCIL)	18.08.17	8:00	18.08.17	18:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
33	220	220KV Mahegaon-Auriya	18.08.17	9:00	18.08.17	17:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
34	400	400KV SSTPS- Pithampur- I	18.08.17	9:00	18.08.17	16:00	daily	FOR LINE / BAY MAINTENANCE WORK	MPPTCL	MPPTCL	R
35	400	400KV SSTPS- Pithampur- II	19.08.17	9:00	19.08.17	16:00	daily	FOR LINE / BAY MAINTENANCE WORK	MPPTCL	MPPTCL	R
36	400	400KV Pithampur-Indore (PGCIL Hathuniya) -I	20.08.17	9:00	20.08.17	16:00	daily	FOR MAINTENANCE AND TESTING WORK	MPPTCL	MPPTCL	R
37	400	400KV Damoh-Katni	21.08.17	8:00	21.08.17	18:00	daily	FOR LINE / BAY MAINTENANCE WORK	MPPTCL	MPPTCL	R
38	400	400KV Main CB of Itarsi -II at 400 kv S/S Bhopal	21.08.17	9:00	22.08.17	17:00	cont.	FOR 3 NO MAIN CT REPLACEMENT WORK	MPPTCL	MPPTCL	R
39	400	400 KV S/S NAGDA 400KV 125 MVAR BUS REACTOR - II	22.08.17	8:00	23.08.17	18:00	cont.	For main CT replacement work	MPPTCL	MPPTCL	R
40	220	220KV Panduran-Kalmeshwar	22.08.17	9:00	22.08.17	18:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
41	400	400KV Nagda-Rajgarh-I	22.08.17	8:00	22.08.17	17:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
42	400	400KV Chhegoan-SSTPS(MALWA)	22.08.17	9:00	22.08.17	16:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
43	400	400KV Nagda -Rajgarh-II	23.08.17	8:00	23.08.17	17:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
44	400	400KV Julwania-SSTPS(MALWA)	23.08.17	9:00	23.08.17	16:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
45	400	400KV Pithampur-Indore (PGCIL Hathuniya) -II	24.08.17	9:00	24.08.17	16:00	daily	FOR MAINTENANCE AND TESTING WORK	MPPTCL	MPPTCL	R
46	400	400KV Main CB of Bina -II at 400 kv S/S Bhopal	24.08.17	9:00	25.08.17	17:00	cont.	FOR 3 NO MAIN CT REPLACEMENT WORK	MPPTCL	MPPTCL	R
47	220	220KV Damoh-Damoh (PGCIL) -I	24.08.17	8:00	24.08.17	18:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
48	220	220KV Annupur-Kotmikala- I	25.08.17	10:00	25.08.17	18:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
49	220	220KV Bina(PGCIL)-Shivpuri	25.08.17	9:00	25.08.17	17:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
50		400KV I.S.P. - Indore I	26.08.17	09:00	26.08.17	16:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
51	400	400KV Tie CB of Itarsi -II & Bina -II at 400 kv S/S Bhopal	28.08.17	9:00	31.08.17	17:00	cont.	FOR 6 NO TIE CT REPLACEMENT WORK	MPPTCL	MPPTCL	R
52	220	220KV Damoh-Damoh (PGCIL) -II	29.08.17	8:00	29.08.17	18:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
53	400	400KV I.S.P. - Indore II	30.08.17	9:00	30.08.17	16:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R
54	220	220KV Annupur-Kotmikala -II	30.08.17	10:00	30.08.17	18:00	daily	FOR LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R