

WRPC 501st OCC APPROVED SHUTDOWNS FOR DECEMBER 2017

ALL INTRA STATE ENTITIES ARE REQUESTED TO GIVE THEIR READINESS FOR AVAILING SHUTDOWN ON D-3 BASIS ELSE THE SHUTDOWN MAY BE TREATED AS DEEMED CANCEL

Sr No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type
1	400	400KV Nagda-Rajgarh-I	01 December 2017	8:00	07 December 2017	18:00	Daily	For replacement of disc insulator indentified by PID through outsource agency	MPPTCL	MPPTCL	R
2	400	400KV ISP-Nagda	01 December 2017	9:00	01 December 2017	18:00	Daily	For post monsoon maintenance work	MPPTCL	MPPTCL	R
3	220	220KV Badod-Kota line	03 December 2017	8:00	03 December 2017	17:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
4	400	315 MVA ICT -I at 400 KV (SSTPS) Singhaji S/S	04 December 2017	8:00	10 December 2017	17:00	Continue	Transformer Testing , cleaning & terminal tightness of panel, protection relay testing work	MPPTCL	MPPTCL	R
5	220	220KV Bhanpura-Modak	04 December 2017	8:00	04 December 2017	17:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
6	400	400 KV Seoni- Sarni	05 December 2017	9:00	06 December 2017	18:00	Daily	For replacement of CT & LMU & testing of carrier protection and CB.	MPPTCL	MPPTCL	R
7	400	400KV Indore (PGCIL Hanuniya)-Pithampur-I	06 December 2017	9:00	06 December 2017	16:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
8	220	220KV Malanpur-Aouriya	07 December 2017	9:00	07 December 2017	17:00	Daily	For bay equipemnt/ line maintenance work	MPPTCL	MPPTCL	R
9	400	400KV Nagda-Rajgarh-II	08 December 2017	8:00	15 December 2017	18:00	Daily	For replacement of disc insulator indentified by PID through outsource agency	MPPTCL	MPPTCL	R
10	400	400KV Indore (PGCIL Hanuniya)-Pithampur-II	08 December 2017	9:00	08 December 2017	16:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
11	400	400KV Seoni-Bhilai	08 December 2017	9:00	08 December 2017	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
12	220	220KV Mahegaon-Aouriya	08 December 2017	9:00	08 December 2017	17:00	Daily	For bay equipemnt/ line maintenance work	MPPTCL	MPPTCL	R
13	400	400KV Indore- ISP-II	11 December 2017	10:00	16 December 2017	18:00	Continue	For bay equipment maintenance and attending CT oil leakage.	MPPTCL	MPPTCL	R
14	400	400KV Damoh (PGCIL)-Katni	11 December 2017	8:00	11 December 2017	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
15	400	400KV Itarsi-Bhopal-I	12 December 2017	9:00	12 December 2017	18:00	Daily	For line signature analysis & post moonson line maintenance work	MPPTCL	MPPTCL	R

16	220	220KV Gwalior(PGCIL)-Malanpur-I	12 December 2017	9:00	12 December 2017	17:00	Daily	For bay equipemnt/ line maintenance work	MPPTCL	MPPTCL	R
17	400	400KV Itarsi-Bhopal-II	13 December 2017	9:00	13 December 2017	18:00	Daily	For line signature analysis & post moonson line maintenance work	MPPTCL	MPPTCL	R
18	220	220KV Gwalior(PGCIL)-Malanpur-II	13 December 2017	9:00	13 December 2017	17:00	Daily	For bay equipemnt/ line maintenance work	MPPTCL	MPPTCL	R
19	400	400KV Nagda-ISP	18 December 2017	9:00	18 December 2017	16:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
20	400	400KV Bhopal-Bina-I	19 December 2017	9:00	19 December 2017	18:00	Daily	For line signature analysis & post moonson line maintenance work	MPPTCL	MPPTCL	R
21	400	400KV Bhopal-Bina-II (main CB) at 400KV S/s Bhopal	20 December 2017	9:00	30 December 2017	17:00	Daily	For 400KV CB replacement work	MPPTCL	MPPTCL	R
22	220	220KV Chhegaon-Khandwa (PGCIL)-II	21 December 2017	9:00	21 December 2017	16:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
23	220	220KV Khandwa(PGCIL)-Nepanagar	22 December 2017	9:00	22 December 2017	16:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
24	220	220KV Gwalior(PGCIL)-Mahalgaon-I	24 December 2017	9:00	24 December 2017	17:00	Daily	Line Maintenance Works & Isolator replacement under PSDF	MPPTCL	MPPTCL	R
25	220	220KV Gwalior(PGCIL)-Mahalgaon-II	25 December 2017	9:00	25 December 2017	17:00	Daily	Line Maintenance Works & Isolator replacement under PSDF	MPPTCL	MPPTCL	R
26	400	400KV ISP-Indore-I	26 December 2017	9:00	26 December 2017	16:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
27	220	220KV Annupur-Kotmikala-I	27 December 2017	10:00	27 December 2017	17:00	Daily	For bay equipemnt/ line maintenance work	MPPTCL	MPPTCL	R
28	400	400KV Rajgarh-SSP-I	28 December 2017	8:00	28 December 2017	18:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
29	400	400KV Seoni-Sarni	28 December 2017	9:00	28 December 2017	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
30	220	220KV Pandurna-Kalmeshwar	28 December 2017	9:00	28 December 2017	18:00	Daily	For bay equipemnt/ line maintenance work	MPPTCL	MPPTCL	R
31	400	400KV Rajgarh-SSP-II	29 December 2017	8:00	29 December 2017	18:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
32	400	400KV ISP-Indore-II	30 December 2017	9:00	30 December 2017	16:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
33	220	220KV Annupur-Kotmikala-II	30 December 2017	10:00	30 December 2017	17:00	Daily	For bay equipemnt/ line maintenance work	MPPTCL	MPPTCL	R