

ALL INTRA STATE ENTITIES ARE REQUESTED TO GIVE THEIR READINESS FOR AVAILING SHUTDOWN ON D-3 BASIS ELSE THE SHUTDOWN MAY BE TREATED AS DEEMED CANCEL .ALL APPROVED OCCM SHUTDOWN AVAILABLE AT SLDC & WRPC WEB-SITE.

SUB :- APPROVED SHUT DOWN OF TRANSMISSION ELEMENTS FOR THE PERIOD FROM 01.05.18 TO 31.05.18, PROPOSED IN 506th OCC MEETING TO BE HELD ON 21.04.18 AT WRPC, MUMBAI

**Approved Shut down of 400 KV Transmission elements
(01.05.18 to 31.05.18)**

Sr. No	KV	Line	From		To		Basis	Reason	System	Agency	Type
			Date	Time	Date	Time					
A.	400 KV TRANSFORMER										
	NIL										
B.	400 KV REACTORS										
1	400	80MVAR REACTOR NO -01 at 400KV S/s Bhopal	14-May-18	09:00	24-May-18	17:00	Continue	For scheduled maintenance and testing work	MPPTCL	MPPTCL	R
C.	400 KV FEEDER & BAYS OF 400 KV- S/S.										
1	400	400KV Bhopal-BDTCL-1	2-May-18	09:00	2-May-18	17:00	Daily	For scheduled maintenance and testing work	MPPTCL	MPPTCL	R
2	400	400KV Bhopal-BDTCL-2	3-May-18	09:00	3-May-18	17:00	Daily	For scheduled maintenance and testing work	MPPTCL	MPPTCL	R
3	400	TIE CB 400KV BDTCL-2 X-MER-2 at 400KV S/s Bhopal	04-May-18	09:00	04-May-18	17:00	Daily	For scheduled maintenance and testing work	MPPTCL	MPPTCL	R
4	400	400KV Indore (PGCIL Hanuniya)-Pithampur-I	5-May-18	10:00	5-May-18	17:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
5	400	TIE CB 400KV BDTCL-1 X-MER-1 at 400KV S/s Bhopal	7-May-18	09:00	7-May-18	17:00	Daily	For scheduled maintenance and testing work	MPPTCL	MPPTCL	R
6	400	400KV Indore-ISP-I	07-May-18	08:00	07-May-18	18:00	Daily	For Relay Testing work	NHDC	NHDC	R
7	400	400KV Nagda-ISP	08-May-18	08:00	08-May-18	18:00	Daily	For Relay Testing work	NHDC	NHDC	R
8	400	400KV Indore-ISP-II	09-May-18	08:00	09-May-18	18:00	Daily	For Relay Testing work	NHDC	NHDC	R
9	400	400KV Rajgarh-SSP-I	12-May-18	07:00	12-May-18	19:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
10	400	400KV ISP-Indore-I	12-May-18	10:00	12-May-18	17:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
11	400	400KV Indore (PGCIL Hanuniya)-Pithampur-II	13-May-18	10:00	13-May-18	17:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
12	400	400KV Rajgarh-SSP-II	13-May-18	07:00	13-May-18	19:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R
13	400	400KV Nagda-Rajgarh(PGCIL)-II Line at 400KV S/S Nagda	14-May-18	07:00	14-May-18	18:00	Daily	For Disc insulator replacement work	MPPTCL	MPPTCL	R
14	400	400KV Nagda-Rajgarh(PGCIL)-II Line at 400KV S/S Nagda	15-May-18	07:00	16-May-18	18:00	Continue	For Disc insulator replacement work	MPPTCL	MPPTCL	R

15	400	400KV Bhopal-Itarsi (PGCIL)-I	15-May-18	09:00	15-May-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
16	400	400KV ISP-Indore-II	16-May-18	10:00	16-May-18	17:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R	
17	400	400KV Bhopal-Itarsi (PGCIL)-II	16-May-18	09:00	16-May-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
18	400	400KV ISP-Indore-II	17-May-18	10:00	17-May-18	17:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R	
19	400	400KV Seoni (PGCIL)-Sarni	18-May-18	09:00	18-May-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
20	400	400KV Nagda-ISP	19-May-18	07:00	19-May-18	19:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R	
21	400	400KV Sarni-Seoni	21-May-18	09:00	23-May-18	18:00	Continue	For replacement of static relays of distance protection main-II by numerical relays	MPPTCL	MPPTCL	R	
22	400	400KV MAIN BUS - I AT 400 KV S/s ISP	22-May-18	08:00	23-May-18	18:00	Continue	Annual Maintenance	NHDC	NHDC	R	
23	400	400KV MAIN BUS - II AT 400 KV S/s ISP	24-May-18	08:00	25-May-18	18:00	Continue	Annual Maintenance	NHDC	NHDC	R	
24	400	400KV Seoni (PGCIL)-Bhilai	28-May-18	09:00	28-May-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	

D. 220 KV LINES												
1	220	220KV Gwalior(PGCIL)-Malanpur-I	03-May-18	09:00	03-May-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
2	220	220KV Malanpur-Aouriya	04-May-18	09:00	04-May-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
3	220	220KV Mahegaon-Aouriya	05-May-18	09:00	05-May-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
4	220	220KV Sagar-Damoh PGCIL-I	07-May-18	09:00	07-May-18	17:00	Daily	For pre monsoon maintenance / Testing work	MPPTCL	MPPTCL	R	
5	220	220KV Sagar-Damoh PGCIL-II	08-May-18	09:00	08-May-18	17:00	Daily	For pre monsoon maintenance / Testing work	MPPTCL	MPPTCL	R	
6	220	220KV Gwalior(PGCIL)-Malanpur-II	09-May-18	09:00	09-May-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
7	220	220KV Chhegaon-Khandwa-I	14-May-18	10:00	14-May-18	17:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R	
8	220	220KV Gwalior(PGCIL)-Mahalgaon-I	18-May-18	09:00	18-May-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
9	220	220KV Gwalior(PGCIL)-Mahalgaon-II	19-May-18	09:00	19-May-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
10	220	220kv Rajgarh-Shujalpur (PGCIL)-I	22-May-18	09:00	22-May-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
11	220	220kv Rajgarh-Shujalpur (PGCIL)-II	23-May-18	09:00	23-May-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
12	220	220kv Annupur-Kotmikala-I	23-May-18	10:00	23-May-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
13	220	220kv Damoh (PGCIL)-Sagar -I	26-May-18	09:00	26-May-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
14	220	220KV Bhanpura-Modak	26-May-18	09:00	26-May-18	18:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R	
15	220	220KV Bhanpura-Modak	29-May-18	09:00	29-May-18	18:00	Daily	Tightening of jumper cone & arching horn & other maintenance work	MPPTCL	MPPTCL	R	
16	220	220kv Annupur-Kotmikala-II	30-May-18	10:00	30-May-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
17	220	220kv Damoh (PGCIL)-Sagar -II	31-May-18	09:00	31-May-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	

E. 132 KV LINES												
1	132	132 KV Balaghat-Bhanegoan (During S/D supply to Bhanegoan (20 mw) feed from Dongargarh s/s of Chhatisgarh)	01-May-18	09:00	05-May-18	18:00	Continue	LILO arrangement at Kirnapur 400 KV S/S	MPPTCL	MPPTCL	R	
2	132	132kv Morwa-Anpara ckt	09-May-18	09:00	15-May-18	18:00	Continue	For tower erection work.	MPPTCL	MPPTCL	R	
3	132	132kv Morwa-Bina ckt	09-May-18	09:00	15-May-18	18:00	Continue	For tower erection work.	MPPTCL	MPPTCL	R	

SHUTDOWN NOT CONSIDERED

9	220	220KV Badod-Kota	18-May-18	09:00	18-May-18	18:00	Daily	Tightening of jumper cone & arching horn & other maintenance work				
11	220	220KV Badod-Kota	22-May-18	09:00	22-May-18	18:00	Daily	Tightening of jumper cone & arching horn & other maintenance work				

**EE.(SLDC)
MPPTCL, JBP**

R	not exist in present network
R	not exist in present network