

## WRPC 500th OCC APPROVED SHUTDOWNS FOR NOVEMBER 2017

ALL INTRA STATE ENTITIES ARE REQUESTED TO GIVE THEIR READINESS FOR AVAILING SHUTDOWN ON D-3 BASIS ELSE THE SHUTDOWN MAY BE TREATED AS DEEMED CANCEL

Sr No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type
1	400	400Kv Nagda-Rajgarh-I	1.Nov.17	9:00	7.Nov.17	18:00	Daily	Insulator disc replacement work	MPPTCL	MPPTCL	R
2	400	315MVA BHEL Xmer-I at 400KV S/s Bina	2.Nov.17	8:00	4.Nov.17	17:00	Continue	For Y-Ph OLTC Vovel gear Oil leakage attending Work	MPPTCL	MPPTCL	R
3	400	400kV Seoni-Bhilai	3.Nov.17	9:00	3.Nov.17	18:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
4	400	315MVA TRANSFORMER-III at 400KV S/s Bhopal	4.Nov.17	9:00	10.Nov.17	17:00	Continue	For attending oil leakage from various places and painting of transformer	MPPTCL	MPPTCL	R
5	400	Main CB OF 400KV 315 MVA X-mer -I (ICT - I) at 400KV S/s Nagda	6.Nov.17	8:00	18.Nov.17	18:00	Continue	For Old CB Repalement work.	MPPTCL	MPPTCL	R
6	400	400KV Bina-Bhopal-I at 400KV S/s Bina	6.Nov.17	8:00	10.Nov.17	17:00	Continue	Tie CB replacement work	MPPTCL	MPPTCL	R
7	132	132 KV Morwa- Bina- Annpara (DCDS) Line	06-Nov-17	9:00	8.Nov.17	17:00	cont.	Location No. 1&2 Eraction work of Tower E-60	MPPTCL	MPPTCL	R
8	400	400kV Itarsi-Bhopal-I	7.Nov.17	9:00	7.Nov.17	18:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
9	220	220KV Badod-Kota line	7.Nov.17	9:00	7.Nov.17	18:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
10	400	400KV Nagda- Rajghar-II Line Reactor at 400KV S/s Nagda	8.Nov.17	9:00	8.Nov.17	18:00	Daily	For post monsoon maintenance and testing work	MPPTCL	MPPTCL	R
11	400	400kV Itarsi-Bhopal-I	8.Nov.17	9:00	8.Nov.17	18:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
12	220	220KV Gwalior(PGCIL)-Malanpur-I at 220KV S/s Malanpur	8.Nov.17	9:00	8.Nov.17	17:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
13	220	220KV Badod-Modak Line	8.Nov.17	9:00	8.Nov.17	18:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
14	400	400KV Nagda- Rajghar-I Line reactor at 400KV S/s Nagda	9.Nov.17	9:00	24.Nov.17	18:00	Continue	For post monsoon maintenance work and old CB replacement work	MPPTCL	MPPTCL	R
15	400	400kV Itarsi-Bhopal-II	9.Nov.17	9:00	9.Nov.17	18:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
16	220	220KV Gwalior(PGCIL)-Malanpur-II at 220KV S/s Malanpur	9.Nov.17	9:00	9.Nov.17	17:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
17	400	400kV Itarsi-Bhopal-II	10.Nov.17	9:00	10.Nov.17	18:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
18	220	220KV Gwalior(PGCIL)-Mahalgaon-I at 220KV S/s Mahalgaon	10.Nov.17	9:00	10.Nov.17	17:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
19	220	220kV Pandurna-Kalmeshwar at 220KV S/s Pandhurna	10.Nov.17	9:00	10.Nov.17	18:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
20	220	220KV Gwalior(PGCIL)-Mahalgaon-II at 220KV S/s Mahalgaon	11.Nov.17	9:00	11.Nov.17	17:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
21	400	400KV Bina-Bhopal-I at 400KV S/s Bina	13.Nov.17	8:00	18.Nov.17	17:00	Continue	Main CB and 2Nos Main CTs (R & Y-ph) replacement work	MPPTCL	MPPTCL	R
22	220	220KV Malanpur-Aouriya at 220KV S/s Malanpur	15.Nov.17	9:00	15.Nov.17	17:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R

23	400	400kV Seoni-Sarni	16.Nov.17	9:00	16.Nov.17	18:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
24	400	400Kv Nagda-Rajgarh-I	18.Nov.17	9:00	24.Nov.17	18:00	Daily	Insulator disc replacement work	MPPTCL	MPPTCL	R
25	220	220KV Mahegaon-Aouriya at 220KV Mehgaon	18.Nov.17	9:00	18.Nov.17	17:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
26	400	400kV Damoh-Katni	20.Nov.17	10:00	20.Nov.17	17:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
27	220	220KV Chhegaon-Khandwa (PGCIL)-II at 400KV S/s Chhegaon	20.Nov.17	10:00	20.Nov.17	17:00	Daily	For post monsoon maintenance and testing work	MPPTCL	MPPTCL	R
28	400	315MVA BHEL Xmer-II at 400KV S/s Bina	21.Nov.17	8:00	23.Nov.17	17:00	Continue	For Main CTs replacement work	MPPTCL	MPPTCL	R
29	220	220kv Khandwa(PGCIL)-Nepanagar	22.Nov.17	9:00	22.Nov.17	16:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
30	400	400Kv Nagda-Rajgarh-II	25.Nov.17	9:00	30.Nov.17	18:00	Daily	Insulator disc replacement work	MPPTCL	MPPTCL	R
31	400	400kV ISP-Indore-I	27.Nov.17	9:00	27.Nov.17	16:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
32	220	220kv Annupur-Kotmikala-I	27.Nov.17	10:00	27.Nov.17	17:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
33	220	220kV Annupur-Kotmikala-II	29.Nov.17	10:00	29.Nov.17	17:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R
34	400	400kV ISP-Indore-II	30.Nov.17	9:00	30.Nov.17	16:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	R