

**MADHYA PRADESH POWER TRANSMISSION COMPANY LIMITED**  
**STATE LOAD DESPATCH CENTER, NAYAGAON, RAMPUR, JABALPUR**  
**Telephone: (0761) 2702740/2702748 Fax :(0761) 2664343**  
**E-mail slidcmjbp@gmail.com**

**ALL INTRA STATE ENTITIES ARE REQUESTED TO GIVE THEIR READINESS FOR AVAILING SHUTDOWN ON D-3 BASIS ELSE THE SHUTDOWN MAY BE TREATED AS DEEMED CANCEL .**

**ALL APPROVED OCCM SHUTDOWN AVAIL ABLE AT SLDC & WRPC WEB-SITE**

**SUB :- APPROVED SHUT DOWN OF TRANSMISSION ELEMENTS FOR THE PERIOD FROM 01.11.18 TO 30.11.18, APPROVED IN 512th OCC MEETING TO BE HELD ON 23.10.18 AT WRPC, MUMBAI**

Approved Shut down of 400 KV Transmission elements  
( 01.11.18 to 30.11.18 )

Sr. No	KV	Line	From		To		Basis	Reason	System	Agency	Type
			Date	Time	Date	Time					
<b>A 400KV TRANSFORMER</b>											
1	400	315 MVA CGL MAKE X-MER-3 at 400KV S/s Bina	01-Nov-18	8:00	03-Nov-18	17:00	Continue	For Urgent NIFPS Commissioning work & Post monsoon maintenance Work	MPPTCL	MPPTCL	R
2	400	315 MVA 400/220 KV Xmer IV & Main bus -I at 400KV S/s Indore	3-Nov-18	9:00	5-Nov-18	18:00	Continue	For replacement of 400 KV pantagraph isolator , Post monsoon maintenance & Testing work, ICT IV will be off	MPPTCL	MPPTCL	R
<b>B 400 KV REACTORS</b>											
1	400	80MVAR Reactor 1 at 400KV S/s Bhopal	28-Nov-18	8:00	30-Nov-18	18:00	Continue	For attending oil leakage and Testing Work	MPPTCL	MPPTCL	R
<b>C 400 KV FEEDER &amp; BAYS OF 400 KV- S/S.</b>											
1	400	400KV Indore-Asoj -I	1-Nov-18	8:00	1-Nov-18	17:00	Daily	Over head crossing work of under construction lines 400 KV Badnawar-Pithampur DCDS Line	MPPTCL	MPPTCL	R
2	400	400KV Indore-Asoj -I	2-Nov-18	8:00	2-Nov-18	17:00	Daily	Over head crossing work of under construction lines 400 KV Badnawar-Pithampur DCDS Line	MPPTCL	MPPTCL	R
3	400	400KV Indore-Asoj -II	12-Nov-18	8:00	12-Nov-18	17:00	Daily	Over head crossing work of under construction lines 400 KV Badnawar-Pithampur DCDS Line	MPPTCL	MPPTCL	R
4	400	400 kV ISP-Nagda	12-Nov-18	9:00	12-Nov-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
5	400	400KV Indore-Asoj -II	13-Nov-18	8:00	13-Nov-18	17:00	Daily	Over head crossing work of under construction lines 400 KV Badnawar-Pithampur DCDS Line	MPPTCL	MPPTCL	R
6	400	400KV Itarsi-Bhopal-II Main CB at PG Itarsi	13-Nov-18	8:00	26-Nov-18	18:00	Continue	For replacement of 400kv CB and 400kv CTs under PSDF Scheme. Line will remain charged through Tie CB	MPPTCL	MPPTCL	R
7	400	400 kV ISP-Nagda	13-Nov-18	9:00	13-Nov-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
8	400	400KV Seoni-Bhilai	13-Nov-18	9:00	13-Nov-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
9	400	400KV Main Bus -I at 400KV S/s Indore	14-Nov-18	9:00	16-Nov-18	18:00	continue	for replacement of 400 KV pantagraph isolator & line Isolator of ISP-I & ISP-II of main Bus-I	MPPTCL	MPPTCL	R
10	400	400KV Indore-ISP-II	14-Nov-18	9:00	16-Nov-18	18:00	continue	For replacement of 400KV pantagraph isolator & line Isolator of ISP-II main Bus-I, 400 KV ISP-II will be off	MPPTCL	MPPTCL	R
11	400	400KV Bina- Bhopal-I	17-Nov-18	0:00	20-Nov-18	24:00	Continue	For CVT & LA replacement work and Post monsoon maintenance work	MPPTCL	MPPTCL	R
12	400	400KV Indore-ISP-I	17-Nov-18	9:00	19-Nov-18	18:00	continue	For replacement of 400 KV pantagraph isolator & line Isolator of 400 KV ISP-I Main bus -I, 400 KV ISP-I will be off	MPPTCL	MPPTCL	R
13	400	400KV Rajgarh-SSP-I	19-Nov-18	9:00	19-Nov-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
14	400	400KV Indore(PGCIL)-Pithampur I & II	19-Nov-18	9:00	19-Nov-18	17:00	Daily	Over head crossing work of under construction lines 400 KV Badnawar-Pithampur DCDS & 400KV Khandwa -Pithampur DCDS lines	MPPTCL	MPPTCL	R
15	400	400KV Rajgarh-SSP-II	20-Nov-18	9:00	20-Nov-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
16	400	400KV Indore(PGCIL)-Pithampur I & II	20-Nov-18	9:00	20-Nov-18	17:00	Daily	Over head crossing work of under construction lines 400 KV Badnawar-Pithampur DCDS & 400KV Khandwa -Pithampur DCDS lines	MPPTCL	MPPTCL	R
17	400	400KV Seoni-Sarni	22-Nov-18	9:00	22-Nov-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
18	400	400KV Nagda-Rajgarh I&II	24-Nov-18	9:00	30-Nov-18	18:00	Continue	For LILO at 400KV Badnawar S/S	MPPTCL	MPPTCL	R
19	400	400KV Itarsi-Bhopal-II Main CB at PG Itarsi	26-Nov-18	8:00	26-Nov-18	18:00	Daily	Testing work after replacement of CB.Line will be under shutdown	MPPTCL	MPPTCL	R
20	400	400KV Bhopal-Itarsi-I	27-Nov-18	7:00	27-Nov-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R

D. 220 KV LINES											
1	220	220KV Malanpur- Adani	02-Nov-18	9:00	02-Nov-18	17:00	Daily	For Post monsoon maintenance / testing work	MPPTCL	MPPTCL	R
2	220	220KV Mehgaon-Malanpur	05-Nov-18	9:00	05-Nov-18	17:00	Daily	For Post monsoon maintenance / testing work	MPPTCL	MPPTCL	R
3	220	220 KV ICT II at 220KV S/s Sukha	12-Nov-18	9:00	14-Nov-18	17:00	Continue	For Breaker replacement and maintnace work.	MPPTCL	MPPTCL	R
4	220	220KV Bhanpura-Modak	14-Nov-18	9:00	14-Nov-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
5	220	220KV Bhanpura-Kota (Sakatpura)	15-Nov-18	9:00	15-Nov-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
6	220	220KV Pithampur-Rajgarh(PGCIL)	15-Nov-18	7:00	15-Nov-18	18:00	Daily	Over head crossing work of under construction lines 400 KV Badnawar-Pithampur DCDS Line	MPPTCL	MPPTCL	R
7	220	220KV Pithampur-Rajgarh(PGCIL)	16-Nov-18	7:00	15-Nov-18	18:00	Daily	Over head crossing work of under construction lines 400 KV Badnawar-Pithampur DCDS Line	MPPTCL	MPPTCL	R
8	220	220 KV Gwalior(PGCIL)-Malanpur-I	16-Nov-18	9:00	16-Nov-18	17:00	Daily	For Post monsoon maintenance / testing work	MPPTCL	MPPTCL	R
9	220	220 kV Pandhurna-Kamleshwar	17-Nov-18	9:00	17-Nov-18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
10	220	220 KV Gwalior(PGCIL)-Malanpur-II	17-Nov-18	9:00	17-Nov-18	17:00	Daily	For Post monsoon maintenance / testing work	MPPTCL	MPPTCL	R
11	220	220 KV bus -I at 400KV S/s Indore	19-Nov-18	9:00	21-Nov-18	18:00	Continue	for replacement of bus-I isolator of dewas & South Zone - I. Dewas & South Zone -I will be on TBC simultanously.	MPPTCL	MPPTCL	R
12	220	220KV Malanpur-Aouriya	20-Nov-18	9:00	20-Nov-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
13	220	220 KV Gwalior(PGCIL)-Mahalgaon-I	21-Nov-18	9:00	21-Nov-18	17:00	Daily	For Post monsoon maintenance / testing work	MPPTCL	MPPTCL	R
14	220	220 KV Mahegaon-Aouriya	23-Nov-18	9:00	23-Nov-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
15	220	220 KV Gwalior(PGCIL)-Mahalgaon-II	22-Nov-18	9:00	22-Nov-18	17:00	Daily	For Post monsoon maintenance / testing work	MPPTCL	MPPTCL	R
16	220	220 KV bus -II & ICT IV at 400KV S/s Indore	26-Nov-18	9:00	28-Nov-18	18:00	Continue	for replacement of bus-II isolator of ICT -III & ICT IV. ICT-III will be on TBC & ICT IV will be off	MPPTCL	MPPTCL	R
17	220	220KV Annupur-Kotmikala-I	26-Nov-18	10:00	26-Nov-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
18	220	220 KV ICT I at 220KV S/s Sukha	27-Nov-18	9:00	28-Nov-18	17:00	Continue	For Breaker replacement and maintnace work.	MPPTCL	MPPTCL	R
19	220	220KV Annupur-Kotmikala-II	29-Nov-18	10:00	29-Nov-18	17:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R