

## WRPC 498th OCC APPROVED SHUTDOWNS FOR SEPTEMBER 2017

ALL INTRA STATE ENTITIES ARE REQUESTED TO GIVE THEIR READINESS FOR AVAILING SHUTDOWN ON D-3 BASIS ELSE THE SHUTDOWN MAY BE TREATED AS DEEMED CANCEL

Sr No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type
1	400	400KV Itarsi-I Main CB at 400 kv s/s Bhopal	02.09.17	9:00	14.09.17	17:00	cont.	For CB replacae ment and 3No. CT replacement work	MPPTCL	MPPTCL	R
2	220	220KV Bina-Bina(PGCIL)	02.09.17	8:00	02.09.17	17:00	daily	For routine testing & maintenance of equipments	MPPTCL	MPPTCL	R
3	400	400KV Indore- Nagda	04.09.17	10:00	05.09.17	17:00	cont.	Replacement of 400KV CT	MPPTCL	MPPTCL	R
4	400	400 KV NAGDA MAIN CB of 400KV ICT-III	04.09.17	9:00	15.09.17	17:00	cont.	For replacement of MAIN CB	MPPTCL	MPPTCL	R
5	220	220KV Rajgarh(PGCIL) -Rajgarh(Dhar) I/C-I	04.09.17	9:00	04.09.17	16:00	daily	Tightening of jumper cone, arching horn & other maintenance work	MPPTCL	MPPTCL	R
6	220	220KV Pandhurna-Kalmeshwar	04.09.17	9:00	05.09.17	17:00	cont.	For shifting of location of 220kv PT substation	MPPTCL	MPPTCL	R
7	400	400 KV S/S KATNI 400KV 125 MVA BHEL REACTOR	04.09.17	9:00	05.09.17	17:00	cont.	For post monsoon maintenance work	MPPTCL	MPPTCL	R
8	400	400 KV S/S PITHAMPUR 400KV 50 MVAR REACTOR -I	04.09.17	7:00	04.09.17	17:00	daily	For post monsoon maintenance work	MPPTCL	MPPTCL	R
9	400	400 KV S/S PITHAMPUR 400KV 50 MVAR REACTOR -II	05.09.17	7:00	05.09.17	17:00	daily	For post monsoon maintenance work	MPPTCL	MPPTCL	R
10	400	400 KV BINA 315MVA BHEL X'mer-III (CGL)	05.09.17	8:00	05.09.17	17:00	daily	For routine testing and maintenance of equipments	MPPTCL	MPPTCL	R
11	400	400 KV PITHAMPUR 315MVA ICT-I	06.09.17	7:00	07.09.17	17:00	cont.	For post monsoon maintenance work	MPPTCL	MPPTCL	R
12	400	400KV Nagda -ISP	06.09.17	9:00	07.09.17	17:00	cont.	For isolator and panel replacement work	MPPTCL	MPPTCL	R
13	220	220KV Shujalpur(MP)-Shujalpur(PGCIL) -I	06.09.17	9:00	06.09.17	18:00	daily	220 kv CVT jumpering work	MPPTCL	MPPTCL	R
14	220	220KV Damoh(PGCIL)-Sagar -II	06.09.17	9:00	06.09.17	18:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
15	220	220KV Rajgarh(PGCIL) -Rajgarh(Dhar) I/C-II	06.09.17	9:00	06.09.17	16:00	daily	Tightening of jumper cone, arching horn & other maintenance work	MPPTCL	MPPTCL	R
16	220	220KV Shujalpur(MP)-Shujalpur(PGCIL) -II	07.09.17	9:00	07.09.17	18:00	daily	220 kv CVT jumpering work	MPPTCL	MPPTCL	R
17	400	400KV SSTPS(MALWA)- Pithampur-II	07.09.17	9:00	07.09.17	16:00	daily	Tightening of jumper cone, arching horn & other maintenance work	MPPTCL	MPPTCL	R
18	400	400 KV BINA 315MVA BHEL X'mer-I	07.09.17	8:00	08.09.17	17:00	daily	For routine testing and maintenance of equipments	MPPTCL	MPPTCL	R
19	400	400KV Indore-ISP-I	08.09.17	10:00	09.09.17	17:00	daily	Replacement of 400KV CT	MPPTCL	MPPTCL	R
20	220	220KV Dhar - Rajgarh(PGCIL)	08.09.17	9:00	08.09.17	16:00	daily	Tightening of jumper cone, arching horn & other maintenance work	MPPTCL	MPPTCL	R
21	400	400 KV BINA 315MVA BHEL X'mer-I	08.09.17	8:00	09.09.17	17:00	daily	For routine testing and maintenance of equipments	MPPTCL	MPPTCL	R
22	400	400 KV BINA 315MVA BHEL X'mer-III	08.09.17	8:00	08.09.17	17:00	daily	For routine testing and maintenance of equipments	MPPTCL	MPPTCL	R
23	400	400 KV INDORE 315MVA X'mer-IV	11.09.17	10:00	14.09.17	17:00	cont.	For CB replacement load will be Transfer on TBC	MPPTCL	MPPTCL	R
24	400	400 KV BINA 315MVA BHEL X'mer-II	11.09.17	8:00	11.09.17	17:00	daily	For routine testing and maintenance of equipments	MPPTCL	MPPTCL	R
25	400	400 KV PITHAMPUR 315MVA ICT-II	11.09.17	7:00	12.09.17	17:00	cont.	For post monsoon maintenance work	MPPTCL	MPPTCL	R
26	400	400KV Birsingpur-Katni -II	11.09.17	9:00	11.09.17	18:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
27	220	220KV Gwalior(PGCIL)-Malanpur -I	11.09.17	9:00	11.09.17	17:00	daily	For line maintenance work	MPPTCL	MPPTCL	R

28	220	220KV Badod-Kota	12.09.17	9:00	12.09.17	18:00	daily	For rectification of defects observed during routine patrolling & to attend the damper ,arcing horn ,f/o & broken disc replacement work	MPPTCL	MPPTCL	R
29	220	220KV Gwalior(PGCIL)-Malanpur -II	12.09.17	9:00	12.09.17	17:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
30	400	400KV Sarni- Seoni	12.09.17	9:00	12.09.17	17:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
31	400	400 KV BINA 315MVA BHEL X'mer-II	12.09.17	8:00	12.09.17	17:00	daily	For routine testing and maintenance of equipments	MPPTCL	MPPTCL	R
32	400	400 KV BINA 315MVA BHEL X'mer-II	13.09.17	8:00	13.09.17	17:00	daily	For routine testing and maintenance of equipments	MPPTCL	MPPTCL	R
33	400	400KV Seoni-Bhilai	13.09.17	9:00	13.09.17	18:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
34	220	220KV Gwalior(PGCIL)-Gwalior-II-ckt -I	13.09.17	9:00	13.09.17	17:00	daily	For post monsoon maintenance work	MPPTCL	MPPTCL	R
35	220	220KV Badod-Modak	14.09.17	9:00	14.09.17	18:00	daily	For rectification of defects observed during routine patrolling & to attend the damper ,arcing horn ,f/o & broken disc replacement work	MPPTCL	MPPTCL	R
36	220	220KV Shujalpur(MP)-Shujalpur(PGCIL) -I	14.09.17	9:00	14.09.17	18:00	daily	Add DPR Installation work	MPPTCL	MPPTCL	R
37	400	400 KV KATNI 315MVA BHEL X'mer	14.09.17	9:00	15.09.17	17:00	cont.	For post monsoon maintenance work	MPPTCL	MPPTCL	R
38	400	400 KV NAGDA 315MVA ICT-III	14.09.17	9:00	15.09.17	17:00	cont.	For post monsoon maintenance work	MPPTCL	MPPTCL	R
39	400	400 KV BINA 315MVA BHEL X'mer-II	14.09.17	8:00	14.09.17	17:00	daily	For routine testing and maintenance of equipments	MPPTCL	MPPTCL	R
40	400	400 KV BHOPAL 315MVA X'mer-III	15.09.17	9:00	25.09.17	17:00	cont.	For attending oil leakage from turret of HV and LV bushing from radiator inspection window etc	MPPTCL	MPPTCL	R
41	400	400 KV INDORE 315MVA X'mer-IV	15.09.17	10:00	16.09.17	17:00	cont.	X-mer will be OFF due to replacement of 400KV CB	MPPTCL	MPPTCL	R
42	220	220KV Pithampur - Rajgarh(PGCIL) -II	15.09.17	9:00	15.09.17	16:00	daily	Tightening of jumper cone, arcing horn & other maintenance work	MPPTCL	MPPTCL	R
43	220	220KV Gwalior(PGCIL)-Mahalgaon -I	15.09.17	9:00	15.09.17	17:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
44	220	220KV Shujalpur(MP)-Shujalpur(PGCIL) -II	15.09.17	9:00	15.09.17	18:00	daily	Add DPR Installation work	MPPTCL	MPPTCL	R
45	220	220KV Seoni(PG)- Chhindwara-I	15.09.17	9:00	15.09.17	18:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
46	220	220KV Damoh(PGCIL)-Tikamgarh -I	15.09.17	9:00	15.09.17	18:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
47	220	220KV Gwalior(PGCIL)-Mahalgaon -II	16.09.17	9:00	16.09.17	17:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
48	400	400 KV NAGDA MAIN CB of 400KV ICT-I	18.09.17	9:00	29.09.17	17:00	cont.	For replacement of MAIN CB	MPPTCL	MPPTCL	R
49	400	400KV SSTPS(MALWA)- Pithampur-I	18.09.17	9:00	18.09.17	16:00	daily	Tightening of jumper cone, arcing horn & other maintenance work	MPPTCL	MPPTCL	R
50	400	400KV Rajgarh-SSP-I	19.09.17	7:00	19.09.17	19:00	daily	For rectification of defects observed during routine patrolling & to attend the damper ,arcing horn ,f/o & broken disc replacement work	MPPTCL	MPPTCL	R
51	220	220KV Malanpur-Auriya	19.09.17	9:00	19.09.17	17:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
52	400	400KV Itarsi-Bhopal-II	19.09.17	9:00	19.09.17	17:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
53	400	400 KV KATNI 315MVA TELK X'mer	19.09.17	10:00	20.09.17	17:00	cont.	For post monsoon maintenance work	MPPTCL	MPPTCL	R
54	400	400 KV INDORE 315MVA X'mer-III	20.09.17	10:00	21.09.17	17:00	cont.	For replacement of transformer Aircell	MPPTCL	MPPTCL	R
55	400	400KV Itarsi-Bhopal-I	20.09.17	9:00	20.09.17	17:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
56	400	400 KV INDORE 315MVA X'mer-III	20.09.17	10:00	21.09.17	17:00	cont.	For replacement of transformer Aircell	MPPTCL	MPPTCL	R
57	400	400KV Damoh-Katni	20.09.17	9:00	20.09.17	18:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
58	400	400KV Nagda-Rajgarh-II	20.09.17	9:00	21.09.17	17:00	cont.	For isolator and CT replacement work	MPPTCL	MPPTCL	R
59	400	400 KV INDORE 315MVA X'mer-III	21.09.17	9:00	22.09.17	17:00	daily	For maintenance & relay testing work	MPPTCL	MPPTCL	R

60	400	400KV SSTPS(MALWA)- Chhgoan	22.09.17	9:00	22.09.17	16:00	daily	Tightening of jumper cone, arching horn & other maintenance work	MPPTCL	MPPTCL	R
61	400	400KV Sarni- Indirasagar	22.09.17	9:00	22.09.17	17:00	cont.	For line maintenance work	MPPTCL	MPPTCL	R
62	220	220KV Seoni(PG)- Chhindwara-II	22.09.17	9:00	22.09.17	18:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
63	220	220KV Annupur-Kotmikala -I	22.09.17	9:00	22.09.17	18:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
64		220KV Damoh(PGCIL)-Damoh-I	23.09.17	9:00	23.09.17	18:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
65	400	400KV SSTPS(MALWA)- Julwania	23.09.17	9:00	23.09.17	16:00	daily	Tightening of jumper cone, arching horn & other maintenance work	MPPTCL	MPPTCL	R
66	400	400KV Rajgarh-SSP-II	25.09.17	7:00	25.09.17	19:00	daily	For rectification of defects observed during routine patrolling & to attend the damper ,arching horn ,f/o & broken disc replacement work	MPPTCL	MPPTCL	R
67	400	400KV Indore (PGCIL Hathuniya )-Pithampur-II	25.09.17	9:00	25.09.17	16:00	daily	Tightening of jumper cone, arching horn & other maintenance work	MPPTCL	MPPTCL	R
68	400	400KV Main BUS -I at 400 kv s/s Nagda	25.09.17	9:00	26.09.17	17:00	cont.	For bus routine maintenance work	MPPTCL	MPPTCL	R
69	400	400 KV INDORE 315MVA X'mer-II	26.09.17	9:00	27.09.17	17:00	daily	For maintenance & relay testing work	MPPTCL	MPPTCL	R
70	220	220KV Bina(PGCIL)-Shivpuri	26.09.17	9:00	26.09.17	17:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
71	220	220KV Annupur-Kotmikala -II	27.09.17	9:00	27.09.17	18:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
72		220KV Damoh(PGCIL)-Damoh-II	27.09.17	9:00	27.09.17	18:00	daily	For line maintenance work	MPPTCL	MPPTCL	R
73	400	400KV Indore (PGCIL Hathuniya )-Pithampur-I	27.09.17	9:00	27.09.17	16:00	daily	Tightening of jumper cone, arching horn & other maintenance work	MPPTCL	MPPTCL	R
74	400	400 KV BHOPAL 315MVA X'mer-II	27.09.17	9:00	27.09.17	17:00	daily	For post monsoon maintenance work	MPPTCL	MPPTCL	R
75	400	400 KV BHOPAL 315MVA X'mer-II	28.09.17	9:00	28.09.17	17:00	daily	For post monsoon maintenance work	MPPTCL	MPPTCL	R
76	400	400 KV NAGDA 315MVA ICT-I	28.09.17	9:00	29.09.17	17:00	cont.	For post monsoon maintenance work	MPPTCL	MPPTCL	R
77	400	400KV Indore-ISP-II	29.09.17	9:00	29.09.17	16:00	daily	Tightening of jumper cone, arching horn & other maintenance work	MPPTCL	MPPTCL	R
78	400	400 KV BHOPAL 315MVA X'mer-II	29.09.17	9:00	29.09.17	17:00	daily	For post monsoon maintenance work	MPPTCL	MPPTCL	R
79	220	220KV Mahegaon-Auriya	30.09.17	9:00	30.09.17	17:00	daily	For line maintenance work	MPPTCL	MPPTCL	R