

**6.3** Generating Units / Machines shall be allowed for AOH / COH from the dates approved by the OCC Forum.

**6.4** If there shall be any change in date of taking unit / machine under AOH / COH, the same shall be intimated to the SLDC at least 10 days in advance.

**6.5** Readiness of taking unit / machine under AOH / COH shall be communicated to SLDC **3 days in advance** else permission for taking unit / machine for AOH / COH shall be given 3 days after receipt of communication from the Generating Station.

**6.6** If any Generating Unit is required to be taken under Planned Outage, the intimation in this regard and expected time of synchronization shall be given to the SLDC **7 days in advance**.

...