



**MADHYA PRADESH POWER TRANSMISSION COMPANY LIMITED**

**STATE LOAD DESPATCH CENTRE, NAYAGAON, RAMPUR, JABALPUR**

Telephone: (0761) 2970089 Fax: (0761) 2664343/2970119 e-mail [sldcmpjbp@gmail.com](mailto:sldcmpjbp@gmail.com)

**Corporate office:** Madhya Pradesh Power Transmission Co. Ltd., Block No.2, Shakti Bhawan,  
Rampur, Jabalpur 482008, CIN-U40109MP2001SGC014880, Email-mdtransco.nic.co.in



ISO 9001:2015

No.07-05/SG-9B-II/1211

Jabalpur, dated:04.09.2023

To

**As per distribution list**

Sub: Agenda of 86<sup>th</sup> meeting of Operation and Coordination Committee of MP.

...

The Agenda of 86<sup>th</sup> meeting of the Operation and Coordination Committee of MP scheduled on **06<sup>th</sup> September 2023** at Conference Hall, SLDC, MPPTCL, Jabalpur has been uploaded on the website of SLDC 'www.sldcmpindia.com' and can be downloaded.

**V. K. Agrawal**  
**Superintending Engineer (Opn)**  
**& Member Secretary, MP-OCC,**  
**SLDC, MPPTCL, Jabalpur.**

## Distribution List

1. The Chief Engineer (Works), MP Power Transmission Co. Limited, Shakti Bhawan, Jabalpur, email- [cehtmi@yahoo.com](mailto:cehtmi@yahoo.com).
2. The Chief Engineer (T&C), MP Power Transmission Co. Limited, Jabalpur. Fax No- 0761-2665593, 2702710 Email- [cetandc@gmail.com](mailto:cetandc@gmail.com)
3. The Chief Engineer (Transmission-East Zone), MP Power Transmission Co. Limited, Shakti Bhawan, Jabalpur. Email- [sk.gaikwad@mptransco.nic.in](mailto:sk.gaikwad@mptransco.nic.in).
4. The Chief Engineer (Transmission-West Zone), MP Power Transmission Co. Limited, Indore.
5. The Chief Engineer (Transmission-Central Zone), MP Power Transmission Co. Limited, Bijlee Nagar, Govindpura, Bhopal, email- [setncbpl@gmail.com](mailto:setncbpl@gmail.com).
6. The Chief Engineer (Plg & Des), MP Power Transmission Co. Limited, Jabalpur, Fax No- 0761-2660908 Email- [ceps321@yahoo.com](mailto:ceps321@yahoo.com)
7. The Chief Engineer (Procurement.), MP Power Transmission Co. Limited, Jabalpur, .Fax No- 0761-2660908 Email – [substation\\_vi@yahoo.com](mailto:substation_vi@yahoo.com)
8. The Chief Engineer(EHT:Const.), MP Power Transmission Co. Limited, Jabalpur. Fax-0761-2661618, E-mail- [ce.ehtc@mptransco.nic.in](mailto:ce.ehtc@mptransco.nic.in).
9. The Chief Engineer(EHT:Maint&insp.), MP Power Transmission Co. Limited, Jabalpur. Fax-0761-2665593, E-mail- [ce.mni@mptransco.nic.in](mailto:ce.mni@mptransco.nic.in).
10. The Executive Director (O & M:Gen), MP Power Generating Company Limited, Jabalpur. Fax No- 0761-2664749, Email- [gcc.mppgcl@gmail.com](mailto:gcc.mppgcl@gmail.com), Email- [edomg\\_mpeb@rediffmail.com](mailto:edomg_mpeb@rediffmail.com)
11. The Chief Engineer (O&M:Hydel), MP Power Generating Co. Ltd, Jabalpur, Fax No-0761-2664749.
12. The General Manager(PM), MPPMCL, Jabalpur Email – [gm\\_pm@mptradeco.com](mailto:gm_pm@mptradeco.com) [controlroom.tradeco@gmail.com](mailto:controlroom.tradeco@gmail.com)
13. The Superintending Engineer (GCC), MPPGCL, Jabalpur Email – [segcc.mppgcl@gmail.com](mailto:segcc.mppgcl@gmail.com) [gcc.mppgcl@gmail.com](mailto:gcc.mppgcl@gmail.com).
14. The General Manger (DCC-EZ), DISCOM Control Centre, MP Poorva Kshetra Vidyut Vitaran Co.Limited, Jabalpur, Fax No- 0761-2668503, Email – [cmdez\\_ld@yahoo.co.in](mailto:cmdez_ld@yahoo.co.in).
15. The Dy. General Manager (DCC –CZ), DISCOM Control Centre, MP Madhya Kshetra Vidyut Vitaran Co. Limited, Bhopal, Fax No-0755-2580611,Email- [pjm.mpcz@gmail.com](mailto:pjm.mpcz@gmail.com).
16. The Executive Engineer (DCC-WZ), DISCOM Control Centre, MP Paschim Kshetra Vidyut Vitaran Co. Limited, Near Polo Ground, Jail Road, Indore, Fax No- 0731-2421554, Email- [dccindore@gmail.com](mailto:dccindore@gmail.com).
17. The Executive Engineer, Sub Load Despatch Centre, MPPTCL, Indore, Fax No- 0731-2874515, Email – [eesubldcind@yahoo.com](mailto:eesubldcind@yahoo.com).
18. The Executive Engineer, Sub Load Despatch Centre, MPPTCL, Bhopal, Fax No- 0755-2885220, Email – [aldc\\_bpl@yahoo.co.in](mailto:aldc_bpl@yahoo.co.in)
19. The General Manger(RO), MPPMCL, In front of Bhojpur Club, E-4, Arera Colony,Bhopal, Fax No-0755-2423046, Email-[Rajeev\\_keskar@rediffmail.com](mailto:Rajeev_keskar@rediffmail.com)
20. The Chief Engineer (PM&C), Narmada Hydroelectric Development Corpn. Ltd, NHDC Parisar, Shamla Hills, Bhopal – 462013., Fax No- 0755-4030130,Email – [om.co.nhdc@gmail.com](mailto:om.co.nhdc@gmail.com) [5vinodnhdc@rediffmail.com](mailto:5vinodnhdc@rediffmail.com)
21. The Chief Electrical Distribution Engineer, West Central Railway (WCR), General Manager's Office, Electrical Department, Jabalpur-482001 (MP), Fax: 0761-2627629, Email- [cede@wcr.gov.in](mailto:cede@wcr.gov.in), [dyceetrdwcr@gmail.com](mailto:dyceetrdwcr@gmail.com), M-9752415312, Mr.Satyendra Kumar (Dy.CE), Mob.9752415301 (CEDE, WCR).
22. The General Manager, Indira Sagar Power Station, NHDC Office complex, PO : Narmada Nagar, Distt : Khandwa (MP) – 450 119, Fax No- 07323-284080, Email – [nhdc-isp@rediffmail.com](mailto:nhdc-isp@rediffmail.com)
23. The General Manager, Omkareshwar Power Station, Prashnsnik Bhawan, Urja Vihar, Sidhwarkut, Distt : Khandwa (MP) – 450 554, FaxNo-07280-271703, Email- [pk saxena@nhdc.com](mailto:pk saxena@nhdc.com), [saxena\\_pks123@rediffmail.com](mailto:saxena_pks123@rediffmail.com), [omkareshwar.nhdc@gmail.com](mailto:omkareshwar.nhdc@gmail.com).
24. The Director (Projects), BLA Power Limited, At : Niwari, PO: Khorsipan, Tah : Gadarwara, Distt ; Narsinghpur 487 551, Fax No. 07791-243667 / 243669, Email – [manish@bla.co.in](mailto:manish@bla.co.in)
25. The Sr. Vice President, Jaiprakash Power Ventures Ltd., Village Sirchopi Subpost Office-Agasod, Post Office-Bina-470113 Distt- Sagar, Fax No. 07580-277200, Email – [jbtppbina400kvswitchyard@gmail.com](mailto:jbtppbina400kvswitchyard@gmail.com) [jptpp.switchyard@jalindia.co.in](mailto:jptpp.switchyard@jalindia.co.in).
26. The General Manager Operation Satpura Transco Pvt. Ltd., Satpura Colony, Betul Road, Old Itarsi, Distt. Hoshangabad, Email – [p iyush.pandya@clpindia.in](mailto:p iyush.pandya@clpindia.in), [sachin.ashish@clpindia.in](mailto:sachin.ashish@clpindia.in) .
27. M/s Ujaas Energy Ltd. 701, NRK Business park, Vijay Nagar Sqaure, Indore – 452010, Email id :-[solar@ujaas.com](mailto:solar@ujaas.com)
28. M/s Suzlon Global Services Ltd., 1090, Scheme no. 114, Park-2, Ring Road, Universal Hospital Row.

**AGENDA FOR 85<sup>th</sup> MEETING OF OPERATION & COORDINATION COMMITTEE OF MP TO BE HELD ON 18<sup>th</sup> AUGUST 2023 AT 11:00 AM AT CONFERENCE HALL, SLDC, MPPTCL, NAYAGAON, JABALPUR.**

**ITEM NO. 1 : CONFIRMATION OF MINUTES :** Minutes of 85<sup>th</sup> meeting of Operation & Coordination Committee of MP were forwarded to the committee members vide No. 07-05/SG-9B-II/787 Jabalpur dated 14.06.2023 respectively.

No comments have been received.

[OCC may confirm the minutes]

**ITEM NO.2: REVIEW OF SYSTEM OPERATION DURING THE MONTHS APRIL 2023 TO JULY 2023.**

**2.1. Frequency Particulars:** The detailed frequency particulars for the month of **APRIL 2023 TO JULY 2023** are enclosed at **Annexure-2.1**. The brief detail of frequency profile is given here under:-

Month	Average frequency	Minimum Integrated frequency over an hour	Maximum integrated frequency over an hour	Instantaneous Minimum Frequency	Instantaneous Maximum Frequency
APRIL 2023	50 Hz	49.67 Hz	50.26 Hz	49.49 Hz	50.33 Hz
MAY 2023	50 Hz	49.64 Hz	50.37 Hz	49.43 Hz	50.40 Hz
JUNE 2023	50.01 Hz	49.6 Hz	50.37 Hz	49.51 Hz	50.41 Hz
JULY 2023	50.01 Hz	49.7 Hz	50.35Hz	49.58 Hz	50.42 Hz

[Committee may like to note]

**2.2 Operational Matters**

**2.2.1 Operational Discipline:** Frequency profile for the months **APRIL 2023 TO JULY 2023** is as given below for discussion by the committee:

%age of time when frequency was	Apr-23	May-23	Jun-23	Jul-23
Above 50.30 Hz	0.04	0.08	0.10	0.11
Between 50.05 Hz and 50.30 Hz	21.68	21.72	25.31	17.25
Between 50.00 Hz and 50.05 Hz	26.50	27.24	29.17	35.01
Between 49.9 Hz and 50.00 Hz	41.25	41.10	38.71	42.25
Between 49.5 Hz and 49.9 Hz	10.53	9.85	6.71	5.38
Between 49.2 Hz and 49.5 Hz	0.00	0.00	0.00	0.00
Below 49.2 Hz	0.00	0.00	0.00	0.00

[Committee may like to note]

**2.2.2 Voltage Profile:** the maximum and minimum voltage as recorded at important 400 KV s/s in MP Grid from **APRIL 2023 TO JULY 2023** is enclosed as **Annexure – 2.2.2**.

[Committee may please note & discuss]

**2.2.3 STATUS OF CAPACITOR BANKS IN SUB-TRANSMISSION SYSTEM:** The updated information of the status of capacitor banks in sub-transmission system as on 31<sup>th</sup> JULY 2023 as submitted by DISCOMS is detailed below:

DISCOM	Capacitor bank installed in good condition (No)				Capacitor Banks healthy but not in service due to control ckt problem			Capacitor bank installed but defective & are repairable (No)			Requirement of repair against each unit (No)	Requirement against non-repairable capacitor banks		Capacitor banks already covered under ADB T-V		Balance capacitor banks to be covered in other schemes	
	600 KVAR	1200 KVAR	1500 KVAR	1800 KVAR	600 KVAR	1200 KVAR	1500 KVAR	600 KVAR	1200 KVAR	1500 KVAR	No of 100 KVAR Units required	600 KVAR	1200 KVAR	600 KVAR	1200 KVAR	600 KVAR	1500 KVAR
EZ	416	132	111	-	2	5	4	4	8	0	6	24	7	0	0	-	0
CZ	0	498	1103	211	-	-	-	0	0	0	0	0	0	0	0	0	538
WZ	533	515	801	-	0	0	0	52	61	59	1010	10	21	0	0	-	0

Discoms are requested to provide updated status of capacitor bank in the meeting. The committee may like to discuss.

[Action: DISCOMS]

**2.2.4 Status of Shunt Capacitor Banks installed at various EHV Transmission Substation:** The updated information of the status of installed capacitor banks (in MVAR) in EHV transmission system as on **30.06.2023** as submitted by MPPTCL is given below: -

Voltage Class	Capacitor bank installed as on 31.12.2022 (MVAR)	Capacity Added after Last OCC Meeting (MVAR)	TOTAL CAPACITY AS ON 31.03.2023 (MVAR)	Capacitor Bank Installed but defective & are not repairable (No & MVAR)
220 KV	0.00	0.00	0.00	All in Service
132 KV	1139.00	0.00	1139.00	
33/36 KV	7632.50	36.00	7668.50	
<b>TOTAL</b>	<b>8771.50</b>	<b>36.00</b>	<b>8807.50</b>	

Data not provided by T&C.

[Action: MPPTCL]

## 2.2.5 U/F and df/dt Relay Operation

- (i) **U/F and df/dt Relay Operation:** During **APRIL 2023 TO JULY 2023** , frequency did not touch 49.40 Hz. There was no df/dt operation during the same period. MPPTCL informed that under Frequency Plan for all the stages have been implemented and in operation.

[Action: MPPTCL]

- (ii) **Defective u/f, df/dt Relays:** MPPTCL has informed that all the df/dt and U/F relays are in operation, where the U/F relays are not available, the numerical relays programmed for under frequency operation. All U/F stages are in good/ healthy & working condition.

[Committee may like to note]

## 2.3 POWER CUTS / LOAD RESTRICTIONS/DIFFERENTIAL LOAD SHEDDING BY DISCOMS & GROUP ALLOCATION TO 33 KV FEEDERS: -

- (i) Details of DISCOM wise Power supply given to various domestic categories during the period **APRIL 2023 TO JULY 2023** is enclosed at **Annexure 2.3(i)**.

[Committee may like to note]

- (ii) **Group Allocation to Newly Commissioned existing EHV substations:-** The region wise list of 33 KV feeders emanating from various newly commissioned/existing EHV substations for which groups have not been allocated provided by T&C. **The DISCOM wise details of pending group allocation to 33 KV feeders as provided by DISCOMS is given below:-**

SN	DISCOM	Region	No of 33 KV feeders for which groups to be allocated
01	EAST	Jabalpur	16
02		Sagar	11
		Seoni	06
03		Satna	42
04		<b>Total</b>	<b>82</b>
05	WEST	Indore	04
06		Khandwa	22
07		Mandsaur/Ujjain	10
08		<b>Total</b>	<b>36</b>
09	CENTRAL	Bhopal	25
10		Gwalior	00
		Guna	05
11		<b>Total</b>	<b>30</b>
<b>TOTAL</b>		<b>Grand Total</b>	<b>141</b>

DISCOMS are requested to furnish the details as per list enclosed at **Annexure-2.3(ii)** in the meeting.

In view of the above it is requested that the order copy for which group have been allocated may please be submitted to T&C, MPPTCL under intimation to SLDC.

[ACTION: DISCOMS, T&C-MPPTCL]

### ITEM NO. 3 : OPERATIONAL PLANNING:

**3.1 Generating Units under planned outage and proposed maintenance program:** The latest status for annual maintenance /outages of thermal generating units of MPPGCL as provided by ED(O&M:Gen) for FY-2023 – 2024 is enclosed as **Annexure-3.1**.

[Committee May like to note]

**3.2 Proposed shutdown program of Transmission lines / Transformers:** The proposed shutdown of transmission elements for the period 01.06.2023 to 31.08.2023 as submitted by T&C, MPPTCL is enclosed as **Annexure-3.2**.

[Committee May like to discuss]

**3.3 Long Outages of transmission elements and protections:** The status submitted by MPPGCL /MPPTCL are given below:-

Sr. No	Line/Transformer/ etc under long Outage	Outage date	Reason	Response from Utility
1	220 KV ATPS – Railway Traction Ckt - 1	15.05.2019	B-Phase LA Burst	MPPGCL in 79th OCCM intimated that the line is ready for charging from ATPS end. Railway replied that the line cannot be charged from railway end as it was suspected that high voltage impulse is generated in charging the line which is the cause of frequent failure of power transformers. Railway reply letter is attached as <b>annexure 3.3</b>  RAILWAY may submit the latest status
2	50Mvar line reactor of 400 KV Indore – ISP Ckt-II at 400 KV Indore end	02.02.2022	Y-PH BUCHOLZ, IT GOT BURST AND CAUGHT FIRE.	To be replaced by another reactor. T&C / P&D may submit the latest status
3	3X40MVA, 220/132KV, MITSUBISHI X'mer at 220 KV S/s Itarsi	28.04.2023	Differential and Buchholz trip indication.	X'mer is being replaced by 160MVA X'mer by Aug-2023. MPPTCL may please update the status.
4	50MVA, 132/33KV BBL X'mer at 132 KV S/s Damoh	26.05.2023	Buchholz trip indication	X'mer is being replaced by 50MVA X'mer by Aug-2023. MPPTCL may please update the status.

	40MVA, 132/33KV BHEL X'mer 220 KV S/s Ratlam	28.06.2023	Buchholz trip indication	X'mer is being replaced by 50MVA X'mer by Sep-2023. MPPTCL may please update the status.
	40MVA, 132/33KV BHEL X'MER AT 132KV S/S BARMAN	13.03.2023	Differential and Buchholz trip indication. Key gases found increased.	Replaced by another 40MVA X'mer on 16.05.2023
	63MVA, 132/33KV BBL X'MER AT 220 KV S/S INDORE-SZ	05.04.2023	Differential indication.	Replaced by another 40MVA X'mer on 12.05.2023

Any transmission element/ EHV element under outage, which has not been intimated/included under aforesaid outage list, should be invariably intimated to SLDC. All entities are requested to ensure the same. The utility may submit the latest status.

**[Action:MPPGCL/MPPTCL]**

#### **ITEM NO. 4 : OPERATIONAL STATISTICS FROM APRIL 2023 TO JULY 2023 :**

The details of actual generation, Schedule from Central Sector, demand etc. are given in the following Annexures:

- Annex. 4.1** Unit wise actual Generation of MPPGCL thermal Units and station wise Generation of MPPGCL & NHDC Hydel Units.
- Annex. 4.2** Power Supply Position(Energy Balance Sheet).
- Annex. 4.3** Hourly Average of Availability and Demand.
- Annex. 4.4** Hourly average schedule Vs Drawal of DISCOMs.

**[Committee may like to note]**

#### **ITEM NO. 5: SYSTEM DISTURBANCE IN MP**

**5.1 REPORTING OF FLASH REPORT, DR AND EL FOR 400KV, INTERSTATE TRANSMISSION ELEMENTS & DETAILED TRIPPING REPORT:-** As per the provisions of Regulation 5.2 (r) of CERC (Indian Electricity Grid Code) Regulations 2010 and Regulation of 5(9) of CERC (Indian Electricity Grid Code) (First Amendment) Regulations, 2012 all the Regional Entities of the Region shall furnish the tripping details including DR & EL output to RLDC with in 24 hrs of the event for analysis and identify the real-time measures required in future to ensure secured grid operation. The flash report is also required to be furnished to SLDC within an hour of tripping. Sometimes It is observed that FLASH REPORT are being made available but not DR & EL of tripping of transmission grid element by the State Grid Entities.

It has been intimated by WRLDC that in case of tripping of Inter State & inter Regional lines of voltage class 220 KV & above level, a tripping report along with the DR/EL files shall be submitted to WRLDC within 24Hrs. Also the DR/EL shall be submitted to WRLDC tripping portal, details of which were previously

circulated. The incidences / tripping's which occurred during the month of APRIL-2023 to JULY-2023 for which the details have not been submitted are:-

S NO	Event at s/s	Date	Flash report	DR/EL	REMARK
1	220kV Malanpur-Auraiya S/C	01-05-2023	submitted	submitted	A/R not attempted. MPPTCL may kindly look into the issue
2	220 kV Bhanpura-Ranpur	26-05-2023	submitted	submitted	Line A/R successfully and tripped due to recurrence of fault in reclaim time.
3	220kV Malanpur-Auraiya S/C	05-07-2023	submitted	submitted	A/R not attempted for single phase fault, MPPTCL/NTPC may kindly look into the issue
4	220kV Mehgaon-Auraiya S/C	06-07-2023	submitted	submitted	A/R not attempted for single phase fault, MPPTCL/NTPC may kindly look into the issue

[T&C,MPPTCL/MPPGCL]

#### ITEM NO. 6.0 : IMPORTANT OPERATIONAL ISSUES:-

**6.1 STATUS OF COMPLETION OF ONGOING SCHEMES FOR COMMISSIONING OF REACTORS / TRANSMISSION ELEMENTS:-** The present status regarding schedule and commissioning of reactors / transmission elements is as below:-

S.No.	400 KV S/s	Size MVAR	Implementing Agency	Expected Date of Commissioning as intimated in last OCC
1.	Line reactor on 400 KV S/s Satna (PG) – Sagar Ckt at 400 KV S/s Sagar end.	50 MVar Line Reactor	MPPTCL	P&D informed that the reactor is in the tendering stage, it will be completed by Dec-22, after that it will require 12 months for commissioning work. T&C and P&D MPPTCL please submit the latest status
2.	400KV S/s Sagar	125 MVar Bus Reactor	MPPTCL	Some shifting work is required after that Reactor will be ready for commissioning. It is also to intimate that a revised/recent EI approval shall be provided prior to its charging as the



				element was not in service for more than 6 months. T&C and P&D MPPTCL please submit the latest status
3	400 KV S/S KIRNAPUR	125 MVAR Bus Reactor	MPPTCL	T&C and P&D MPPTCL please submit the status for commissioning of Reactor.

[Action: MPPTCL]

## 6.2 GUIDELINES FOR RESOURCE ADEQUACY PLANNING FRAMEWORK FOR

**INDIA** :- In exercise of the powers conferred under the Rule 16 of Electricity (Amendment) Rules, 2022, the Ministry of Power, Government of India, in consultation with Central Electricity Authority (CEA) hereby issues the guidelines for Resource Adequacy for the Indian electricity sector.

For the past few years, India has been the fastest growing large economy in the World; and the growth will continue. Currently, it is the fifth largest economy in the World; and it is poised to become the third largest economy by 2030. This will only be possible if there is sufficient electricity to power this growth. It is essential that generation capacity is added at a pace matching the growth in demand- and in fact slightly ahead of the demand; so that the shortage of electricity does not slow down growth.

These guidelines shall be followed by all institutions and stakeholders. The complete Guidelines for Resource Adequacy Planning Framework for India is enclosed as **Annexure-6.2**. It is also pertinent to say that Resource Adequacy Planning Framework had been included in IEGC 2023 as an integral part. All the stake holders are requested to provide comments if any.

[Action: MPPTCL, MPPGCL, ]

**6.3 PROTECTION AUDIT** :- In 132nd PCM held on 18/04/2018, it was decided that the protection audit of all critical S/S of 220 kV and all 400 kV level S/S newly commissioned S/S's immediately shall be carried out on specified interval of time (**i.e. within one year of commissioning**) and S/S's where protection audit has been carried out **5 years** back.

In view of the above protection audit of 09 no. substations/generating station (as detailed below) has been carried out in the month of July 2023. The list of substations wise observations is Enclosed as **Annexure – 6.3**. All the concerned entities are requested to provide the status for rectification/compliance of the audit observations in the meeting.

T&C is requested to provide dates of last Third Party Protection audit conducted at 400KV Substations of MPPTCL.

## 6.4 HON'BLE CERC (INDIAN ELECTRICITY GRID CODE) REGULATIONS, 2023

**PROTECTION CODE**:- Hon'ble CERC vide notification dated 03.08.2023 have notified the date of

effective of the (Indian Electricity Grid Code) Regulations, 2023, as 01.10.2023. A new chapter on “Protection Code” has been included and all the users of the system are required to adhere with the clauses of the regulation. The important provisions are as follows.

**Protection Protocol:-**

(1) All users connected to the integrated grid shall provide and maintain effective protection system having reliability, selectivity, speed and sensitivity to isolate faulty section and protect element(s) as per the CEA Technical Standards for Construction, the CEA Technical Standards for Connectivity, the CEA (Grid Standards) Regulations, 2010, the CEA Technical Standards for Communication and any other applicable CEA Standards specified from time to time.

(2) RPC shall develop the protection protocol and revise the same, after review from time to time, in consultation with the stakeholders in the concerned region.

(3) Violation of the protection protocol of the region shall be brought to the notice of concerned RPC by the concerned RLDC or SLDC, as the case may be.

**Protection Settings:-**

(1) RPCs shall undertake review of the protection settings, assess the requirement of revisions in protection settings and revise protection settings in consultation with the stakeholders of the respective region, from time to time and at least once in a year. The necessary studies in this regard shall be carried out by the respective RPCs. The data including base case (peak and off-peak cases) files for carrying out studies shall be provided by RLDC and CTU to the RPCs.

(2) All users connected to the grid shall “furnish the protection settings implemented for each element to respective RPC in a format as prescribed by the concerned RPC”, “obtain approval of the concerned RPC for (i) any revision in settings, and (ii) implementation of new protection system, “ensure correct and appropriate settings of protection as specified by the concerned RPC” and “ensure proper coordinated protection settings”. RPCs shall:

(3) “maintain a centralized database and update the same on periodic basis in respect of their respective region containing details of relay settings for grid elements connected to 220 kV and above (132 kV and above in NER). RLDCs shall also maintain such database”, “carry out detailed system studies, once a year, for protection settings and advise modifications / changes, if any, to CTU and to all users and STUs of their respective regions. The data required to carry out such studies shall be provided by RLDCs and CTU” and “provide the database access to CTU and NLDC and to all users, RLDC, SLDCs, and STUs of the respective regions. The database shall have different access rights for different users”.

(4) The changes in the network and protection settings of grid elements connected to 220kV and above (132 kV and above in NER) shall be informed to RPCs by CTU and STUs, as the case may be.

**Protection Audit Plan:-**

(1) All users shall conduct internal audit of their protection systems annually.

(2) All users shall also conduct third party protection audit of each sub-station at 220 kV and above (132 kV and above in NER) once in five years or earlier as advised by the respective RPC.

(3) After analysis of any event, each RPC shall identify a list of substations / and generating stations where third-party protection audit is required to be carried out and accordingly advise the respective users to complete third party audit within three months.

(4) The third-party protection audit report shall contain information sought in the format enclosed as **Annexure 5.1**. in 153<sup>rd</sup> PCM Agenda of WRPC. The protection audit reports, along with action plan for rectification of deficiencies detected, if any, shall be submitted to the respective RPC and RLDC or SLDC, as the case may be, within a month of submission of third-party audit report. The necessary compliance to such protection audit report shall be followed up regularly in the respective RPC.

(5) Annual audit plan for the next financial year shall be submitted by the users to their respective RPC by 31st October. The users shall adhere to the annual audit plan and report compliance of the same to their respective RPC.

(6) Users shall submit the protection performance indices of previous month to their respective RPC and RLDC on monthly basis for 220 kV and above

#### **System Protection Scheme (SPS)**

(1) For the operational SPS, RLDC or NLDC, as the case may be, in consultation with the concerned RPC(s) shall perform regular load flow and dynamic studies and mock testing for reviewing SPS parameters & functions, at least once in a year. RLDC or NLDC shall share the report of such studies and mock testing including any short comings to respective RPC(s). The data for such studies shall be provided by CTU to the concerned RPC, RLDC and NLDC.

(2) The users and SLDCs shall report about the operation of SPS immediately and detailed report shall be submitted within three days of operation to the concerned RPC and RLDC in the format specified by the respective RPCs.

(3) The performance of SPS shall be assessed as per the protection performance indices specified in these Regulations. In case, the SPS fails to operate, the concerned User shall take corrective actions and submit a detailed report on the corrective actions taken to the concerned RPC within a fortnight.

**Recording Instruments:-** DR/EL synchronization and standard format for recording analogue and digital signals guidelines to be issued by RPC.

**Power System Stabilizers (PSSs),** AVRs of generating units and reactive power controllers shall be properly tuned by the generating station as per the plan and the procedure prepared by the concerned RPC. In case the tuning is not complied with as per the plan and procedure, the concerned RLDC shall issue notice to the defaulting generating station to complete the tuning within a specified time, failing which the concerned RLDC may approach the Commission under Section 29 of the Act.

**[Action:-All Stake holders]**



In view of the above T&C, MPPTCL is also requested to review the existing load drop scheme and shall revise the load drop scheme if required according to the changes/augmentation the network under intimation to SLDC.

The committee may discuss the matter.

[Action:-CE(T&C)-MPPTCL]

#### 6.7 MULTIPLE TRIPPING OF 132 KV KIRNAPUR – DINGARGARH CKT:- Multiple

trippings have occurred on 132 KV Kirnapur – Dongargarh Ckt which is a interstate line. It was intimated that the loading of the line is restricted to 240Amp/55MW to avoid overloading of 400/132KV, 100MVA ICT -1 &2 at Kirnapur. Details of tripping is as follows:-

S.No	Element Name	Date / Time of tripping	Date / Time of Charging
1	132 KV Kirnapur – Dongergarh Ckt	09.08.2023/18:33Hrs	09.08.2023/19:30Hrs
2		10.08.2023/16:31Hrs	10.08.2023/17:23Hrs
3		11.08.2023/07:03Hrs	11.08.2023/07:52Hrs
4		11.08.2023/08:57Hrs	11.08.2023/10:18Hrs
5		11.08.2023/10:57Hrs	11.08.2023/17:17Hrs
6		12.08.2023/00:46Hrs	12.08.2023/01:31Hrs
7		12.08.2023/02:26Hrs	13.08.2023/14:26Hrs
8		13.08.2023/14:28Hrs	14.08.2023/22:52Hrs

T&C, MPPTCL may investigate the reason and provide the details.

[Action:-CE(T&C)-MPPTCL]

#### 6.8 SYSTEM CONSTRAINTS OBSERVED AS PER STUDY FOR UPCOMING RABI

**SEASON:-** A simulation study has been conducted by MP SLDC for meeting the demand of 18500MW (MP periphery)/ 18100MW (Discom periphery) during the ensuing Rabi Season considering the new elements to be commissioned by December-2023.

For Meeting the demand of about 18500MW, the total internal generation has been considered as 6645.9MW . The ATC/TTC calculated by MP SLDC is about 12255.7/11885MW respectively with 370MW TRM and the most credible contingency noticed is at 400/220KV ICT – 1&2 at 400 KV Julwania. The simulation study has been conducted after considering the new/future elements to be commissioned by Dec-2023 as received from STU.

**The constraints observed is as detailed below:-**

**i. 220 KV Shujalpur – Shujalpur (PG) Ckt – 1 & 2:-** As per study the load on these 220 KV circuits is 201 MW each under normal condition and under N-1 contingency it is about 399MW. The conductors of 220 KV Shujalpur – Shujalpur (PG) Ckt – 1 & 2 have been replaced by HTLS conductors to enhance its current carrying capacity. However the up-gradation of the bays at both end is still pending which is restricting the capacity of these circuits to about 800Amps. T&C-MPPTCI, EHT-MPPTCL is requested to provide the status for up gradation of bays at both end.

**ii. 220 KV Khandwa – Neapanagar Ckt and 220 KV Chhegaon – Npeanagar Ckt:-** As per study the load on these 220 KV circuits is 210 MW each under normal condition and under N-1 contingency it is about 299MW. Neapanagar & Bhuranpur is fed through these 2 no. 220 KV Circuits and 2 no. 132 KV circuits only and the load is increasing in the area. In case of contingency of any one of the 220 KV circuit the complete area will be interrupted. P&D-MPPTCL is requested to provide network strengthening plan for the area. Further T&C-MPPTCL is requested to provide the details load drop scheme implemented/to be implemented on 220 KV Khandwa – Neapanagar Ckt and 220 KV Chhegaon – Npeanagar Ckt to avoid any overload/cascade tripping in the area.

**iii. 220 KV Betul (PG) – Betul (MP) Ckt – 1 & 2:-** As per study the load on these 220 KV circuits is 123 MW each under normal condition and under N-1 contingency it is about 243MW. T&C is requested to ensure healthiness of the load drop implemented/to be implemented.

**iv. 220/132KV, 160MVA and 200MVA X'mer at 220 KV S/s Rewa:-** The loading of 220/132KV, 200 MVA X'mer is about 178MW & loading of 220/132KV, 160 MVA X'mer is about 140MW in normal condition. Under N-1 contingency loading is about 200MW. T&C-MPPTCL is requested to ensure the healthiness of the load drop scheme implemented and P&D-MPPTCL is requested to provide network strengthening plan for the area

**v. Single Bus System At Rewa Mp And Loading Issue:-** 220kv Rewa MP is the s/s which is connected with different kind of entities like MPPGCL, PGCIL and other nodes of MPPTCL. This s/s is having only one main bus system on 220kv voltage level. Further, in month of September-22, 220KV REWA MP-REWA RUMS CKT 1 and 2 having HTLS conductors has been charged. After this connection, fault level has been increased at Rewa and it is exporting power to all other nodes .

In this situation the importance of 220kv Rewa MP s/s is very prominent looking to the reliability of network of that area. At this point if any planned or emergency s/d comes on bus then s/s left with no other option instead to keep the entire 220kv network out of service.

As Rewa is the vital source of supply to that area now, hence possibility of construction of 220kv Main Bus no 2 may be explored, it will definitely improve the reliability of power of this area.

**vi. 160MVA, 220/132KV X'mer-1&2 at 220 KV S/s Neapanagar:-** During the 2022-2023 peak demand period the load of the X'mers were 135MW each. Under N-1 contingency the x'mer will get

overloaded and creat interruption in Neapanagar area. P&D may please update the plan for addition of capacity/X'mer at 220KV S/s Neapanagar.

P&D /T&C may please intimate any plan for new bus.

**[Action: MPPTCL (T&C, P&D)]**

**6.9 Tripping of 400 KV SATPURA – ASHTA TRANSMISSION LINE :-** “400 KV DCDS Sarni to Ashta Transmission line, circuit II tripped on **30<sup>th</sup> April 2023 at 17:05 Hrs.** due to heavy rain, Lightning, and thunderstorm.

Upon receiving the tripping information, our ground patrolling team from Shahpur hub reached the tower location nearing the identified fault zone, as observed in Zone 1 Protection Relay. However, no physical deformities were found along the transmission line. Based on our feedback, the transmission line was successfully recharged at 23:37 Hrs. on 30<sup>th</sup> April 2023.

The following observations was found during this tripping:

1. **Sarni end (Satpura Thermal Power Plant) observations:** While reviewing the relay tripping indications, it was observed that the Auto Recloser at the **Sarni end** did not operate, despite the fault being identified as a Single Phase to Earth (B-N) fault. Additionally, the Auto Recloser Block did not appear on the relay. It appears that there may be a problem with the Auto Recloser relay at the **Sarni end**.
2. **Ashta end (400 KV GSS Substation) observations:** According to the relay indications received from Ashta end, it was indicated as “**Broken Conductor**” fault. However, no broken conductor was found during the patrolling of the transmission line, which has been energized since 30<sup>th</sup> April 2023.
3. The Disturbance Recorder / Event Log & Tripping Report at both ends need to be analysed.
4. It is also observed that few towers of 220 KV Transmission line near to our Transmission line at Sarni got collapsed during this event. “

**[Action: MPPTCL (T&C-MPPTCL, MPPGCL, Kalptaru)]**

## **ITEM NO. 7: BLACK-START MOCK DRILL OF HYDEL POWER STATIONS:**

**7.1 BLACK START MOCK DRILL OF HYDEL STATIONS OF MP:-** During 2023-2024 Black Start Mock Drill proposed to be conducted at various Hydel power station of MP is detailed as mentioned below:-

S.NO.	NAME OF HPS	PROPOSED/TENTATIVE DATE OF MOCK DRILL
1.	PENCH HPS	Mock drill proposed by Maharashtra on 06.09.2023
2.	BARGI HPS	Conducted in May 2023
3.	BIRSINGHPUR HPS	Conducted in Dec 2022
4.	MADIKHEDA HPS	Conducted 22.08.2023
5.	TONS HPS	MPPGCL shall intimate the date
6.	ISP HPS	Cannot be conducted due to failure / non-availability of Line Reactor of 400 KV ISP – Indore Ckt – 2 at Indore end.
7.	OSP HPS	NHDC proposed the Month of October for the Mock Drill.
8.	RAJGHAT HPS	Proposed for Sep-2023/ MPPGCL shall intimate the date

[Committee may like to discuss]

## ITEM NO. 8 : AVAILABILITY BASED TARIFF (ABT) RELATED ISSUES:

### 8.1 Non availability of Interface meter data due problem in AMR facility and JMR data:

1. As already informed in previous OCCM that data of around 25 Nos. ABT meters installed at the interface points of Xmers / Feeders are not being downloaded through AMR system of SLDC due to problem in SIM card, no network or meter defective. The list of these interface points is shown in **Annexure-I**. These meters are included in AMC contract. CE(T&C) office is requested to issue instructions to field officers for resolving the issues so that meter data is downloaded remotely at SLDC.

2. Around 07 Nos. ABT meters are installed at the interface points of newly commissioned substation / Xmers as shown in **Annexure-II** are not include in AMC list. The list of meters is already sent to CE(T&C) office vide email dated 31.08.2023. CE(T&C) office is requested to include the list of newly installed meters in the existing AMC contract (Order No. 04-04/ TC-AMR/ SII/ Addl. Order/1799/310 dated 04/05/2022 so as to ensure complete data availability of meters.

3. Non receipt JMR data of newly commissioned substation / Xmers of MP Power Transmission Package -II Limited, MPPTP-IIL is requested to furnish the JMR data every month for checking / verification of meter data as per format enclosed herewith in **Annexure-III**.

[Action : CE(T&C) MPPTCL & MPPTP-IIL]

### 8.2 NON RECEIPT OF ABT METER DATA OF RAILWAY TSS THROUGH AMR SYSTEM

**& JMR:** Railway has informed in the previous OCCMs that the proposal of AMC contract to M/s Secure Meters Ltd. is under process. Railways has also ensured for timely receipt of meter data / JMR data at SLDC on weekly / Monthly basis for issuance of accounts. However, inspite of repeated requests from SLDC, the



complete meter data of Railways is not received by SLDC. Railways is once again requested to provide following assistance to SLDC for timely issuance of accounts on weekly / Monthly basis

1. Issue instructions to concerned officials for providing the weekly / monthly JMR data of TSS end meters to SLDC.
2. In case of missing meter data and JMR data, Nodal officer shall send weekly / monthly meter data through email within two days on request of SLDC.
3. 21 Nos. ABT meters installed at TSS end for the month of August-2023 are not communicating with SLDC AMR system. Also, manually downloaded meter data of these TSS is not received by SLDC despite repeated requests from SLDC.
4. Provide AMC for AMR system of meters installed at TSS and GSS end for successful downloading of meter data.

Railway is requested to apprise the Committee on the status of above issues.

**[Action :Railway]**

**8.3 NON-RECEIPT OF ABT METER DATA OF SOLAR GENERATING STATION:-** SLDC is not receiving the meter data of some pooling stations qualified for RE DSM. The list of missing data of meters has already been emailed on monthly basis but, SLDC is not receiving the meter data timely. The list of meters whose data is not received at SLDC is as under:

Sr. no.	Feeder Name	Location	Meter No
1	VIVAAN SOLAR -1 MAKDON	132KV S/S MAKDON	MPC55922
2	VIVAAN SOLAR -2 MAKDON	132KV S/S MAKDON	XC529587
3	33KV VIVAAN SOLAR -1 TARANA	132KV S/S MAKDON	XD501478

DCC, Indore is requested to take up the matter with concerned officials of West Discoms for providing data to SLDC.

**[Action: West Discoms/ MPPTCL ]**

**8.4 TIME DRIFT IN ABT METER INSTALLED AT THE POOLING STATIONS OF WIND AND SOLAR GENERATING STATIONS AND SLIDING WINDOW PROBLEM:**

The ABT meters installed at the following Pooling Stations of Wind and Solar Power Project has time drift and thus not recording the correct data. SLDC has requested to QCA / Generators with copy to concerned licensee vide letter no 07-05/REG-201/147 dated 25/01/2021 and letter no 07-05/REG -201/2215 dated 30.11.2021 for time synchronization of the ABT meters with GPS so that correct DSM account of these Wind and Solar Projects is issued by SLDC.

Sr.	FEEDER	SUBSTATION	ZONE	Meter No.	TIME DRIFT
-----	--------	------------	------	-----------	------------

no.			(Discom)		IN MINUTES
1	UJAAS I SUSNER	132KV S/s Susner	WZONE	XB571653	417.00
2	33KV MARUTSHAKTI CHANDWASA	33KV CHANDWASA	WZONE	XC502303	330.00
3	UJAAS-1 BERCHHA	132KV S/s BERCHA	WZONE	XB571652	168.00
4	UJAAS -II ICHHAWAR 33 KV	132KV S/S ICHHAWAR	CZONE	MPC59975	137.00
5	GLOBUS STEEL & POWER	132KV S/s SITAMOU	WZONE	XC562469	118.00
6	UJAAS-1 RAJGARH (BIORA)	220KV S/S RAJGARH BIAORA	CZONE	MPP28513	93.00
7	UJAAS 2 SITAMAU	132KV SITAMAU	WZONE	XD501479	22.00
8	33KV TODAY CLEAN ENERGY FDR-II	220KV S/S BAROD	WZONE	XD511507	21:00

Further, ABT meters installed at the following Wind and Solar Generating Stations are recording the 15 minutes block wise data on sliding window principal thus blockwise data do not match with midnight data. SLDC has requested to Generators with copy to concerned licensee vide letter no. 2353 dated 31/08/2019, letter no. 2771, dated 16/10/2019, letter no. 809 & 810 dated 03/06/2020 and letter no 07-05/REG -201/2215 dated 30.11.2021 for immediate replacement of these ABT meters.

Sr.No.	FEEDER NAME	SUBSTATION	ABT METER No.	ZONE	QCA NAME
1	33KV SUZLON- IV RATLAM	132KV S/S JAORA	XE479859	WZONE	RECONNECT ENERGY SOLUTION
2	33KV SUZLON- V RATLAM	132KV S/S JAORA	XE479860	WZONE	RECONNECT ENERGY SOLUTION
3	33KV SUZLON-IV AGAR	132KV S/S AGAR	XE479864	WZONE	RECONNECT ENERGY SOLUTION
4	33KV SUZLON-V (SUSNER-III)	132KV S/S SUSNER	XE479867	WZONE	RECONNECT ENERGY SOLUTION
5	33KV GI POWER PVT. LTD.	220KV S/s MAKDON	X1071843	WZONE	KREATE TECHNOLOGY PVT

6	SUZLON DEV 1 NAGDA HILL	220 KV DEWAS	XE479868	WZONE	RECONNECT ENERGY SOLUTION
7	SIMCON FEEDER - 2	220KV GANJBASODA	Y0327309	CZONE	KREATE TECHNOLOGIES LLP
8	M/S SUZLON INFRA. MAHURIYA 1 SUSNER	132KV S/S SUSNER	XE479866	WZONE	RECONNECT ENERGY SOLUTION PVT LTD

Licenseses are requested to take-up the issue with concerned officials for time synchronization and replacement of ABT meters. Further licenseses are requested to provide monthly status of those meters in which correction of time drift and replacement/ reconfiguration of meters based on sliding window principle were done.

**[Action : West & Central Discoms / MPPTCL]**

## **8.5 VERIFICATION OF CAPTIVE STATUS OF GENERATING PLANTS AND THEIR**

**USERS:** SLDC representative inform that previous OCCM\_85, The Hon'ble M.P. Electricity Regulatory Commission vide order dated 24.03.2023 has authorized Chief Engineer (SLDC), MPPTCL, Jabalpur as the "Designated Authority" under Regulation 5.1 of the Madhya Pradesh Electricity Regulatory Commission (Verification of Captive Generating Plants and Captive Users) Regulations 2023 for determination of the captive status of Captive Generating Plants and Captive Users. The Hon'ble Commission vide aforesaid order has also directed that Designated Authority shall intimate the fulfillment of condition in regard to the captive status to the Captive Generating Plant / Captive Users and the Distribution Licensee by the 15<sup>th</sup> July 2023. Hon'ble MPERC has issued the procedure for verification of Captive Status of Generating Plants and Users which is applicable for FY-2023-24.

SLDC vide letter no. 462 dated 13.04.2023, 587 dated 08.05.2023, 805 dated 20.06.2023 and 927 dated 12.07.2023 has requested the commercial sections of Discoms to provide the informations in respect of Captive Generating Plants and Captive Users under area of their jurisdiction for verification of captive status of Generator and Users so that information could be submitted timely to Hon'ble Commission. The required information of CPP has been received only from West Discoms but not received from Central & East Discom.

DCC of Central & East Discom is requested to take up the matter with their commercial sections for submission of information to SLDC.

**[Action : East & Central Discoms]**

## **ITEM NO. 9: SCADA and E&T RELATED ISSUES**

### **9.1 INTEGRATION OF INTERFACE ENERGY METERS INTO RTUS FOR PROVIDING**

**REAL TIME DATA TO SLDC SCADA/EMS SYSTEM:** As per WRPC decision, The Interface Energy meters installed at interface points are to be integrated into SCADA/EMS system installed at SLDC Jabalpur. By implementing this, all the interface points of STU with ISTS, real time data of interface meters

can also be integrated in SCADA for better management of drawl of State from the Regional Grid. Further WRPC is constantly monitoring the progress regarding installation of Interface Energy meters at interface points with SCADA/EMS system. The list of interface point where integration is to be done is provided earlier and again enclosed herewith as **annexure-I**. However integration of energy meters of Interface point with RTUs for real time display of energy meter reading at SLDC SCADA/EMS system has been done at following locations

- (1) 132 KV Rajghat-Lalitpur
- (2) 400 KV Birsinghpur-Damoh(PG)1
- (3) 400 KV Birsinghpur-Damoh(PG)2
- (4) 400 KV Birsinghpur-KSTPS-1
- (5) 400 KV Birsinghpur-KSTPS-2
- (6) 400 KV Sagar-Bina PG
- (7) 400 KV Sagar-Satna PG
- (8) 400 KV Katni-Damoh PG

The matter regarding integration of energy meter with RTU at MPPGCL and MPPTCL S/s was also discussed in the meeting dtd. 23.12.21 and various OCCM at SLDC and list of interface point have already been shared to official of MPPGCL and MPPTCL.

During the meeting, it was decided that the integration work of Interface meters with RTUs at all the interface point /Drawl point shall be carried out at the earliest. MPPGCL and MPPTCL are thus requested to kindly provide progress in the matter.

MPPGCL official are requested to provide the current status regarding integration of Energy meter at STPS at the interface point of 400 KV Feeder Itarsi(PG), Seoni (PG), and Koradi (MH) and providing real time telemetry data at SCADA system installed at SLDC.

**9.2 REPLACEMENT OF RTUS IN THERMAL POWER STATIONS:-** The matter was taken up by SLDC in various OCCM meetings as well as in separate SCADA and communication meetings held with power station officers and status as per the last OCC Meeting is summarized hereunder.

(i) STPS: - it was informed by MPPGCL they are exploring the possibility of integrating the telemetry of thermal Power Stations through existing SCADA system at Power stations at STPS PH-IV.

(ii) SGTPS: - Procurement of New RTU is in process and is under budgetary offer stage. It is requested to kindly provide present status and time line regarding procurement of RTU.

(iii) ATPS:- Procurement of RTU is in process and shall be completed at the earliest. It is requested to kindly provide present status and time line regarding procurement of RTU.

In view of the above, it is requested to kindly provide present status and expedite the procurement of RTU of ATPS and STPS at the earliest.

MPPGCL is thus requested to provide current progress in the matter.

**9.3 ARRANGEMENT OF TELEMETRY OF IMPORTANT 220KV SUB STATIONS & 132KV S/S HAVING INJECTION FROM RENEWABLES/CAPTIVE POWER PLANTS OR HAVING INTERDISCOM FEEDERS /TRACTION FEEDERS:-**

The telemetry of Birsingpur HPS was commissioned, however the telemetry of Birsingpur HPS is currently not available due to RTU shifting work and some issue in 48 V DC Charger. MPPGCL informed that the 48 V DC Chargers is being replaced with a new Charger. New charger has been procured and connection needs to be done.

MPPGCL are requested to provide current progress in the matter.

The telemetry of Zinna HPS is not available at SLDC SCADA System due to due to some issue in PLCC Channel. Please provide the current Status.

**Action : - MPTPCL, ED (O&M : Gen), MPPGCL**

**9.4 UPGRADATION OF EXISTING RTUS & DISCREPANCY IN TELEMETRERED VALUES RECEIVED FROM DIFFERENT EHV S/S & POWER STATIONS :-**

The present status of telemetry discrepancy including upgradation requirement is enclosed herewith as Annexure-II. The list of major telemetry discrepancies is as given below:-

**(a) MPPGCL Generating Substations :-**

**1. SGTPS :-**

1.Sr. No.	Description	Unit	Pending since
1	XFMR 220 /33, STN XFMR	CB	15 month

**(b) Transmission/ other Generating Substations :-**

SI No.	Name of Substation	Name of feeders/transformers
01	400 KV KATNI S/s	Bus 2 Voltage and Frequency is not available at SLDC SCADA System
02	220 KV SATNA S/s	Katni Feeder MVAR and CB not available

**Action : - MPPTCL, MPPGCL**

**9.5 EXTENSION OF RGMO/FGMO SIGNAL TO SLDC/WRLDC:-** The extension of RGMO/FGMO signal of following generating units is still pending: -

S.No.	Name of Generating Station	Unit.No.	MPPGCL response in last OCC
1	SGTPS	1,2,3,4	MPPGCL informed in last six OCC meetings that it is under tendering process & telemetry integration of RGMO/FGMO signal shall be completed within 3-4 months. However, no progress in the matter has been observed even after lapse of one and half year period.
2.	Singha Ji Phase 2	3, 4	MPPGCL informed in last 6 OCCM that matter has been taken up with L&T to initiate the work at the earliest & the integration work will be done when the units will be taken on operation. MPPGCL is requested to update the progress in this matter.
3	Bargi Unit	2	RGMO status is not available due to wiring related issue in panel.

**9.6 LONG OUTAGE OF RTUS, PROBLEM IN DATA AND VOICE CHANNELS & INTERMITTENT TELEMETRY:-** As per CERC communication regulation 2017, availability of telemetry is required to be ensured more than 99.9%. However following RTUs are either out since very long time or are intermittent:-

S.No.	Name of RTU	Remarks	Telemetry Availability %
1	Birsingpur HPS	Out since more than 20 months	20 %
2	132 KV Ingoria	Intermittent	60%
3	132 KV Bijawar	Intermittent	36 %
4	132 KV Khanooj	Intermittent	55%
5	220 KV Pitampur Sec -III	Intermittent	58%
6	132 KV Zinna	Intermittent	0%
7	132 KV Bara malhera	Intermittent	32%
8	132 KV Amarpatan	Intermittent	71%
9	132 KV Bamore	Intermittent	79%
10	132 KV Sailana	Intermittent	48 %
11	132 KV Raghogarh	Intermittent	21%

12	132 KV Momenbarodia	Intermittent	72%
13	220 KV Sidhi	Intermittent	63 %
14	132 KV Rewa	Intermittent	39 %
15	132 Niwari	Intermittent	73 %

As per WRLDC directives poor telemetry availability (below 95%) is to be treated as violation of grid code as per Clause 4.6.2 of IEGC and WRLDC instructed SLDC to comply the same and to initiate necessary action as per grid code to ensure round the clock availability of telemetry. All grid users are therefore requested to take necessary action to ensure uninterrupted round the clock telemetry availability.

### **9.7 NON AVAILABILITY VOICE COMMUNICATION BETWEEN SLDC TO BANSAGAR –IV (ZINNA) HYDEL POWER STATIONS:-**

It is to inform that as per CERC communication regulation 2017, availability of communication channel is required to be ensured more than 99.9%. However, despite constant pursuance, the PLCC voice communication between SLDC to Bansagar-IV (zinna) has not been established so far. The matter has been also discussed with communication division Satna and it has been informed that due to multiple breakage in coaxial cable and faulty LMU unit, PLCC link is currently not in working condition. However it is pending for more than two years.

MPPGCL is thus requested to provide current progress in the matter.

### **9.8 RECTIFICATION/CONFIRMATION OF READINESS OF OPGW LINKS**

S.No.	OPGW LINK	Action	Remark
1.	220 KV Satna-Katni	Replacement of OPGW cable between 220 KV Satna-Katni	OK
2.	400 KV Bhopal -Bina	Shifting of traffic from Old link to newly constructed Link by MPPTCL	Confirmation and readiness pending.
3.	400 KV Pithampur-Indore	Repairing of 22 faulty fibers out of 24 Fibers	No confirmation from field has been received and Repairing is pending

MPPTCL is thus requested to provide current progress in the matter as testing for the same is pending for more than four months.

**9.9 TELEMETRY OF RAILWAY TSS SUB STATIONS:** - The Reliability of telemetry of existing 73 Nos Railway Traction Sub Stations need to be improved by railway for monitoring of drawl by each TSS and also monitoring of demand of railway in MP. However telemetry availability of Railway TSS is need to be improved.

Railways are requested to ensure reliable telemetry of existing Railway TSS. Further it is to mention that redundant link shall be established as IP scheme has already been provided by this office so that both at a time and through one channel it should report to SLDC Jabalpur and from another channel it should report to Back- up SLDC Bhopal rather to explore the possibility of automatic switching of link at SLDC Jabalpur from both dedicated link.

[Action :- Railway]

**9.10 INFORMATION REGARDING PMU'S FOR THE SECOND PHASE OF URTDSM PROJECT:** - SLDC has provided the list of PMUs proposed to be installed under the URTDSM Phase-II project to be implemented by PGCIL and PGCIL vide email dtd. 21.07.23 has requested to provide the requirements of PMUs by 04.08.23 so that upgradation of PDC/Control Centre and analytics shall be done & requested to verify the list of PMUs and provide the information regarding PMUs requirement for upcoming substations in next 3 years through UO Note dtd. 02.08.23. Further SLDC have sent the remainder UO note dated 23.08.2023 regarding the same information. However the desired details have not yet been provided to this office.

[Action :- Planning & Design ,T&C]

**9.11 DETAILS REGARDING WR-UNMS:-** Power grid vide email dated 30.08.2023, informed that PGCIL is implementing the WR-UNMS project as approved in the 15<sup>th</sup> NCT meeting and desired the details of existing communication equipment as per the format sent through mail dtd 31.08.23 by this office. Therefore, it is requested to kindly share the details of existing communication equipment.

[ Action :- T&C]

**ITEM NO 10 : DATE AND VENUE OF NEXT OCC MEETING :** In 86<sup>th</sup> OCC, the roster for the upcoming OCCM was discussed & finalized in the meeting which is as detailed below. The venue of the same shall be decided in the meeting. It is also proposed that the OCC members shall host the alternate OCC meeting.

MEETING ROSTER	
HOST	MEETING NO.
BLA	87 <sup>TH</sup>
MP Power Transmission Package-II Limited	89 <sup>TH</sup>
OSP	90 <sup>TH</sup>



<b>RAILWAY</b>	91 <sup>ST</sup>
<b>JP Bina</b>	92 <sup>ND</sup>
<b>WEST DISCOM</b>	93 <sup>rd</sup>
<b>ISP</b>	94 <sup>th</sup>

**[Action :- All the concerned entities]**

\*\*\*\*\*

**FREQUENCY PARTICULARS**

S. No.	Particulars	Apr-23		May-23		Jun-23		Jul-23	
<b>1 INTEGRATED OVER AN-HOUR</b>									
1.1	Maximum Frequency	50.26 Hz	Between 14.00 hrs & 14.15 Hrs on 30.04.23	50.37 Hz	Between 01.15 hrs & 01.30 Hrs on 18.05.23	50.34 Hz	Between 07.45 hrs & 08.00 Hrs on 14.06.23	50.35 Hz	Between 13.00 hrs & 13.15 Hrs on 30.07.23
1.2	Minimum Frequency	49.67 Hz	Between 13.45 hrs & 14.00 Hrs on 28.04.23	49.64 Hz	Between 12.30 hrs & 12.45 Hrs on 28.05.23	49.6 Hz	Between 22.30 hrs & 22.45 Hrs on 14.05.23	49.7 Hz	Between 19.15 hrs & 19.30 Hrs on 02.07.23
1.3	Average Frequency	50 Hz		50 Hz		50.01 Hz		50.01 Hz	
<b>2 INSTANTANEOUS FREQUENCY</b>									
2.1	Maximum Frequency	50.33 Hz	AT 18.03:00 HRS ON 16.04.23	50.4 Hz	AT 18.03:00 HRS ON 16.05.23	50.41 Hz	AT 18.00:21 HRS ON 14.06.23	50.42 Hz	AT 13.01:57 HRS ON 30.07.23
2.2	Minimum Frequency	49.49 Hz	AT 22:09:00 HRS ON 15.04.23	49.43 Hz	AT 11:52:09 HRS ON 15.05.23	49.51 Hz	AT 22:33:50 HRS ON 14.06.23	49.58 Hz	AT 19:43:40 HRS ON 03.07.23

**3 Percentage of time when frequency was :-**

	%age of time when frequency was	Apr-23	May-23	Jun-23	Jul-23
3.1	Above 50.30 Hz	0.04	0.08	0.10	0.11
3.2	Between 50.05 Hz and 50.30 Hz	21.68	21.72	25.31	17.25
3.3	Between 50.00 Hz and 50.05 Hz	26.50	27.24	29.17	35.01
3.4	Between 49.9 Hz and 50.00 Hz	41.25	41.10	38.71	42.25
3.5	Between 49.5 Hz and 49.9 Hz	10.53	9.85	6.71	5.38
3.6	Between 49.2 Hz and 49.5 Hz	0.00	0.00	0.00	0.00
3.7	Below 49.2 Hz	0.00	0.00	0.00	0.00



## Discoms wise Average Supply Hours

PARTICULARS	East Zone				Central Zone			
	Apr-23	May-23	Jun-23	Jul-23	Apr-23	May-23	Jun-23	Jul-23
Commissary HQ	23:50	23:55	23:56	23:57	23:53	23:55	23:53	23:46
District HQ	23:49	23:48	23:48	23:47	23:50	23:47	23:50	23:48
Tehsil HQ	23:38	23:32	23:33	23:38	23:49	23:43	23:45	23:39
Rural -Mixed	23:16	23:12	23:10	23:18	23:32	23:15	23:21	23:13
Rural -DLF	23:13	23:12	23:09	23:17	23:26	23:21	23:26	23:16
Rural -Irrigation	9:43	9:44	9:40	9:45	9:46	9:43	9:24	9:45
PARTICULARS	West Zone				MP			
	Apr-23	May-23	Jun-23	Jul-23	Apr-23	May-23	Jun-23	Jul-23
Commissary HQ	23:55	23:51	23:55	23:55	23:52	23:54	23:54	23:52
District HQ	23:48	23:45	23:51	23:53	23:49	23:47	23:49	23:41
Tehsil HQ	23:37	23:39	23:44	23:48	23:41	23:37	23:40	23:41
Rural -3Phase	23:06	23:10	23:19	23:25	23:21	23:13	23:15	23:17
Rural -1Phase	23:21	23:21	23:31	23:39	23:20	23:18	23:21	23:23
Total Rural	9:30	9:29	9:35	9:47	9:40	9:40	9:40	9:46

**ANNEXURE-2.2.2**

**Apr-23**

Sr No	Name of Sub Station	M A X I M U M			M I N I M U M		
		KV	TIME	DATE	KV	TIME	DATE
1	Indore	421	4.00	27 Apr 23	401	16.00	10 Apr 23
2	Bhopal	426	13.10	30 Apr 23	413	3.15	17 Apr 23
3	Nagda	422	4.00	27 Apr 23	403	16.00	10 Apr 23
4	Satpura	433	13.00	30 Apr 23	413	16.00	10 Apr 23
5	SGTPS Birsinghpur	422	18.00	20 Apr 23	405	24.00	10 Apr 23
6	Bina	418	13.10	30 Apr 23	398	22.10	6 Apr 23
7	Pithampur	423	13.00	30 Apr 23	405	16.00	10 Apr 23
8	Ashta	424	13.00	30 Apr 23	404	16.00	10 Apr 23
9	Julwania	424	18.00	28 Apr 23	404	15.00	11 Apr 23
10	Kirnapur	429	9.00	30 Apr 23	411	23.00	10 Apr 23
11	Badnawar	428	4.00	27 Apr 23	409	16.00	10 Apr 23

**May-23**

Sr No	Name of Sub Station	M A X I M U M			M I N I M U M		
		KV	TIME	DATE	KV	TIME	DATE
1	Indore	423	5.00	26 May 23	400	15.00	12 May 23
2	Bhopal	428	4.20	26 May 23	416	4.35	6 May 23
3	Nagda	423	5.00	26 May 23	404	15.00	20 May 23
4	Satpura	430	19.00	21 May 23	412	16.00	13 May 23
5	SGTPS Birsinghpur	418	13.00	1 May 23	402	24.00	13 May 23
6	Bina	420	4.30	26 May 23	393	23.45	13 May 23
7	Pithampur	422	5.00	26 May 23	405	15.00	29 May 23
8	Ashta	425	5.00	26 May 23	404	15.00	29 May 23
9	Julwania	426	1.00	29 May 23	404	12.00	25 May 23
10	Kirnapur	431	8.00	26 May 23	412	15.00	27 May 23
11	Badnawar	429	5.00	26 May 23	408	15.00	29 May 23

### Jun-23

Sr No	Name of Sub Station	M A X I M U M			M I N I M U M		
		KV	TIME	DATE	KV	TIME	DATE
1	Indore	421	4.00	30 Jun 23	401	12.00	3 Jun 23
2	Bhopal	423	18.00	25 Jun 23	401	11.25	3 Jun 23
3	Nagda	422	4.00	30 Jun 23	401	12.00	3 Jun 23
4	Satpura	430	17.00	25 Jun 23	411	15.00	3 Jun 23
5	SGTPS Birsinghpur	423	9.00	14 Jun 23	405	3.00	2 Jun 23
6	Bina	418	13.20	29 Jun 23	398	22.30	2 Jun 23
7	Pithampur	421	4.00	26 Jun 23	404	15.00	3 Jun 23
8	Ashta	423	4.00	30 Jun 23	403	15.00	3 Jun 23
9	Julwania	425	4.00	30 Jun 23	404	16.00	2 Jun 23
10	Kirnapur	433	13.00	25 Jun 23	414	15.00	2 Jun 23
11	Badnawar	433	13.00	25 Jun 23	414	15.00	2 Jun 23

### Jul-23

Name of Sub Station	M A X I M U M			M I N I M U M		
	KV	TIME	DATE	KV	TIME	DATE
Indore	421	4.00	29 Jul 23	406	10.00	21 Jul 23
Bhopal	429	4.25	28 Jul 23	403	19.10	7 Jul 23
Nagda	421	4.00	1 Jul 23	407	10.00	4 Jul 23
Satpura	429	1.00	1 Jul 23	410	13.00	25 Jul 23
SGTPS Birsinghpur	419	12.00	2 Jul 23	406	20.00	3 Jul 23
Bina	419	17.30	28 Jul 23	399	20.45	2 Jul 23
Pithampur	422	5.00	19 Jul 23	409	20.00	3 Jul 23
Ashta	423	4.00	29 Jul 23	407	20.00	3 Jul 23
Julwania	424	5.00	29 Jul 23	412	10.00	4 Jul 23
Kirnapur	431	13.00	8 Jul 23	415	10.00	4 Jul 23
Badnawar	428	4.00	1 Jul 23	414	20.00	3 Jul 23

## Point 10: Details of 33KV feeder which are not allocated with any Group No. as on 30.06.23

Sl.No.	T&C Circle	EHV Sub-Station	Name of 33KV Feeder not allocated with any Group number for U/F & Load Shadding	Feeder DOC
1	SATNA	SATNA 220	33KV BHILAI J P	29-09-09
2	SATNA	KOTAR 220	33KV SUKWAH	15-11-10
3	SATNA	KOTAR 220	33KV KOTAR-II	16-02-18
4	SATNA	MAHAIR 220	33KV BHARAUJI	02-04-11
5	SATNA	MAHAIR 220	33KV UDAYPUR	20-08-13
6	SATNA	AMARPATAN 132	33KV NADAN -2	20-08-09
7	SATNA	AMARPATAN 132	33KV JAL NIGAM	10-03-22
8	SATNA	MAJHGAWAN 132	33KV BARONDHA	07-07-10
9	SATNA	MAJHGAWAN 132	33KV KOTHI	07-07-10
10	SATNA	MAJHGAWAN 132	33KV EAST DICOM	13-03-18
11	SATNA	NAGOD 132	33KV RAHIKWARA	13-02-12
12	SATNA	NAGOD 132	33KV BASUDHA	23-07-15
13	SATNA	NAGOD 132	33KV JASO-II	13-07-21
14	SATNA	NAGOD 132	33KV DEVENDRA NAGAR	BAY CHARGED
15	SATNA	SATNA -II 132	33KV TRANSPORT NAGAR	03-01-19
16	SATNA	SATNA -II 132	33KV ANIKET MATEHNA	17-09-19
17	SATNA	SATNA -II 132	33KV NAVEEN UDHYOGIK BABUPUR	03-02-22
18	SATNA	SATNA -II 132	33KV TIKURIYA TOLA	07-01-19
19	SATNA	SATNA -II 132	33KV BHATANVARA	22-07-22
20	SATNA	SATNA -II 132	33KV MAHADEVA	22-07-22
21	SATNA	SATNA -II 132	33KV SMART CITY	03-09-21
22	SATNA	SATNA -II 132	33KV PURANA POWER HOUSE	22-12-19
23	SATNA	SATNA -II 132	33KV MEDICAL COLLEGE	08-12-18
24	SATNA	UNCHEHRA 132	33KV UNCHEHRA	18-07-20
25	SATNA	UNCHEHRA 132	33KV JEETNAGAR	18-07-20
26	SATNA	UNCHEHRA 132	33KV EAST DISCOM	BAY CHARGED
27	SATNA	RAMPUR BAGHELAN 132	33KV MATEHNA	31-01-19
28	SATNA	PANNA 132	33KV NEW EAST DISCOM	21-11-13
29	SATNA	PAWAI 132	33KV NEW JAY KAYCEM	BAY CHARGED
30	SATNA	REWA 220	33KV GOVIND GARH	11-10-22
31	SATNA	REWA II 132	33KV JAL NIGAM	13-09-22
32	SATNA	MAUGANJ 132	33KV MAUGANJ JAIL	06-12-18
33	SATNA	KATRA 132	33KV GARH	17-08-15
34	SATNA	KATRA 132	33KV PANGADHI	17-08-15
35	SATNA	REWA 132	33KV VTL NEW	08-06-20
36	SATNA	SIRMOUR 220	33KV DEWAS	20-06-16
37	SATNA	SIRMOUR 220	33KV PATEHRA	20-06-16
38	SATNA	SIRMOUR 220	33KV UMARI	19-10-15
39	SATNA	RAMPUR NAIKIN 132	33KV RAMNAGAR (EEWRD SATNA )	09-04-22
40	SATNA	RAMPUR NAIKIN 132	33KV KOTHIYA	28-08-15
41	SATNA	RAMPUR NAIKIN 132	33KV DHANHA	03-04-19
42	SATNA	DONGARITAL 132	33KV APMDCL	24-01-22
43	SEONI	CHHINDWARA 132	33KV DIST HOSPITAL	04-06-18
44	SEONI	SAORI 132	33KV SAORI	11-12-18
45	SEONI	SAORI 132	33KV LAWAGHOGRI	13-11-18
46	SEONI	SAORI 132	33KV MUJAWAR	11-12-18
47	SEONI	SAORI 132	33KV BHUTAI	30-01-19
48	SEONI	SEONI 220	33KV KALARBANKI II	04-10-23
49	SAGAR	RAHLI 132	33KV RAHLI	03-06-19
50	SAGAR	RAHLI 132	33KV CHIRARI	02-04-19
51	SAGAR	RAHLI 132	33KV PATNA BUJURG	30-07-19
52	SAGAR	RAHLI 132	33KV GUDA	27-06-20
53	SAGAR	DEORI 132	33KV KOPRA	20-07-20
54	SAGAR	DEORI 132	33KV DEORI	20-07-20
55	SAGAR	DAMOH 220	33KV JALNIGAM ADHROTA	07-02-22
56	SAGAR	BANDA 132	33KV DALPATPUR-2	28-07-21
57	SAGAR	BANDA 132	33KV JALNIGAM	12-10-22
58	SAGAR	BATIYAGARH 132	33KV BAXWAHA	09-09-15
59	SAGAR	BADAMALEHRA 132	33KV JALNIGAM ( BAANSUJARA)	15-09-22
60	GUNA	MYANA 132	33KV SENDHUA	19-06-21
61	GUNA	CHACHODA 132	33KV CHACHODA	10-11-20

Sl.No.	T&C Circle	EHV Sub-Station	Name of 33KV Feeder not allocated with any Group number for U/F & Load Shadding	Feeder DOC
62	GUNA	CHACHODA 132	33KV RAMDI	10-11-20
63	GUNA	CHACHODA 132	33KV SANAI	19-06-21
64	GUNA	CHACHODA 132	33KV PANCHI	03-02-22
65	KHANDWA	KHANDWA 132	33KV WEST DISCOM	30-11-14
66	KHANDWA	BADGAON 132	33KV AKVN	17-03-21
67	KHANDWA	MOONDI 132	33KV SHIWARIYA TOWN-I	15-10-20
68	KHANDWA	CHHEGOAN MAKHAN 132	33KV MALWA-I	24-02-22
69	KHANDWA	CHHEGAON 400	33KV NVDA -I	12-03-2021
70	KHANDWA	CHHEGAON 400	33KV MICRO IRRIGATION	03-02-22
71	KHANDWA	SANAWAD 132	33KV KHARGONE TRANS. LTD.	15-05-19
72	KHANDWA	SANAWAD 132	33KV BANGARDA	29-01-13
73	KHANDWA	ANDAD 132	33KV MOHAMDPUR	12-09-19
74	KHANDWA	ANDAD 132	33KV GYARASPURA	12-09-19
75	KHANDWA	ANDAD	33KV REHGAON	16-03-21
76	KHANDWA	KASRAWAD 132	33KV BALAKWADA LIFT IRRI.	27-03-21
77	KHANDWA	SHAH PURA 132	33KV WARLA	22-12-21
78	KHANDWA	SHAH PURA 132	33KV BALWADI	10-04-19
79	KHANDWA	SHAH PURA 132	33KV JAMTI	15-10-19
80	KHANDWA	SENDHWA 220	33KV GAWADI	29-05-20
81	KHANDWA	SENDHWA 220	33KV CHACHRIYA	16-08-21
82	KHANDWA	PATI 132	33KV SILAWAD	14-01-21
83	KHANDWA	PATI 132	33KV BOKRATA	04-08-21
84	KHANDWA	BARWANI 132	33KV GHUGSI BIJASAN	20-04-23
85	KHANDWA	JULWANIYA 400	33KV NVDA PH5&7	17-02-23
86	KHANDWA	TALAKPURA 132	33KV LEHKU (PH-6)	15-06-23
87	BHOPAL 400	ADAMPUR 220	33KV KOKTA-I	24-06-21
88	BHOPAL 400	ADAMPUR 220	33KV KOKTA -II	23-06-21
89	BHOPAL 400	MANDIDEEP 132	33KV INTER CONNECTOR-IV	BAY CHARGED
90	BHOPAL 400	MANDIDEEP 132	33KV DAHOD	23-12-19
91	BHOPAL 400	MANDIDEEP 220	33KV INTERCONNECTOR 1	30-12-10
92	BHOPAL 400	MANDIDEEP 220	33KV INTERCONNECTOR 2	16-02-20
93	BHOPAL 400	MANDIDEEP 220	33KV MAHAPET -1	17-03-19
94	BHOPAL 400	MANDIDEEP 220	33KV MAHAPET -2	26-09-19
95	BHOPAL 400	MANDIDEEP 220	33KV INTERCONNECTOR 3	03-03-12
96	BHOPAL 400	MANDIDEEP 220	33KV PARLE	26-02-20
97	BHOPAL 400	TAMOT 132	33KV AKVN NO. I.	05-10-16
98	BHOPAL 400	TAMOT 132	33KV AKVN NO. II.	05-10-16
99	BHOPAL 400	TAMOT 132	33KV OBEDULLAH GANJ	02-02-17
100	BHOPAL 400	TAMOT 132	33KV PLASTIC PARK NO-1	04-04-18
101	BHOPAL 400	TAMOT 132	33KV PLASTIC PARK NO-2	04-04-18
102	BHOPAL 400	BAGRODA 132	33KV AKVN NO. I.	02-07-16
103	BHOPAL 400	BAGRODA 132	33KV AKVN NO. II.	02-07-16
104	BHOPAL 400	BAGRODA 132	33KV DURGA STEEL	22-02-19
105	BHOPAL 400	BAGRODA 132	33KV SOLANKI ENERGY	11-04-18
106	BHOPAL 400	KANNOD 132	33KV M.S.K.	27-07-08
107	BHOPAL 400	TENDUKHEDA 132	33KV SPARE BAY	30-07-20
108	BHOPAL 400	SILWANI 132	33KV SPARE BAY	28-03-2019
109	BHOPAL 400	EINTKHEDI 132	33KV TEXTTILE PARK - I	26-03-23
110	BHOPAL 400	EINTKHEDI 132	33KV TEXTTILE PARK - II	26-03-23
111	JABALPUR	JABALPUR (GORABAZAR ) 220	33KV IIIT DUMNA FEEDER	27-04-23
112	JABALPUR	JABALPUR (GORABAZAR ) 220	33KV GORABAZAR NO-2	27-04-23
113	JABALPUR	JABALPUR (GORABAZAR ) 220	33KV BARELA FEEDER	27-04-23
114	JABALPUR	JABALPUR (GORABAZAR ) 220	33KV KOSAMGHAT FEEDER	27-04-23
115	JABALPUR	JABALPUR (GORABAZAR ) 220	33KV SUKHLALPUR FEEDER	19-04-23
116	JABALPUR	BARHI 132	33KV KUWA	20-01-18
117	JABALPUR	BARHI 132	33KV BARHI	20-01-18
118	JABALPUR	BARHI 132	33KV GERTALAI	20-03-18
119	JABALPUR	BARHI 132	33KV PIPARIYA	20-03-18
120	JABALPUR	DHEEMARKHEDA 132	33KV DASRAMAN	06-09-22
121	JABALPUR	DHEEMARKHEDA 132	33KV KHIRHNI	24-04-23
122	JABALPUR	DHEEMARKHEDA 132	33KV DHEEMERKHEDA	06-06-23
123	JABALPUR	DHEEMARKHEDA 132	33KV JHINNA PIPARIYA	06-06-23
124	JABALPUR	GORAKHPUR 132	33KV GORAKHPUR	21-12-20
125	JABALPUR	GORAKHPUR 132	33KV KARANJIYA	21-12-20

Sl.No.	T&C Circle	EHV Sub-Station	Name of 33KV Feeder not allocated with any Group number for U/F & Load Shadding	Feeder DOC
126	JABALPUR	GORAKHPUR 132	33KV DAMEHARI	20-12-22
127	Bhopal	Amla 132	33KV AIR FORCE	18-05-23
128	Mandsaur	Sailana 220	33KV Dhamedi feeder	29-04-20
129	Mandsaur	Sailana 220	33KV Khedawada feeder	29-04-20
130	Mandsaur	Shivgarh 132	33KV Bhadankala	19-08-20
131	Mandsaur	Shivgarh 132	33KV New Raoti	07-09-20
132	Mandsaur	Shivgarh 132	33KV Palsodi	18-10-20
133	Mandsaur	Daloda 220	33KV Jawasia	17-10-20
134	Mandsaur	Daloda 220	33KV Khilchipura2	13-01-21
135	Indore	Rau 132	33 KV MPIDC-I	16-10-22
136	Indore	Rau 132	33 KV MPIDC-II	16-10-22
137	Indore	Rau 132	33 KV PANTHAR	29-09-13
138	Indore	Rau 132	33 KV HARI PATHAK	29-09-13
139	Ujjain	Nalkheda 220	33KV M/s MKPMU (WRD)	06-01-23
140	Ujjain	Susner 132	33KV M/s MKPMU (WRD)	01-12-22
141	Ujjain	Chapda 220	33KV NVDA	26-04-23



## POINT 5: PROPOSED SHUTDOWN OF TRANSMISSION ELEMENTS FOR THE PERIOD : 01.09.2023 To 31.10.2023

Sr- No	KV	LINE / TRANSFORMER / REACTOR / BAY WITH NAME OF SUB-STATION	From		To		Basis (Daily/ Continue)	Reason
			Date	Time	Date	Time		
<b>A- 400 KV TRANSFORMERS</b>								
1	400	315MVA EMCO TRANSFORMER AT 400KV S/S BINA	01-Sep-23	08:00	01-Sep-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
2	400	315MVA BHEL TRANSFORMER AT 400KV S/S BINA	04-Sep-23	08:00	04-Sep-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
3	400	315MVA CGL TRANSFORMER AT 400KV S/S BINA	06-Sep-23	08:00	06-Sep-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
4	400	315MVA TRANSFORMER-I AT 400KV S/S SAGAR	16-Oct-23	9.00	16-Oct-23	18.00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
5	400	315MVA TRANSFORMER-I AT 400KV S/S SAGAR	17-Oct-23	9.00	17-Oct-23	18.00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
6	400	315 MVA EMCO TRANSFORMER AT 400KV S/S JULWANIA	26-Oct-23	09:00	26-Oct-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
7	400	315MVA CGL TRANSFORMER-I AT 400KV S/S ASHTA	18-Sep-23	09:00	18-Sep-23	18.00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
8	400	315MVA CGL TRANSFORMER-II AT 400KV S/S ASHTA	20-Sep-23	09:00	20-Sep-23	18.00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
9	400	315MVA CGL TRANSFORMER-I AT 400KV S/S ASHTA	25-Sep-23	09:00	25-Sep-23	18.00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
10	400	315MVA BHEL TRANSFORMER AT AT 400KV S/S KATNI	09-Oct-23	09:00	10-Oct-23	17:00	Continue	FOR POST MANSOON MAINTENANCE & TESTING WORK.
11	400	315MVA TELK TRANSFORMER AT 400KV KATNI S/S	12-Oct-23	09:00	13-Oct-23	17:00	Continue	FOR POST MANSOON MAINTENANCE & TESTING WORK.
12	400	315 MVA X-MER ICT- I AT 400KV S/S INDORE	04-Sep-23	09:00	05-Sep-23	17:00	Continue	FOR POST MANSOON MAINTENANCE & TESTING WORK.
13	400	315 MVA X-MER ICT- II AT 400KV S/S INDORE	11-Sep-23	09:00	12-Sep-23	17:00	Continue	FOR POST MANSOON MAINTENANCE & TESTING WORK.
14	400	315 MVA X-MER ICT- IV AT 400KV S/S INDORE	13-Sep-23	09:00	14-Sep-23	17:00	Continue	FOR POST MANSOON MAINTENANCE & TESTING WORK.
15	400	315 MVA TRANSFORMER-I AT 400KV S/S UJJAIN	15-Sep-23	09:00	15-Sep-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
16	400	315 MVA TRANSFORMER-II AT 400KV S/S UJJAIN	18-Sep-23	09:00	18-Sep-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
17	400	315 MVA TRANSFORMER-I AT 400KV S/S UJJAIN	17-Oct-23	09:00	17-Oct-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
18	400	315 MVA TRANSFORMER-II AT 400KV S/S UJJAIN	18-Oct-23	09:00	18-Oct-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
19	400	315MVA TRANSFORMER-III AT 400KV S/S NAGDA	22-Sep-23	09:00	22-Sep-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
20	400	315MVA TRANSFORMER-IV AT 400KV S/S NAGDA	26-Sep-23	09:00	26-Sep-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
21	400	315MVA TRANSFORMER-I AT 400KV S/S NAGDA	04-Oct-23	09:00	04-Oct-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
<b>B- 400 KV REACTORS</b>								
1	400	50MVAR BHOPAL LINE REACTOR-I AT BINA 400KV S/S	08-Sep-23	08:00	08-Sep-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
2	400	50MVAR BHOPAL LINE REACTOR-II AT BINA 400KV S/S	11-Sep-23	08:00	11-Sep-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
3	400	50MVAR BUS REACTOR AT BINA 400KV S/S	14-Sep-23	08:00	14-Sep-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
4	400	80MVAR LINE REACTOR GUNA-1ST AT BINA 400KV S/S	12-Sep-23	08:00	12-Sep-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
5	400	80MVAR LINE REACTOR GUNA-2ND AT BINA 400KV S/S	13-Sep-23	08:00	13-Sep-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
6	400	125MVAR REACTOR AT 400KV S/S SAGAR	18-Oct-23	09:00	18-Oct-23	18.00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.

Sr- No	KV	LINE / TRANSFORMER / REACTOR / BAY WITH NAME OF SUB-STATION	From		To		Basis (Daily/Continue)	Reason
			Date	Time	Date	Time		
7	400	50MVAR BHEL LINE REACTOR NO-1 AT ASHTA 400KV S/S	27-Sep-23	09:00	27-Sep-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
8	400	50MVAR BHEL LINE REACTOR NO-2 AT ASHTA 400KV S/S	29-Sep-23	09:00	29-Sep-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
9	400	50MVAR CGL BUS REACTOR AT ASHTA 400KV S/S	30-Sep-23	09:00	30-Sep-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
10	400	125MVAR BHEL REACTOR AT KATNI 400KV S/S	16-Oct-23	09:00	16-Oct-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
11	400	400KV, 125 MVAR REACTOR AT 400KV S/S UJJAIN	14-Sep-23	09:00	14-Sep-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
12	400	400KV, 125 MVAR REACTOR AT 400KV S/S UJJAIN	16-Oct-23	09:00	16-Oct-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
<b>C- 400 KV FEEDER &amp; BAYS</b>								
1	400	400KV BHOPAL FEEDER-I AT BINA 400KV S/S	03-Oct-23	08:00	03-Oct-23	17:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
2	400	400KV BHOPAL FEEDER-II AT BINA 400KV S/S	04-Oct-23	08:00	04-Oct-23	17:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
3	400	400KV GUNA FEEDER-I AT BINA 400KV S/S	06-Oct-23	08:00	06-Oct-23	17:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
4	400	400KV GUNA FEEDER-II AT BINA 400KV S/S	07-Oct-23	08:00	07-Oct-23	17:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
5	400	400KV BPSCL (JP POWER) FEEDER AT BINA 400KV S/S	09-Oct-23	08:00	09-Oct-23	17:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
6	400	400KV MPPTCL SAGAR- PGCIL SATNA	06-Sep-23	09:00	06-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
7	400	400KV MPPTCL SAGAR- PGCIL BINA	08-Sep-23	09:00	08-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
8	400	400KV ASHTA SATPURA CKT-1 AT ASHTA 400KV S/S	27-Sep-23	09:00	27-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
9	400	400KV ASHTA SATPURA CKT-2 AT ASHTA 400KV S/S	29-Sep-23	09:00	29-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
10	400	400KV BINA - II FEEDER AT BHOPAL 400KV S/S	11-Sep-23	09:00	20-Sep-23	18:00	Countinue	FOR 400KV C&R PANNEL REPLACEMENT WORK
11	400	400KV ITARSI - I FEEDER AT BHOPAL 400KV S/S	25-Sep-23	09:00	27-Sep-23	18:00	Countinue	FOR ATTENDING BMK RUSTING ISSUE AT 400 KV S/S PGCIL ITARSI END.
12	400	400KV ASHTA UJJAIN -1 AT ASHTA 400KV S/S	04-Oct-23	09:00	04-Oct-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
13	400	400KV ASHTA UJJAIN -2 AT ASHTA 400KV S/S	06-Oct-23	09:00	06-Oct-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
14	400	400KV BUS COUPLER AT ASHTA 400KV S/S	09-Oct-23	09:00	09-Oct-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
15	400	400KV BINA - II FEEDER AT BHOPAL 400KV S/S	03-Oct-23	09:00	13-Oct-23	18:00	Countinue	FOR 400KV C&R PANNEL REPLACEMENT WORK
16	400	400KV ITARSI - II FEEDER AT BHOPAL 400KV S/S	20-Oct-23	09:00	31-Oct-23	18:00	Countinue	FOR 400KV C&R PANNEL REPLACEMENT WORK
17	400	400KV ISP-I AT 400KV S/S INDORE	19-Sep-23	09:00	19-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
18	400	400KV ISP-II AT 400KV S/S INDORE	20-Sep-23	09:00	20-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
19	400	400KV NAGDA AT 400KV S/S INDORE	22-Sep-23	09:00	22-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
20	400	400KV TBC AT 400KV S/S INDORE	03-Oct-23	09:00	03-Oct-23	18:00	Dialy	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
21	400	400 KV BUS COUPLER AT 400KV S/S INDORE	04-Oct-23	09:00	04-Oct-23	18:00	Dialy	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
22	400	400KV MAIN BUS -IST AT 400KV S/S UJJAIN	01-Sep-23	09:00	01-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
23	400	400KV MAIN BUS -IIND AT 400KV S/S UJJAIN	04-Sep-23	09:00	04-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
24	400	400KV UJJAIN -NAGDA CKT-IST AT 400KV S/S UJJAIN	05-Sep-23	09:00	05-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
25	400	400KV UJJAIN -NAGDA CKT-IIND AT 400KV S/S UJJAIN	06-Sep-23	09:00	06-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
26	400	400KV UJJAIN -(INDORE)PGCIL CKT-IST AT 400KV S/S UJJAIN	08-Sep-23	09:00	08-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK

Sr- No	KV	LINE / TRANSFORMER / REACTOR / BAY WITH NAME OF SUB-STATION	From		To		Basis (Daily/Continue)	Reason
			Date	Time	Date	Time		
27	400	400KV UJJAIN -(INDORE)PGCIL CKT-IIND AT 400KV S/S UJJAIN	11-Sep-23	09:00	11-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
28	400	400KV UJJAIN -ASHTA CKT-IST AT 400KV S/S UJJAIN	12-Sep-23	09:00	12-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
29	400	400KV UJJAIN -ASHTA CKT-IIND AT 400KV S/S UJJAIN	13-Sep-23	09:00	13-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
30	400	400KV BUS TIE AT 400KV S/S UJJAIN	19-Sep-23	09:00	19-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
31	400	400KV MAIN BUS -IST AT 400KV S/S UJJAIN	03-Oct-23	09:00	03-Oct-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
32	400	400KV MAIN BUS -IIND AT 400KV S/S UJJAIN	04-Oct-23	09:00	04-Oct-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
33	400	400KV UJJAIN -NAGDA CKT-IST AT 400KV S/S UJJAIN	05-Oct-23	09:00	05-Oct-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
34	400	400KV UJJAIN -NAGDA CKT-IIND AT 400KV S/S UJJAIN	06-Oct-23	09:00	06-Oct-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
35	400	400KV UJJAIN -(INDORE)PGCIL CKT-IST AT 400KV S/S UJJAIN	09-Oct-23	09:00	09-Oct-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
36	400	400KV UJJAIN -(INDORE)PGCIL CKT-IIND AT 400KV S/S UJJAIN	10-Oct-23	09:00	10-Oct-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
37	400	400KV UJJAIN -ASHTA CKT-IST AT 400KV S/S UJJAIN	11-Oct-23	09:00	11-Oct-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
38	400	400KV UJJAIN -ASHTA CKT-IIND AT 400KV S/S UJJAIN	12-Oct-23	09:00	12-Oct-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
39	400	400KV BUS TIE AT 400KV S/S UJJAIN	13-Oct-23	09:00	13-Oct-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
40	400	400KV BADNAWAR CKT-I AT 400KV S/S NAGDA	15-Sep-23	09:00	15-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
41	400	400KV ISP AT 400KV S/S NAGDA	26-Sep-23	09:00	26-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
42	400	400KV INDORE AT 400KV S/S NAGDA	29-Sep-23	09:00	29-Sep-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
43	400	400KV BADNAWAR CKT-II AT 400KV S/S NAGDA	04-Oct-23	09:00	04-Oct-23	18:00	Daily	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK
<b>D- 220 KV TRANSFORMERS</b>								
1	220	220KV PANDHURNA 160MVA X-MER -I CGL	10-Oct-23	09:00	10-Oct-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK
2	220	220KV PANDHURNA 160MVA X-MER -II BBL	11-Oct-23	09:00	11-Oct-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
3	220	200 MVA AT 220KV DAMOH	09-Oct-23	9.00	09-Oct-23	18.00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
4	220	160 MVA BHEL AT 220KV DAMOH	10-Oct-23	9.00	10-Oct-23	18.00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
5	220	160 MVA AREVA AT 220KV DAMOH	11-Oct-23	9.00	11-Oct-23	18.00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
6	220	160 MVA BHEL AT 400KV SAGAR	03-Oct-23	9.00	03-Oct-23	18.00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
7	220	160 MVA AREVA AT 400KV SAGAR	04-Oct-23	9.00	04-Oct-23	18.00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
8	220	160 MVA BBL AT 400KV SAGAR	05-Oct-23	9.00	05-Oct-23	18.00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
9	220	160MVA X-MER (NGEF) (AT BARWAHA 220KV SUBSTATION)	04-Sep-23	09:00	04-Sep-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
10	220	160MVA X-MER (BHEL) (AT NIMRANI 220KV SUBSTATION)	05-Sep-23	09:00	05-Sep-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
11	220	160MVA X-MER (CGL) (AT NIMRANI 220KV SUBSTATION)	08-Oct-23	09:00	08-Oct-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
12	220	160MVA X-MER (BHEL) (AT NIMRANI 220KV SUBSTATION)	09-Oct-23	09:00	09-Oct-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.

Sr- No	KV	LINE / TRANSFORMER / REACTOR / BAY WITH NAME OF SUB-STATION	From		To		Basis (Daily/ Continue)	Reason
			Date	Time	Date	Time		
13	220	160MVA X-MER-I (BHEL) (AT JULWANIYA 400KV SUBSTATION)	11-Oct-23	09:00	11-Oct-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
14	220	160MVA X-MER-II (BHEL) (AT JULWANIYA 400KV SUBSTATION)	17-Oct-23	09:00	17-Oct-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
15	220	160MVA X-MER-II (BBL) (AT JULWANIYA 220KV SUBSTATION)	27-Oct-23	09:00	27-Oct-23	17:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
16	220	100MVA X-MER - (CGL) (ASHTA 400)	11-Sep-23	09:00	11-Sep-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
17	220	50MVA X-MER - (BBL) (ASHTA 400)	13-Sep-23	09:00	13-Sep-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
18	220	160MVA X-MER - I (AREVA) (ASHTA 400)	15-Sep-23	09:00	15-Sep-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
19	220	160MVA X-MER - II (BBL) (ASHTA 400)	18-Sep-23	09:00	18-Sep-23	18:00	Daily	FOR POST MANSOON MAINTENANCE & TESTING WORK.
20	220	160MVA AREVA TRANSFORMER AT 220KV S/S NAGDA	03-Oct-23	09:00	03-Oct-23	18:00	Daily	POST MANSOON MAINTENANCE WORK
21	220	50MVA BBL TRANSFORMER AT 220KV S/S NAGDA	10-Oct-23	09:00	10-Oct-23	18:00	Daily	POST MANSOON MAINTENANCE WORK
22	220	160MVA CGL TRANSFORMER AT 220KV S/S NAGDA	18-Oct-23	09:00	18-Oct-23	18:00	Daily	POST MANSOON MAINTENANCE WORK

Unitwise / Stationwise Generation in MU						
A. Thermal			Ann 4.1			
Stn. Name	UNIT No.	Capacity MW	Apr-23	May-23	June-23	July-23
AMARKA	5	210	150.57	150.09	130.47	155.21
	PH III	210	150.57	150.09	130.47	155.21
	TOT	210	150.57	150.09	130.47	155.21
SATPURA	6	200	0.00	0.00	0.00	0.00
	7	210	0.00	0.00	0.00	0.00
	PH II	410	0.00	0.00	0.00	0.00
	8	210	0.00	0.00	0.00	0.00
	9	210	0.00	0.00	0.00	0.00
	PH III	420	0.00	0.00	0.00	0.00
	10	250	173.75	178.59	172.21	179.34
	11	250	174.59	179.05	156.00	123.64
	PH IV	500	348.34	357.64	328.21	302.99
TOT	1330	348.34	357.64	328.21	302.99	
SANJAY GANDHI	1	210	114.23	118.12	95.53	114.35
	2	210	106.79	127.48	122.25	106.05
	PH I	420	221.02	245.60	217.78	220.41
	3	210	88.46	39.50	125.68	119.78
	4	210	128.13	34.72	129.50	126.77
	PH II	420	216.60	74.23	255.18	246.55
	5	500	316.51	361.40	304.72	364.18
	PH III	500	316.51	361.40	304.72	364.18
TOT	1340	754.13	681.23	777.68	831.14	
SSTPS	1	600	286.80	300.69	323.88	290.55
	2	600	278.73	254.83	127.16	24.42
	PH1	1200	565.53	555.52	451.04	314.97
	3	660	339.48	407.90	283.49	392.82
	4	660	220.17	248.47	284.74	278.88
	PH II	1320	559.65	656.37	568.23	671.70
TOT	2520	1125.18	1211.89	1019.27	986.67	
MPPGCL THERMAL		5400	2378.21	2400.84	2255.64	2276.00
<b>B. Hydel</b>						
Station Name	Capacity MW	Apr-23	May-23	June-23	July-23	
GANDHISAGAR	115.0	30.21	25.88	1.48	15.71	
R.P.SAGAR	172.0	1.97	1.90	0.48	45.02	
J.SAGAR	99.0	0.12	1.21	2.25	32.89	
CHAMBAL	386.0	32.30	28.98	4.21	93.62	
M.P.CHAMBAL	193.0	16.15	14.49	2.10	46.81	
PENCH	160.0	5.39	3.38	6.09	21.89	
M.P.PENCH	107.0	3.60	2.25	4.06	14.59	
BARGI	90.0	15.76	25.31	30.64	61.21	
TONS	315.0	51.87	53.40	45.23	24.20	
BIRSINGHPUR	20.0	0.00	0.05	2.10	12.38	
B.SGR(DEOLONDH)	60.0	0.00	0.00	12.40	42.01	
B.SGR(SILPARA)	30.0	6.41	8.53	7.02	4.55	
RAJGHAT	45.0	0.00	3.17	0.43	16.47	
M.P.RAJGHAT	22.5	0.00	1.89	0.25	9.83	
B.SGR(JINHA)	20.0	6.18	7.42	6.54	7.28	
MADIKHEDA	60.0	0.00	0.00	1.56	5.71	
TOTAL HYDEL	1186.0	117.90	130.25	116.22	289.31	
MPPGCL Hydel	915.0	115.82	127.14	113.50	211.40	
MPSEB HYDEL Share	917.5	99.96	113.35	111.92	228.56	
<b>C. NHDC (Ex-Bus)</b>						
Station Name	Capacity MW	Apr-23	May-23	June-23	July-23	
Indira Sagar Hydel Project	1000	29.65	76.15	193.86	380.53	
Omkareshwar Hydel Project	520	20.63	34.86	101.71	230.44	



**ENERGY BALANCE SHEET : Demand & Sypply Hours**

**Year : 2023 -24**

S.NO		Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	Yr 20-21
<b>C. MORNING PEAK (MAX)</b>														
1	DEMAND MET	11711	11429	11260	11815	0	0	0	0	0	0	0	0	11815
2	LOAD RELIEF	0	0	0	0	0	0	0	0	0	0	0	0	0
3	LOAD SHEDDING	0	0	0	0	0	0	0	0	0	0	0	0	0
<b>D. EVENING PEAK (MAX)</b>														
1	DEMAND MET	11782	11518	11393	11728	0	0	0	0	0	0	0	0	11782
2	LOAD RELIEF	0	0	0	0	0	0	0	0	0	0	0	0	0
3	LOAD SHEDDING	0	0	0	0	0	0	0	0	0	0	0	0	0
<b>F. REGISTERED MAXIMUM</b>		11974	12103	11631	11815	0	0	0	0	0	0	0	0	12103
<b>G. COMPUTED MAXIMUM DEMAND</b>		12028	12103	11631	11815	0	0	0	0	0	0	0	0	12103
<b>H. UNRESTRICTED MAXIMUM DEMAND</b>		12028	12103	11718	11815	0	0	0	0	0	0	0	0	12103
<b>I. Average Power Supply per day to</b>														
1.	Div. Head Quarters	23:52	23:54	23:54	0:00	0:00	0:00	0:00	0:00	0:00	0:00	0:00	0:00	17:49
2.	District Head Quarters	23:49	23:47	23:49	0:00	0:00	0:00	0:00	0:00	0:00	0:00	0:00	0:00	17:45
3.	Tahsil Head Quarters	23:41	23:37	23:40	0:00	0:00	0:00	0:00	0:00	0:00	0:00	0:00	0:00	17:39
4.	Rural -Mixed	23:21	23:13	23:15	0:00	0:00	0:00	0:00	0:00	0:00	0:00	0:00	0:00	17:21
5.	Rural -DLF	23:20	23:18	23:21	0:00	0:00	0:00	0:00	0:00	0:00	0:00	0:00	0:00	17:24
6.	Rural -Irrigation	9:40	9:40	9:40	0:00	0:00	0:00	0:00	0:00	0:00	0:00	0:00	0:00	7:13
<b>J. LOAD FACTOR %</b>		59.09	59.99	64.19	62.41	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	0.00	61.42

**FREQUENCY ANALYSIS YEAR 2022-23**

S.N	PARTICULARS	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	Yr 20-21
<b>A. INTGRATED FREQUENCY</b>														
1	MAXIMUM	50.26	50.37	50.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	50.37
2	MINIMUM	49.67	49.64	49.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
<b>B. INSTANTANEOUS FREQUENCY</b>														
1	MAXIMUM	50.33	50.40	50.41	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	50.41
2	MINIMUM	49.49	49.43	49.51	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
<b>C. AVG FREQUENCY</b>		50.00	50.00	50.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37.50
<b>D. % TIME WHEN FREQUENCY WAS</b>														
1	Above 50.30 Hz	0.04	0.08	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05
2	Between 50.05 TO 51.30 Hz	21.68	21.72	25.31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.74
3	Between 50.00 TO 50.05 Hz	26.50	27.24	29.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	Between 49.90 TO 50.00 Hz	41.25	41.10	38.71	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5	Between 49.50 TO 49.90 Hz	10.53	9.85	6.71	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.74
6	Between 49.20 TO 49.50 Hz	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	BELOW 49.2 Hz	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

**Hourly Average Own Generation, Schedule Drawal , Actual Drawal & Demand**  
**Month - April 2023**

**FIGURES IN MW**

Hrs.	Own Generation												Schedule from																			Load Shedding				REST. DEMAN D	UNREST. DEMAND		
	FREQ.	THER. Inj Aux	THER. Ext Aux	HYD.	ISP	OSP	Total SPS Injectio n	Total CH2S Injectio n	Total	CSS	Net NR to MP	Slupe n	Lanco	Gasam	Essa r	JP Nigri	RUMS (SCLA RI REWA TO MP) CL	MB Power	Jhabu a	SSP	SCH to Raily	SEZ	Banking	Sale	Pur	STOA	Rihan g-Ma Righ at	MTQA / STOA FROM RAJAS THAN	Total	Tot. Avl.	Act. Dtl	Devia tion	Expo to MS	DEMAN D MET	SCH			UN SCH	TOTAL
1:00	50.00	3427	3206	134	40	9	386	798	4575	3461	36	0	148	1024	47	441	0	332	159	61	351	0	-78	-531	91	-133	1	0	5431	10006	5329	-102	-19	9886	0	0	0	9888	9888
2:00	50.02	3416	3198	109	12	0	356	819	4496	3379	50	0	148	1037	47	441	0	313	159	61	352	0	-78	-648	91	-138	1	0	5213	9709	4997	-215	-18	9476	0	0	0	9477	9477
3:00	50.01	3369	3151	109	4	0	356	788	4406	3273	44	0	148	1040	43	441	0	303	154	61	352	0	-78	-696	99	-147	1	0	5037	9443	5026	-11	-17	9414	0	0	0	9417	9417
4:00	50.00	3361	3144	110	12	0	363	767	4395	3269	29	0	148	1044	43	440	0	284	153	61	364	0	-78	-648	100	-149	1	0	5070	9466	4992	-78	-18	9370	0	0	0	9372	9372
5:00	49.99	3369	3151	113	4	9	372	740	4389	3307	37	0	148	1046	45	441	0	284	139	61	364	0	-78	-712	91	-147	1	0	5019	9468	4946	-73	-18	9317	0	0	0	9322	9322
6:00	49.98	3455	3232	174	60	89	383	669	4606	3411	37	0	148	1038	47	442	1	307	154	67	360	0	-78	-474	91	-129	1	0	5424	10030	5409	-15	-20	9995	0	0	0	10004	10004
7:00	50.06	3497	3272	288	184	115	404	701	4966	3519	48	0	148	1025	47	442	15	335	159	67	370	0	-78	-219	110	-156	1	0	5833	10799	5765	-68	-22	10709	0	0	0	10709	10709
8:00	50.05	3391	3172	215	57	80	368	821	4683	3364	21	0	148	1024	44	442	149	310	148	66	358	0	-78	-245	145	-233	1	0	5664	10347	5907	243	-23	10567	0	0	0	10568	10568
9:00	50.03	3290	3076	199	56	41	326	1025	4724	3090	14	0	147	1025	36	435	316	260	118	65	357	0	-78	-312	96	-311	1	0	5200	9984	5905	544	-21	10507	0	0	0	10510	10510
10:00	50.01	3163	2956	125	8	13	306	1282	4690	3022	13	0	147	1022	24	431	460	214	112	60	360	0	-78	-619	88	-413	1	0	4845	9536	5450	605	-22	10119	0	0	0	10123	10123
11:00	50.01	3033	2835	117	16	4	286	1372	4633	2955	12	0	147	1016	17	428	534	195	80	55	341	0	-78	-728	49	-492	1	0	4531	9164	5444	913	-21	10056	0	0	0	10060	10060
12:00	49.98	3080	2879	151	24	0	295	1395	4744	2918	16	0	147	1024	12	428	550	201	69	51	338	0	-78	-608	37	-514	1	0	4593	9336	5424	832	-21	10147	0	0	0	10156	10156
13:00	49.98	3016	2821	150	12	0	289	1382	4654	2934	27	0	148	1038	12	428	549	203	85	49	345	0	-78	-503	27	-509	1	0	4756	9410	5618	863	-22	10251	0	0	0	10260	10260
14:00	49.98	3006	2810	140	8	6	294	1316	4575	2863	25	0	148	1036	12	428	514	205	68	50	338	0	-78	-823	30	-482	1	0	4635	9209	5453	818	-22	10006	0	0	0	10016	10016
15:00	49.96	3139	2936	142	28	7	334	1215	4662	2946	50	0	148	1049	25	428	400	261	116	53	344	0	-100	-701	67	-384	1	0	4703	9365	5534	830	-23	10172	0	0	0	10186	10186
16:00	49.97	3288	3076	142	21	13	367	1064	4683	3083	20	0	148	1044	31	429	235	273	130	53	335	0	-100	-667	79	-306	1	0	4787	9470	5356	569	-22	10017	0	0	0	10028	10028
17:00	49.98	3292	3079	152	36	4	364	826	4461	3145	18	0	148	1036	39	434	51	298	133	53	356	0	-100	-717	94	-213	1	0	4775	9237	5073	298	-22	9913	0	0	0	9920	9920
18:00	49.99	3242	3032	149	32	9	352	598	4171	3142	17	0	147	1032	43	436	2	298	134	59	352	0	-78	-457	100	-151	1	0	5077	9247	5196	120	-21	9346	0	0	0	9351	9351
19:00	50.01	3383	3166	232	93	78	404	551	4524	3470	44	0	148	1034	47	443	0	335	150	63	357	0	-78	-284	100	-122	1	0	5706	10230	5615	-91	-20	10118	0	0	0	10123	10123
20:00	50.02	3404	3185	243	84	82	408	578	4580	3542	31	0	148	1016	48	437	0	348	155	65	353	0	-78	-394	99	-122	1	0	5648	10229	5530	-118	-20	10090	0	0	0	10092	10092
21:00	50.00	3404	3185	167	32	41	392	664	4480	3401	23	0	148	1013	48	437	0	317	150	65	361	0	-78	-571	89	-123	1	0	5282	9762	5117	-164	-22	9575	0	0	0	9580	9580
22:00	50.01	3429	3209	143	31	30	392	732	4537	3424	19	0	148	1016	48	438	0	329	155	65	351	0	-78	-515	89	-125	1	0	5367	9904	5262	-105	-21	9778	0	0	0	9782	9782
23:00	49.99	3447	3225	171	73	45	398	798	4710	3513	21	0	148	1016	48	438	0	336	155	64	348	0	-78	-391	89	-125	1	0	5583	10293	5550	-33	-20	10241	0	0	0	10248	10248
24:00	50.01	3423	3202	167	65	33	396	804	4666	3466	23	0	148	1019	48	438	0	323	155	62	346	0	-75	-417	89	-133	1	0	5493	10160	5374	-120	-19	10021	0	0	0	10024	10024
Avg.	50.00	3305	3092	160	41	28	358	904	4584	3246	28	0	148	1030	37	436	157	287	133	60	351	0	-81	-524	85	-240	1	0	5156	9739	5382	227	-21	9945	0	0	0	9951	9951
00 TO 06 HRS.	50.00	3400	3180	125	22	18	370	764	4478	3353	39	0	148	1038	45	441	0	307	153	62	354	0	-78	-618	93	-140	1	0	5199	9677	5117	-82	-18	9576	0	0	0	9580	9580
06 TO 12 HRS.	50.02	3242	3032	183	58	37	331	1099	4740	3145	21	0	148	1023	30	434	337	253	114	61	354	0	-78	-455	88	-353	1	0	5121	9861	5633	511	-22	10351	0	0	0	10354	10354
12 TO 18 HRS.	49.98	3164	2959	146	23	7	333	1067	4534	3019	26	0	148	1039	27	430	292	256	111	53	345	0	-89	-595	66	-341	1	0	4789	9323	5372	583	-22	9884	0	0	0	9894	9894
00 TO 18 HRS.	50.00	3203	2995	164	40	22	332	1083	4637	3082	23	0	148	1031	28	432	315	284	113	57	349	0	-84	-525	77	-347	1	0	4955	9592	5062	547	-22	10117	0	0	0	10124	10124
18 TO 24 HRS.	50.01	3415	3195	187	63	82	398	688	4583	3469	27	0	148	1020	48	438	0	331	153	64	353	0	-78	-429	93	-125	1	0	5513	10096	5408	-105	-20	9971	0	0	0	9975	9975



**Hourly Average Own Generation, Schedule Drawal , Actual Drawal & Demand  
Month - May 2023**

**FIGURES IN MW**

Hrs.	Own Generation											Schedule from																	Load Shedding										
	FREQ.	Ther. Inlet Aux	Ther. Exit Aux	HYD.	ISP	OSP	Total Inlets	Total CHPs	Total	CSS	Net NR to MP	Sign	Lanco	Gasam	Essa	JP Nigri	RUMS (SCLA RI RINA TO MP) CL	MB Power	Jhabu a	SSP	SCH to Raily	SEZ	Banking	Sale	Pur	STOA	Rihan (s-Ma Raha) at	MTQA / STOA FROM RAJAS THAN	Total	Total	Act. Dlt	Devis ion	Expd to MS	DEMAN D MET	SCH	UN SCH	TOTAL	REST. DEMAN D	UNREST. DEMAND
1:00	50.03	3302	3094	170	126	44	471	808	4713	3360	89	0	186	1122	40	431	0	338	150	43	364	0	-202	-297	85	-147	4	0	5565	10278	5341	-224	-13	10041	0	0	0	10042	10042
2:00	50.02	3290	3063	147	107	31	465	787	4621	3323	105	0	186	1127	36	429	0	320	149	23	359	0	-202	-423	79	-164	4	0	5351	9971	5173	-178	-12	9781	0	0	0	9782	9782
3:00	50.01	3303	3095	126	95	29	467	780	4591	3282	78	0	186	1132	32	434	0	320	148	19	350	0	-208	-408	76	-170	3	0	5273	9865	5217	-67	-12	9797	0	0	0	9800	9800
4:00	50.01	3305	3097	138	98	17	459	756	4565	3276	48	0	189	1143	31	435	0	314	143	19	363	0	-208	-437	76	-176	3	0	5220	9785	5088	-132	-12	9641	0	0	0	9644	9644
5:00	49.99	3300	3093	137	57	34	454	707	4481	3237	73	0	189	1166	30	433	0	302	148	31	349	0	-208	-453	76	-173	3	0	5203	9684	5086	-117	-12	9555	0	0	0	9561	9561
6:00	50.00	3322	3114	186	134	50	460	667	4611	3260	45	0	189	1156	30	434	12	326	141	38	361	0	-111	-368	85	-155	3	0	5445	10056	5325	-120	-14	9922	0	0	0	9929	9929
7:00	50.03	3322	3114	204	100	67	454	765	4794	3184	41	0	189	1166	23	434	33	320	141	43	367	0	-111	-221	85	-197	3	0	5499	10203	5436	-63	-15	10125	0	0	0	10127	10127
8:00	50.06	3157	2958	188	64	63	372	524	4569	2931	21	0	186	1164	19	434	207	263	136	29	349	0	-111	-241	82	-287	3	0	5186	9755	5406	220	-15	9960	0	0	0	9961	9961
9:00	50.03	3021	2829	168	54	40	339	1153	4581	2733	21	0	181	1167	18	430	351	196	90	20	362	0	-111	-289	74	-373	3	0	4873	9453	5447	574	-14	10013	0	0	0	10015	10015
10:00	50.00	2926	2740	132	77	25	345	1264	4682	2757	22	0	181	1163	15	430	475	205	91	20	354	0	-208	-543	85	-442	3	0	4588	9270	5281	693	-14	9948	0	0	0	9955	9955
11:00	50.02	2933	2747	152	69	25	354	1482	4828	2732	9	0	179	1139	11	430	536	202	88	19	346	0	-215	-668	44	-494	3	0	4362	9190	5168	806	-14	9983	0	0	0	9985	9985
12:00	49.97	3053	2860	167	73	27	365	1509	5001	2734	8	0	179	1130	11	430	534	226	114	20	333	0	-215	-770	44	-505	3	0	4276	9277	5161	874	-14	10138	0	0	0	10149	10149
13:00	49.96	3057	2864	153	50	23	361	1461	4912	2706	7	0	181	1121	11	430	529	228	104	19	342	0	-215	-619	41	-504	3	0	4384	9296	5363	979	-13	10262	0	0	0	10278	10278
14:00	49.97	3086	2891	146	42	37	372	1429	4918	2728	7	0	184	1129	12	430	481	226	98	19	334	0	-215	-681	44	-483	3	0	4314	9231	5237	923	-13	10142	0	0	0	10153	10153
15:00	49.96	3132	2934	168	107	29	407	1324	4969	2920	4	0	184	1133	20	424	359	271	119	18	342	0	-218	-810	69	-398	3	0	4430	9390	5288	858	-12	10245	0	0	0	10261	10261
16:00	49.99	3244	3040	157	77	25	431	1168	4898	3066	5	0	186	1128	23	431	208	283	136	18	334	0	-218	-729	65	-330	3	0	4607	9506	5236	629	-13	10121	0	0	0	10130	10130
17:00	50.00	3278	3072	152	95	25	447	971	4762	3103	8	0	187	1128	25	436	51	308	140	24	354	0	-218	-709	70	-258	3	0	4651	9413	4866	214	-13	9914	0	0	0	9920	9920
18:00	50.01	3209	3007	149	68	40	434	763	4461	3123	8	0	187	1126	27	430	2	290	135	43	354	0	-218	-678	73	-200	3	0	4706	9166	4759	54	-14	9206	0	0	0	9210	9210
19:00	50.06	3310	3102	191	87	84	465	666	4594	3166	7	0	185	1126	38	431	0	326	145	108	357	0	-218	-428	82	-167	3	0	5162	9756	5151	-11	-14	9731	0	0	0	9731	9731
20:00	50.00	3414	3200	261	221	100	494	636	4912	3395	41	0	189	1127	43	439	0	358	160	108	363	0	-224	-952	91	-139	3	0	5403	10315	5321	-82	-15	10219	0	0	0	10223	10223
21:00	49.98	3410	3196	236	161	86	496	644	4819	3343	12	0	189	1116	43	438	0	344	162	121	364	0	-221	-651	97	-145	3	0	5216	10034	5135	-81	-15	9939	0	0	0	9950	9950
22:00	50.01	3403	3191	212	153	84	507	655	4801	3390	26	0	187	1117	43	438	0	356	157	112	364	0	-221	-627	91	-147	3	0	5390	10191	5369	-21	-14	10155	0	0	0	10158	10158
23:00	49.98	3393	3181	241	260	70	509	694	4954	3493	75	0	187	1116	46	438	0	356	151	89	360	0	-215	-356	91	-159	3	0	5678	10632	5684	6	-14	10624	0	0	0	10636	10636
24:00	50.03	3375	3163	196	236	81	510	767	4932	3475	73	0	189	1119	45	440	0	356	149	60	358	0	-215	-331	82	-159	3	0	5646	10578	5483	-163	-13	10401	0	0	0	10402	10402
Avg.	50.00	3231	3028	174	109	46	436	953	4745	3113	35	0	185	1136	28	433	157	293	133	44	353	0	-197	-508	73	-265	3	0	5018	9763	5250	233	-13	9982	0	0	0	9988	9988
00 TO 06 HRS.	50.01	3304	3096	151	103	34	463	751	4597	3290	73	0	187	1141	33	433	2	320	147	29	358	0	-190	-398	80	-164	3	0	5343	9940	5205	-138	-12	9790	0	0	0	9793	9793
06 TO 12 HRS.	50.02	3069	2874	168	73	41	371	1199	4727	2845	20	0	182	1156	16	431	356	235	110	25	352	0	-162	-455	66	-383	3	0	4797	9525	5315	517	-14	10028	0	0	0	10032	10032
12 TO 18 HRS.	49.98	3168	2968	154	73	30	408	1186	4820	2941	7	0	185	1127	20	430	272	268	122	23	343	0	-217	-704	69	-362	3	0	4515	9335	5125	609	-13	9932	0	0	0	9942	9942
18 TO 19 HRS.	50.00	3118	2921	161	73	35	390	1193	4774	2893	13	0	184	1141	18	431	314	251	116	24	347	0	-189	-680	62	-373	3	0	4656	9430	5220	563	-14	9980	0	0	0	9987	9987
19 TO 24 HRS.	50.01	3384	3172	223	186	81	497	677	4835	3377	39	0	188	1121	43	437	0	349	154	100	361	0	-219	-474	89	-153	3	0	5416	10251	5357	-99	-14	10178	0	0	0	10183	10183

**Hourly Average Own Generation, Schedule Drawal , Actual Drawal & Demand**  
**Month :- June 2023**

**FIGURES IN MW**

Hrs.	Own Generation										Schedule from																Load Shedding				REST. DEMAND	UNREST. DEMAND							
	FREQ.	Ther. Inl Aux	Ther. Extl Aux	HYD.	OSP	Total Wind Injctn	Total Wind Cntrl Injctn	Total	CSS	Net NR to MP	Slugs n	Lanco	Gasam	Essar	JP Ngrl	RUMS (SCLA RI REHA TO WPTU) CL	MB Power	Jhabu a Power	SSP	SCH to Rstly	SEZ	Banking	Sale	Pur	STOA	Rihan (o+Ma) Rstly	MTQA / STOA FROM RAJAS THAN	Total	Tot Avl.	Act. Dtl			Devia tion	Expt to MS	DEMAND MET	SCH	UN SCH	TOTAL	
1:00	50.01	3281	3067	156	390	214	450	986	5263	3255	201	0	220	1311	44	447	0	376	150	94	362	0	-607	-638	91	-152	8	0	5159	10422	5043	-116	-12	10294	0	0	0	10296	10296
2:00	50.01	3281	3067	150	289	145	451	994	5096	3176	216	0	220	1313	43	447	0	357	134	35	367	0	-607	-493	91	-152	8	0	5155	10261	4974	-161	-12	10056	0	0	0	10060	10060
3:00	50.01	3286	3053	131	248	117	445	987	4982	3156	172	0	220	1317	38	447	0	357	134	29	367	0	-630	-332	78	-176	8	0	5164	10165	5115	-69	-12	10085	0	0	0	10089	10089
4:00	50.02	3283	3051	124	184	89	439	953	4841	3094	126	0	220	1317	37	447	0	351	128	28	373	0	-633	-238	78	-172	8	0	5165	10005	5084	-81	-11	9913	0	0	0	9915	9915
5:00	50.00	3248	3036	121	170	89	436	912	4763	3084	108	0	220	1316	37	447	0	351	128	34	363	0	-633	-223	78	-172	8	0	5161	9914	5088	-63	-11	9840	0	0	0	9843	9843
6:00	49.99	3237	3026	151	206	106	418	888	4795	3029	139	0	220	1327	37	447	12	351	139	30	371	0	-300	-287	78	-173	8	0	5427	10222	5293	-134	-12	10076	0	0	0	10083	10083
7:00	50.01	3223	3013	172	264	126	396	1002	4973	2950	92	0	220	1331	25	447	26	351	138	29	370	0	-300	-268	78	-195	8	0	5312	10285	5295	-17	-13	10255	0	0	0	10258	10258
8:00	50.09	3062	2862	171	148	95	358	1337	4970	2785	73	0	217	1332	18	447	180	300	117	26	356	0	-300	-264	75	-263	8	0	5106	10076	5126	20	-13	10084	0	0	0	10084	10084
9:00	50.06	2839	2653	136	99	65	326	1550	4829	2659	56	0	208	1331	17	447	311	250	84	26	364	0	-300	-335	75	-334	8	0	4864	9693	5141	277	-12	9958	0	0	0	9959	9959
10:00	50.01	2784	2600	136	160	65	316	1612	4892	2599	57	0	195	1343	14	447	425	219	42	26	356	0	-500	-531	60	-394	8	0	4366	9258	5009	643	-12	9890	0	0	0	9892	9892
11:00	50.02	2803	2619	127	178	80	319	1607	4931	2522	42	0	198	1337	13	447	490	212	47	26	332	0	-500	-598	51	-425	8	0	4202	9133	4942	740	-12	9861	0	0	0	9863	9863
12:00	50.00	2855	2668	137	194	108	339	1569	5016	2485	36	0	204	1330	13	447	498	273	82	25	333	0	-500	-598	51	-436	8	0	4249	9265	4995	746	-12	10000	0	0	0	10005	10005
13:00	50.01	2930	2738	149	174	121	349	1480	5011	2508	67	0	204	1329	15	447	486	279	94	25	345	0	-500	-599	51	-432	8	0	4326	9337	5171	845	-12	10170	0	0	0	10179	10179
14:00	49.99	2961	2767	136	131	108	356	1441	4940	2507	46	0	200	1336	21	447	430	275	91	25	342	0	-500	-546	72	-385	8	0	4369	9309	5220	851	-12	10148	0	0	0	10157	10157
15:00	49.98	3043	2844	146	162	113	392	1354	5011	2779	53	0	208	1334	31	447	322	307	112	25	347	0	-500	-667	75	-340	8	0	4540	9551	5247	707	-11	10247	0	0	0	10256	10256
16:00	50.00	3136	2931	129	224	119	418	1236	5058	2895	78	0	213	1328	33	447	188	338	128	26	331	0	-500	-682	78	-295	8	0	4612	9670	5167	545	-12	10203	0	0	0	10209	10209
17:00	50.01	3150	2944	123	184	121	415	1089	4876	2979	84	0	217	1310	32	447	49	357	145	27	348	0	-500	-638	78	-240	8	0	4703	9579	4897	194	-12	9762	0	0	0	9765	9765
18:00	50.03	3117	2913	146	232	102	389	901	4684	2866	45	0	217	1309	31	449	4	338	129	30	351	0	-500	-524	81	-196	8	0	4638	9322	4805	167	-11	9477	0	0	0	9479	9479
19:00	50.02	3194	2986	177	278	171	442	807	4861	2956	64	0	221	1309	36	449	0	357	140	73	371	0	-500	-374	85	-162	8	0	5032	9892	4980	-52	-13	9828	0	0	0	9831	9831
20:00	50.00	3296	3081	232	426	206	479	812	5235	3303	241	0	221	1321	42	449	0	382	157	125	362	0	-653	-639	91	-154	8	0	5255	10490	5172	-83	-14	10394	0	0	0	10401	10401
21:00	49.99	3293	3079	229	476	216	483	805	5289	3286	181	0	221	1322	42	449	0	382	158	149	368	0	-650	-846	91	-153	8	0	5007	10296	4867	-140	-14	10142	0	0	0	10149	10149
22:00	50.04	3303	3088	211	546	245	485	872	5445	3342	132	0	221	1331	42	449	0	376	157	141	351	0	-650	-925	91	-153	8	0	4913	10358	4804	-109	-13	10236	0	0	0	10237	10237
23:00	50.00	3305	3089	209	633	277	481	905	5595	3352	167	0	221	1327	42	449	0	376	160	160	348	0	-650	-819	91	-156	8	0	5073	10669	5011	-62	-13	10593	0	0	0	10603	10603
24:00	50.04	3297	3082	182	545	286	479	962	5537	3306	165	0	221	1316	42	449	0	376	157	138	352	0	-650	-779	91	-157	8	0	5032	10568	4882	-149	-13	10406	0	0	0	10409	10409
Avg.	50.01	3132	2927	158	273	141	411	1128	5037	2953	110	0	214	1324	31	447	143	329	123	56	355	0	-523	-535	78	-244	8	0	4868	9906	5055	187	-12	10080	0	0	0	10084	10084
00 TO 06 HRS.	50.01	3263	3050	139	248	127	440	853	4957	3132	160	0	220	1317	39	447	2	357	135	42	368	0	-568	-368	82	-166	8	0	5207	10163	5099	-107	-12	10044	0	0	0	10048	10048
06 TO 12 HRS.	50.03	2928	2736	147	174	90	343	1446	4935	2667	59	0	207	1334	17	447	322	267	85	26	352	0	-400	-431	65	-341	8	0	4683	9619	5085	402	-12	10008	0	0	0	10010	10010
12 TO 18 HRS.	50.00	3056	2856	138	185	114	386	1280	4930	2756	62	0	210	1324	27	447	247	316	116	26	344	0	-500	-610	73	-315	8	0	4531	9461	5083	552	-12	10001	0	0	0	10007	10007
18 TO 24 HRS.	50.02	2992	2796	142	179	102	365	1348	4933	2711	61	0	208	1329	22	447	284	292	101	26	348	0	-450	-520	69	-328	8	0	4607	9540	5084	477	-12	10005	0	0	0	10009	10009
	50.02	3281	3067	207	484	233	476	861	5327	3257	158	0	221	1321	41	449	0	375	155	131	359	0	-626	-730	90	-156	8	0	5052	10379	4953	-99	-13	10267	0	0	0	10272	10272

**Hourly Average Own Generation, Schedule Drawal , Actual Drawal & Demand**  
**Month - July 2023**

**FIGURES IN MW**

Hrs.	Own Generation										Schedule from																		Load Shedding				REST. DEMAND	UNREST. DEMAND					
	FREQ	Ther. Inj Aux	Ther. Ext Aux	HYD.	OSP	Total Injto n	Total COn Injto n	Total	CSS	Net NR to MP	Slage n	Lanco	Gasam	Essa r	JP Nigri	RUMS (SCLA RI, RINA TO MP) CL	MB Power	Jhabu a Power	SSP	SCH to Raily	SEZ	Banking	Sale	Pur	STOA	Rihan (s+Ma) Raily at	MTQA / STOA FROM RAJAS THAN	Total	Tot Avl.	Act. Dtl	Devia tion	Expot to MS			DEMAN D MET	SCH	UN SCH	TOTAL	
1:00	50.00	3172	2965	257	611	329	440	581	5183	3219	145	0	241	1258	40	438	0	378	160	686	375	0	-1396	-703	86	-123	5	0	4728	9912	4673	-65	-8	9848	0	0	0	9852	9852
2:00	50.00	3146	2941	257	494	325	429	623	5068	3067	122	0	241	1258	39	436	0	374	154	449	374	0	-1203	-614	97	-123	5	0	4675	9743	4623	-52	-8	9682	0	0	0	9685	9685
3:00	50.00	3145	2941	258	456	322	406	628	5010	2889	90	0	241	1256	34	436	0	368	148	221	377	0	-893	-523	108	-132	3	0	4624	9634	4642	18	-8	9644	0	0	0	9646	9646
4:00	50.01	3148	2943	258	453	323	389	598	4964	2774	92	0	241	1265	31	434	0	362	148	161	375	0	-611	-576	81	-128	3	0	4654	9617	4612	-41	-8	9568	0	0	0	9570	9570
5:00	50.01	3155	2950	252	444	335	386	568	4935	2755	82	0	238	1285	31	433	0	349	140	113	369	0	-611	-446	92	-125	3	0	4707	9642	4689	-18	-8	9616	0	0	0	9618	9618
6:00	49.98	3166	2960	257	472	337	408	544	4979	2979	90	0	241	1300	34	433	5	367	150	273	370	0	-611	-412	111	-120	3	0	5214	10193	5176	-38	-8	10147	0	0	0	10156	10156
7:00	50.01	3153	2948	285	546	350	420	589	5139	3202	96	0	241	1303	34	432	18	374	154	299	376	0	-624	-517	115	-144	3	0	5363	10501	5423	60	-9	10552	0	0	0	10555	10555
8:00	50.03	3103	2901	292	477	353	390	728	5140	2945	90	0	238	1306	31	431	148	374	155	168	358	0	-624	-375	109	-197	3	0	5151	10291	5269	118	-9	10399	0	0	0	10401	10401
9:00	50.03	3032	2834	293	453	337	352	896	5186	2656	54	0	235	1286	20	431	265	320	123	64	371	0	-624	-361	74	-252	3	0	4664	9650	5055	391	-8	10232	0	0	0	10234	10234
10:00	50.01	2965	2771	284	402	312	345	1002	5117	2502	34	0	235	1284	18	431	361	302	116	16	358	0	-623	-628	97	-299	3	0	4211	9328	4854	643	-8	9963	0	0	0	9966	9966
11:00	50.02	2879	2691	267	407	300	330	1062	5057	2464	37	0	232	1292	18	431	430	284	111	20	357	0	-623	-816	62	-331	3	0	3971	9028	4675	704	-7	9726	0	0	0	9729	9729
12:00	50.01	2838	2653	256	371	298	328	1078	4981	2362	37	0	223	1283	15	431	441	275	101	19	351	0	-624	-826	73	-353	3	0	3810	8790	4892	782	-7	9566	0	0	0	9570	9570
13:00	50.01	2778	2597	256	317	274	312	1076	4832	2350	26	0	221	1338	15	431	423	270	90	19	354	0	-624	-801	92	-362	3	0	3841	8673	4707	866	-7	9532	0	0	0	9539	9539
14:00	50.01	2797	2615	248	381	288	319	1049	4860	2278	23	0	223	1320	16	430	390	282	74	72	345	0	-624	-765	99	-356	3	0	3779	8639	4626	847	-7	9479	0	0	0	9484	9484
15:00	49.97	2897	2708	251	386	282	345	978	4930	2397	26	0	229	1328	24	427	287	306	114	257	339	0	-637	-948	68	-312	3	0	3906	8836	4667	761	-6	9591	0	0	0	9602	9602
16:00	49.99	2975	2780	243	411	243	365	835	4877	2586	27	0	232	1311	26	428	181	320	122	346	339	0	-637	-992	67	-261	3	0	4099	8976	4668	569	-7	9538	0	0	0	9544	9544
17:00	49.98	3044	2845	248	414	247	370	660	4785	2786	35	0	238	1328	28	428	66	338	132	318	352	0	-637	-821	70	-205	3	0	4458	9243	4785	327	-7	9563	0	0	0	9570	9570
18:00	49.98	3071	2871	277	500	289	381	499	4796	2831	33	0	238	1321	30	433	6	338	137	276	357	0	-637	-575	90	-164	3	0	4717	9513	4861	143	-8	9648	0	0	0	9656	9656
19:00	50.02	3129	2925	313	591	305	425	432	4993	2987	111	0	241	1308	37	440	0	368	160	494	381	0	-637	-798	100	-125	3	0	5071	10063	5068	-3	-8	10052	0	0	0	10055	10055
20:00	50.00	3167	2961	339	719	310	448	437	5214	3429	64	0	241	1275	39	446	0	380	160	623	365	0	-947	-743	104	-127	3	0	5312	10526	5246	-66	-10	10451	0	0	0	10459	10459
21:00	50.00	3178	2971	335	741	314	451	460	5274	3468	53	0	241	1282	39	445	0	380	157	594	373	0	-1150	-910	102	-130	3	0	4919	10193	4848	-71	-10	10112	0	0	0	10117	10117
22:00	50.03	3178	2972	312	735	325	451	482	5278	3474	55	0	241	1249	39	444	0	380	158	599	359	0	-1153	-949	102	-130	3	0	4872	10150	4827	-45	-10	10095	0	0	0	10096	10096
23:00	50.01	3174	2968	285	753	373	451	510	5340	3423	70	0	241	1248	39	444	0	379	158	609	371	0	-1155	-903	106	-132	3	0	4904	10244	4867	-37	-9	10198	0	0	0	10202	10202
24:00	50.04	3171	2966	268	704	367	447	551	5301	3375	77	0	241	1249	39	444	0	379	158	571	377	0	-1155	-833	103	-132	3	0	4897	10198	4777	-119	-9	10070	0	0	0	10070	10070
Avg.	50.01	3061	2862	275	510	312	391	702	5052	2883	66	0	237	1287	30	435	126	342	137	299	363	0	-794	-701	92	-198	4	0	4606	9658	4843	237	-8	9886	0	0	0	9891	9891
00 TO 06 HRS.	50.00	3155	2950	256	488	328	410	590	5023	2947	104	0	241	1270	35	435	1	366	150	304	373	0	-888	-546	96	-125	4	0	4767	9790	4736	-31	-8	9751	0	0	0	9755	9755
06 TO 12 HRS.	50.02	2995	2800	279	448	325	360	891	5103	2688	58	0	234	1292	23	431	277	321	127	96	362	0	-624	-586	88	-263	3	0	4528	9631	4978	450	-8	10073	0	0	0	10076	10076
12 TO 18 HRS.	49.99	2927	2736	254	398	261	348	850	4847	2538	29	0	230	1324	23	430	225	304	111	215	348	0	-633	-817	81	-277	3	0	4133	8980	4719	585	-7	9559	0	0	0	9566	9566
00 TO 18 HRS.	50.01	2961	2768	267	423	293	354	870	4975	2613	43	0	232	1308	23	430	251	313	119	155	355	0	-628	-702	84	-270	3	0	4331	9306	4848	518	-8	9816	0	0	0	9821	9821
18 TO 24 HRS.	50.02	3166	2961	309	707	332	446	479	5233	3359	72	0	241	1264	39	444	0	378	158	582	371	0	-1033	-856	103	-129	3	0	4996	10229	4939	-57	-9	10163	0	0	0	10166	10166

**Discomwise Hourly Average Schedule Drawal , Actual Drawal &Over(+)/Under(-) Drawal**  
**Month :- April 2023**

FIGURES IN MW

Hrs.	FREQ.	EZONE								CZONE								WZONE								Railway	
		SCH	Demand Met	O/U DRL	SCH LS	Unsch LS	Restrict ed Demand	Unrestrict ed Demand	SCH	Demand Met	O/U DRL	SCH LS	Unsch LS	Restrict ed Demand	Unrestrict ed Demand	SCH	Demand Met	O/U DRL	SCH LS	Unsch LS	Restrict ed Demand	Unrestrict ed Demand	Total Sch	Total Drawal			
1:00	50.00	3041	2998	-42	0	0	2999	2999	3329	3281	-49	0	0	3282	3282	3285	3239	-46	0	0	3240	3240	351	367			
2:00	50.02	2902	2825	-77	0	0	2825	2825	3279	3191	-87	0	0	3192	3192	3176	3094	-82	0	0	3094	3094	352	366			
3:00	50.01	2776	2766	-10	0	0	2766	2766	3153	3144	-10	0	0	3144	3144	3158	3149	-10	0	0	3149	3149	352	357			
4:00	50.00	2780	2749	-30	0	0	2750	2750	3151	3116	-35	0	0	3117	3117	3177	3142	-35	0	0	3143	3143	364	362			
5:00	49.99	2721	2699	-22	0	0	2701	2701	3122	3095	-26	0	0	3097	3097	3205	3178	-28	0	0	3180	3180	346	344			
6:00	49.98	2867	2860	-8	0	0	2862	2862	3380	3370	-10	0	0	3373	3373	3415	3406	-8	0	0	3409	3409	360	359			
7:00	50.05	3198	3158	-40	0	0	3158	3158	3506	3462	-44	0	0	3462	3462	3770	3723	-47	0	0	3723	3723	370	366			
8:00	50.05	3068	3051	-18	0	0	3051	3051	3386	3366	-20	0	0	3367	3367	3817	3795	-23	0	0	3795	3795	358	356			
9:00	50.03	3033	3019	-14	0	0	3020	3020	3332	3316	-15	0	0	3317	3317	3836	3818	-18	0	0	3819	3819	357	353			
10:00	50.01	2990	2918	-72	0	0	2919	2919	3203	3126	-77	0	0	3127	3127	3809	3718	-91	0	0	3719	3719	360	356			
11:00	50.01	2934	2925	-9	0	0	2926	2926	3006	2998	-8	0	0	2999	2999	3807	3795	-11	0	0	3797	3797	341	338			
12:00	49.98	2823	2787	-36	0	0	2790	2790	3046	3009	-37	0	0	3012	3012	4065	4016	-50	0	0	4019	4019	338	334			
13:00	49.98	2844	2810	-34	0	0	2813	2813	3027	2992	-36	0	0	2995	2995	4154	4107	-48	0	0	4110	4110	345	342			
14:00	49.98	2785	2743	-42	0	0	2746	2746	3007	2962	-44	0	0	2966	2966	4022	3963	-59	0	0	3967	3967	338	337			
15:00	49.96	2816	2793	-23	0	0	2797	2797	3029	3005	-24	0	0	3009	3009	4065	4033	-32	0	0	4039	4039	344	341			
16:00	49.97	2735	2694	-41	0	0	2697	2697	3070	3024	-46	0	0	3028	3028	4025	3967	-59	0	0	3971	3971	335	332			
17:00	49.98	2624	2574	-50	0	0	2576	2576	3079	3020	-60	0	0	3022	3022	3633	3565	-68	0	0	3567	3567	356	354			
18:00	49.99	2531	2508	-23	0	0	2509	2509	3059	3031	-28	0	0	3033	3033	3485	3456	-29	0	0	3457	3457	352	352			
19:00	50.01	2963	2923	-40	0	0	2924	2924	3343	3297	-46	0	0	3298	3298	3590	3540	-50	0	0	3541	3541	357	359			
20:00	50.02	3048	3002	-46	0	0	3002	3002	3470	3415	-55	0	0	3416	3416	3367	3312	-55	0	0	3313	3313	353	361			
21:00	50.00	2957	2897	-59	0	0	2899	2899	3249	3184	-64	0	0	3186	3186	3190	3125	-65	0	0	3126	3126	361	368			
22:00	50.01	2967	2925	-42	0	0	2926	2926	3257	3212	-45	0	0	3213	3213	3323	3277	-46	0	0	3279	3279	351	365			
23:00	49.99	3180	3159	-21	0	0	3162	3162	3356	3334	-22	0	0	3336	3336	3405	3382	-23	0	0	3385	3385	348	365			
24:00	50.01	3159	3110	-49	0	0	3111	3111	3346	3293	-53	0	0	3294	3294	3305	3256	-50	0	0	3257	3257	346	363			
<b>Avg.</b>	<b>50.00</b>	<b>2906</b>	<b>2871</b>	<b>-35</b>	<b>0</b>	<b>0</b>	<b>2872</b>	<b>2872</b>	<b>3216</b>	<b>3177</b>	<b>-39</b>	<b>0</b>	<b>0</b>	<b>3179</b>	<b>3179</b>	<b>3587</b>	<b>3544</b>	<b>-43</b>	<b>0</b>	<b>0</b>	<b>3546</b>	<b>3546</b>	<b>351</b>	<b>354</b>			
<b>00 TO 06 HRS.</b>	50.00	2848	2816	-32	0	0	2817	2817	3236	3200	-36	0	0	3201	3201	3236	3201	-35	0	0	3203	3203	354	359			
<b>06 TO 12 HRS.</b>	50.02	3008	2976	-31	0	0	2977	2977	3246	3213	-33	0	0	3214	3214	3851	3811	-40	0	0	3812	3812	354	351			
<b>12 TO 18 HRS.</b>	49.98	2722	2687	-35	0	0	2690	2690	3045	3006	-40	0	0	3009	3009	3897	3848	-49	0	0	3852	3852	345	343			
<b>06 TO 18 HRS.</b>	50.00	2865	2832	-33	0	0	2834	2834	3146	3109	-36	0	0	3111	3111	3874	3830	-45	0	0	3832	3832	349	347			
<b>18 TO 24 HRS.</b>	50.01	3046	3003	-43	0	0	3004	3004	3337	3289	-48	0	0	3290	3290	3363	3315	-48	0	0	3317	3317	353	364			

**Discomwise Hourly Average Schedule Drawal , Actual Drawal &Over(+)/Under(-) Drawal**  
**Month :- May 2023**

FIGURES IN MW

Hrs.	FREQ.	EZONE								CZONE								WZONE								Railway	
		SCH	Demand Met	O/U DRL	SCH LS	Unsch LS	Restrict ed Demand	Unrestrict ed Demand	SCH	Demand Met	O/U DRL	SCH LS	Unsch LS	Restrict ed Demand	Unrestrict ed Demand	SCH	Demand Met	O/U DRL	SCH LS	Unsch LS	Restrict ed Demand	Unrestrict ed Demand	Total Sch	Total Drawal			
1:00	50.03	3135	3057	-79	0	0	3057	3057	3525	3434	-90	0	0	3435	3435	3259	3184	-75	0	0	3184	3184	364	366			
2:00	50.02	3036	2974	-62	0	0	2974	2974	3396	3328	-68	0	0	3328	3328	3178	3120	-58	0	0	3120	3120	359	360			
3:00	50.01	3002	2981	-21	0	0	2982	2982	3290	3269	-21	0	0	3270	3270	3218	3196	-22	0	0	3197	3197	350	350			
4:00	50.01	2996	2947	-50	0	0	2948	2948	3234	3185	-49	0	0	3186	3186	3199	3146	-53	0	0	3147	3147	363	363			
5:00	49.99	2885	2847	-38	0	0	2849	2849	3225	3190	-36	0	0	3192	3192	3215	3170	-45	0	0	3172	3172	349	349			
6:00	50.00	2925	2888	-37	0	0	2890	2890	3426	3381	-45	0	0	3384	3384	3335	3292	-43	0	0	3294	3294	361	361			
7:00	50.03	3055	3000	-55	0	0	3000	3000	3401	3337	-63	0	0	3338	3338	3486	3422	-64	0	0	3422	3422	367	366			
8:00	50.05	2964	2919	-45	0	0	2919	2919	3329	3278	-50	0	0	3279	3279	3468	3415	-52	0	0	3416	3416	349	348			
9:00	50.03	2933	2909	-24	0	0	2909	2909	3386	3359	-28	0	0	3360	3360	3411	3383	-28	0	0	3384	3384	362	362			
10:00	50.00	2950	2898	-52	0	0	2900	2900	3312	3254	-58	0	0	3256	3256	3505	3443	-62	0	0	3445	3445	354	354			
11:00	50.02	2961	2909	-52	0	0	2910	2910	3245	3190	-55	0	0	3190	3190	3601	3538	-63	0	0	3539	3539	346	346			
12:00	49.97	2941	2903	-38	0	0	2906	2906	3199	3159	-41	0	0	3162	3162	3791	3743	-48	0	0	3747	3747	333	333			
13:00	49.96	2942	2933	-10	0	0	2937	2937	3164	3154	-9	0	0	3159	3159	3844	3834	-11	0	0	3839	3839	342	342			
14:00	49.97	2887	2872	-15	0	0	2875	2875	3184	3169	-15	0	0	3172	3172	3785	3766	-20	0	0	3770	3770	334	336			
15:00	49.96	2898	2881	-17	0	0	2885	2885	3253	3232	-21	0	0	3236	3236	3818	3791	-27	0	0	3797	3797	342	342			
16:00	49.99	2784	2755	-30	0	0	2757	2757	3301	3266	-35	0	0	3268	3268	3807	3767	-40	0	0	3770	3770	334	334			
17:00	50.00	2647	2569	-77	0	0	2571	2571	3315	3221	-94	0	0	3223	3223	3572	3470	-102	0	0	3472	3472	354	354			
18:00	50.01	2515	2466	-49	0	0	2467	2467	3110	3053	-57	0	0	3054	3054	3396	3335	-61	0	0	3336	3336	354	353			
19:00	50.06	2785	2765	-20	0	0	2765	2765	3194	3173	-21	0	0	3173	3173	3455	3433	-22	0	0	3433	3433	357	359			
20:00	50.00	3061	3027	-34	0	0	3028	3028	3461	3422	-39	0	0	3423	3423	3443	3403	-40	0	0	3404	3404	363	368			
21:00	49.98	3005	2976	-29	0	0	2979	2979	3390	3357	-33	0	0	3361	3361	3272	3240	-32	0	0	3243	3243	364	366			
22:00	50.01	3120	3105	-15	0	0	3106	3106	3433	3415	-18	0	0	3416	3416	3282	3265	-17	0	0	3266	3266	364	370			
23:00	49.98	3314	3305	-10	0	0	3309	3309	3573	3561	-11	0	0	3565	3565	3397	3385	-11	0	0	3389	3389	360	373			
24:00	50.03	3328	3265	-62	0	0	3266	3266	3565	3498	-67	0	0	3499	3499	3329	3267	-62	0	0	3267	3267	358	371			
<b>Avg.</b>	<b>50.00</b>	<b>2961</b>	<b>2923</b>	<b>-38</b>	<b>0</b>	<b>0</b>	<b>2925</b>	<b>2925</b>	<b>3330</b>	<b>3287</b>	<b>-43</b>	<b>0</b>	<b>0</b>	<b>3289</b>	<b>3289</b>	<b>3461</b>	<b>3417</b>	<b>-44</b>	<b>0</b>	<b>0</b>	<b>3419</b>	<b>3419</b>	<b>353</b>	<b>355</b>			
<b>00 TO 06 HRS.</b>	50.01	2997	2949	-48	0	0	2950	2950	3349	3298	-52	0	0	3299	3299	3234	3185	-49	0	0	3186	3186	358	358			
<b>06 TO 12 HRS.</b>	50.02	2967	2923	-44	0	0	2924	2924	3312	3263	-49	0	0	3264	3264	3543	3491	-53	0	0	3492	3492	352	351			
<b>12 TO 18 HRS.</b>	49.98	2779	2746	-33	0	0	2749	2749	3221	3182	-39	0	0	3185	3185	3704	3660	-43	0	0	3664	3664	343	343			
<b>06 TO 18 HRS.</b>	50.00	2873	2834	-39	0	0	2836	2836	3266	3223	-44	0	0	3225	3225	3624	3576	-48	0	0	3578	3578	347	347			
<b>18 TO 24 HRS.</b>	50.01	3102	3074	-28	0	0	3075	3075	3436	3404	-31	0	0	3406	3406	3363	3332	-31	0	0	3334	3334	361	368			

**Discomwise Hourly Average Schedule Drawal , Actual Drawal &Over(+)/Under(-) Drawal**  
**Month :- June 2023**

FIGURES IN MW

Hrs.	FREQ.	EZONE								CZONE								WZONE								Railway	
		SCH	Demand Met	O/U DRL	SCH LS	Unsch LS	Restrict ed Demand	Unrestrict ed Demand	SCH	Demand Met	O/U DRL	SCH LS	Unsch LS	Restrict ed Demand	Unrestrict ed Demand	SCH	Demand Met	O/U DRL	SCH LS	Unsch LS	Restrict ed Demand	Unrestrict ed Demand	Total Sch	Total Drawal			
1:00	50.01	3252	3207	-45	0	0	3207	3207	3423	3377	-46	0	0	3377	3377	3383	3337	-46	0	0	3337	3337	362	374			
2:00	50.01	3176	3116	-60	0	0	3117	3117	3366	3302	-64	0	0	3303	3303	3329	3266	-63	0	0	3267	3267	367	373			
3:00	50.01	3125	3102	-23	0	0	3103	3103	3271	3247	-24	0	0	3248	3248	3393	3368	-25	0	0	3369	3369	367	368			
4:00	50.02	3082	3051	-31	0	0	3052	3052	3231	3200	-32	0	0	3200	3200	3322	3289	-33	0	0	3290	3290	373	373			
5:00	50.00	2984	2965	-19	0	0	2966	2966	3217	3197	-20	0	0	3198	3198	3334	3313	-21	0	0	3314	3314	365	365			
6:00	49.99	3024	2982	-42	0	0	2984	2984	3415	3369	-46	0	0	3371	3371	3399	3355	-44	0	0	3357	3357	371	370			
7:00	50.01	3082	3042	-40	0	0	3042	3042	3380	3336	-44	0	0	3337	3337	3554	3508	-46	0	0	3509	3509	370	371			
8:00	50.09	3031	2940	-91	0	0	2940	2940	3383	3281	-102	0	0	3281	3281	3615	3506	-109	0	0	3506	3506	356	357			
9:00	50.06	2990	2903	-87	0	0	2903	2903	3304	3208	-96	0	0	3209	3209	3585	3481	-103	0	0	3481	3481	364	365			
10:00	50.01	2914	2876	-38	0	0	2877	2877	3144	3105	-39	0	0	3106	3106	3596	3552	-43	0	0	3553	3553	356	356			
11:00	50.02	2910	2863	-46	0	0	2864	2864	3135	3088	-47	0	0	3089	3089	3634	3580	-54	0	0	3581	3581	332	330			
12:00	50.00	2948	2892	-56	0	0	2893	2893	3134	3076	-58	0	0	3077	3077	3766	3700	-67	0	0	3701	3701	333	333			
13:00	50.01	2979	2953	-26	0	0	2956	2956	3116	3088	-29	0	0	3090	3090	3817	3783	-34	0	0	3787	3787	345	346			
14:00	49.99	2937	2919	-17	0	0	2922	2922	3136	3120	-16	0	0	3123	3123	3786	3767	-20	0	0	3770	3770	342	342			
15:00	49.98	2979	2939	-40	0	0	2942	2942	3188	3145	-43	0	0	3148	3148	3867	3815	-53	0	0	3818	3818	347	347			
16:00	50.00	2863	2832	-31	0	0	2833	2833	3195	3160	-35	0	0	3162	3162	3922	3880	-41	0	0	3882	3882	331	331			
17:00	50.01	2735	2666	-69	0	0	2667	2667	3203	3125	-78	0	0	3126	3126	3713	3623	-91	0	0	3624	3624	348	349			
18:00	50.03	2552	2541	-11	0	0	2541	2541	3072	3058	-14	0	0	3058	3058	3544	3528	-16	0	0	3529	3529	351	351			
19:00	50.02	2792	2761	-32	0	0	2762	2762	3193	3156	-37	0	0	3157	3157	3580	3541	-40	0	0	3542	3542	371	371			
20:00	50.00	3132	3101	-31	0	0	3103	3103	3477	3442	-35	0	0	3444	3444	3520	3486	-34	0	0	3489	3489	362	364			
21:00	49.99	3134	3085	-49	0	0	3087	3087	3449	3395	-54	0	0	3397	3397	3343	3290	-53	0	0	3292	3292	368	373			
22:00	50.04	3234	3193	-40	0	0	3194	3194	3436	3394	-42	0	0	3394	3394	3326	3285	-41	0	0	3285	3285	351	363			
23:00	50.00	3375	3343	-31	0	0	3346	3346	3466	3433	-32	0	0	3437	3437	3477	3444	-33	0	0	3447	3447	348	373			
24:00	50.04	3357	3293	-64	0	0	3294	3294	3466	3399	-67	0	0	3400	3400	3400	3335	-66	0	0	3335	3335	352	379			
<b>Avg.</b>	<b>50.01</b>	<b>3024</b>	<b>2982</b>	<b>-43</b>	<b>0</b>	<b>0</b>	<b>2983</b>	<b>2983</b>	<b>3283</b>	<b>3238</b>	<b>-46</b>	<b>0</b>	<b>0</b>	<b>3239</b>	<b>3239</b>	<b>3550</b>	<b>3501</b>	<b>-49</b>	<b>0</b>	<b>0</b>	<b>3503</b>	<b>3503</b>	<b>355</b>	<b>359</b>			
<b>00 TO 06 HRS.</b>	50.01	3107	3070	-37	0	0	3071	3071	3320	3282	-38	0	0	3283	3283	3360	3321	-39	0	0	3323	3323	368	370			
<b>06 TO 12 HRS.</b>	50.03	2979	2919	-60	0	0	2920	2920	3247	3182	-64	0	0	3183	3183	3625	3554	-70	0	0	3555	3555	352	352			
<b>12 TO 18 HRS.</b>	50.00	2841	2808	-32	0	0	2810	2810	3152	3116	-36	0	0	3118	3118	3775	3733	-42	0	0	3735	3735	344	344			
<b>06 TO 18 HRS.</b>	50.02	2910	2864	-46	0	0	2865	2865	3199	3149	-50	0	0	3150	3150	3700	3643	-56	0	0	3645	3645	348	348			
<b>18 TO 24 HRS.</b>	50.02	3171	3129	-41	0	0	3131	3131	3414	3370	-45	0	0	3372	3372	3441	3397	-44	0	0	3398	3398	359	371			

**Discomwise Hourly Average Schedule Drawal , Actual Drawal &Over(+)/Under(-) Drawal**  
**Month :- July 2023**

FIGURES IN MW

Hrs.	FREQ.	EZONE								CZONE								WZONE								Railway	
		SCH	Demand Met	O/U DRL	SCH LS	Unsch LS	Restrict ed Demand	Unrestrict ed Demand	SCH	Demand Met	O/U DRL	SCH LS	Unsch LS	Restrict ed Demand	Unrestrict ed Demand	SCH	Demand Met	O/U DRL	SCH LS	Unsch LS	Restrict ed Demand	Unrestrict ed Demand	Total Sch	Total Drawal			
1:00	50.00	3227	3208	-20	0	0	3209	3209	3572	3549	-23	0	0	3551	3551	2730	2713	-17	0	0	2714	2714	375	378			
2:00	50.00	3172	3153	-19	0	0	3154	3154	3484	3463	-21	0	0	3464	3464	2708	2691	-17	0	0	2692	2692	374	375			
3:00	50.00	3143	3147	4	0	0	3148	3148	3457	3463	6	0	0	3463	3463	2654	2658	4	0	0	2658	2658	377	377			
4:00	50.01	3137	3124	-13	0	0	3125	3125	3432	3417	-15	0	0	3418	3418	2663	2652	-12	0	0	2652	2652	375	375			
5:00	50.01	3084	3083	0	0	0	3084	3084	3436	3433	-3	0	0	3433	3433	2734	2731	-3	0	0	2732	2732	369	369			
6:00	49.98	3074	3064	-10	0	0	3067	3067	3614	3603	-11	0	0	3607	3607	3118	3109	-9	0	0	3112	3112	370	370			
7:00	50.01	3181	3173	-8	0	0	3174	3174	3689	3679	-10	0	0	3680	3680	3334	3324	-10	0	0	3325	3325	376	376			
8:00	50.03	3167	3116	-51	0	0	3117	3117	3688	3628	-60	0	0	3628	3628	3352	3297	-55	0	0	3297	3297	358	358			
9:00	50.03	3124	3089	-35	0	0	3089	3089	3650	3609	-41	0	0	3610	3610	3198	3163	-36	0	0	3164	3164	371	371			
10:00	50.01	3026	3008	-18	0	0	3009	3009	3611	3588	-23	0	0	3589	3589	3027	3008	-19	0	0	3009	3009	358	359			
11:00	50.02	3018	2974	-44	0	0	2975	2975	3591	3538	-53	0	0	3539	3539	2899	2858	-41	0	0	2859	2859	357	356			
12:00	50.01	2987	2951	-36	0	0	2952	2952	3492	3449	-42	0	0	3451	3451	2849	2814	-35	0	0	2815	2815	351	352			
13:00	50.01	2948	2934	-14	0	0	2936	2936	3470	3453	-17	0	0	3455	3455	2806	2791	-14	0	0	2793	2793	354	354			
14:00	50.01	2900	2896	-4	0	0	2897	2897	3443	3439	-4	0	0	3441	3441	2803	2799	-3	0	0	2801	2801	345	345			
15:00	49.97	2918	2918	0	0	0	2922	2922	3475	3474	-1	0	0	3478	3478	2861	2859	-2	0	0	2863	2863	339	340			
16:00	49.99	2840	2826	-13	0	0	2828	2828	3492	3476	-17	0	0	3478	3478	2909	2897	-12	0	0	2899	2899	339	339			
17:00	49.98	2764	2738	-27	0	0	2740	2740	3556	3522	-34	0	0	3525	3525	2979	2950	-29	0	0	2952	2952	352	353			
18:00	49.98	2729	2708	-21	0	0	2710	2710	3519	3494	-25	0	0	3497	3497	3111	3090	-21	0	0	3092	3092	357	357			
19:00	50.02	2972	2951	-21	0	0	2952	2952	3540	3517	-23	0	0	3518	3518	3222	3202	-21	0	0	3203	3203	381	382			
20:00	50.00	3288	3257	-31	0	0	3260	3260	3705	3670	-35	0	0	3673	3673	3171	3140	-31	0	0	3142	3142	365	383			
21:00	50.00	3281	3248	-33	0	0	3250	3250	3562	3526	-36	0	0	3528	3528	2977	2946	-30	0	0	2948	2948	373	392			
22:00	50.03	3311	3291	-20	0	0	3291	3291	3572	3551	-21	0	0	3551	3551	2893	2876	-17	0	0	2876	2876	359	377			
23:00	50.01	3362	3338	-24	0	0	3340	3340	3660	3636	-24	0	0	3637	3637	2853	2835	-18	0	0	2836	2836	371	389			
24:00	50.04	3342	3296	-46	0	0	3296	3296	3672	3622	-51	0	0	3622	3622	2804	2765	-39	0	0	2765	2765	377	387			
<b>Avg.</b>	<b>50.01</b>	<b>3083</b>	<b>3062</b>	<b>-21</b>	<b>0</b>	<b>0</b>	<b>3063</b>	<b>3063</b>	<b>3557</b>	<b>3533</b>	<b>-24</b>	<b>0</b>	<b>0</b>	<b>3535</b>	<b>3535</b>	<b>2944</b>	<b>2924</b>	<b>-20</b>	<b>0</b>	<b>0</b>	<b>2925</b>	<b>2925</b>	<b>363</b>	<b>367</b>			
<b>00 TO 06 HRS.</b>	50.00	3140	3130	-10	0	0	3131	3131	3499	3488	-11	0	0	3489	3489	2768	2759	-9	0	0	2760	2760	373	374			
<b>06 TO 12 HRS.</b>	50.02	3084	3052	-32	0	0	3053	3053	3620	3582	-38	0	0	3583	3583	3110	3077	-33	0	0	3078	3078	362	362			
<b>12 TO 18 HRS.</b>	49.99	2850	2837	-13	0	0	2839	2839	3492	3476	-16	0	0	3479	3479	2911	2898	-14	0	0	2900	2900	348	348			
<b>06 TO 18 HRS.</b>	50.01	2967	2944	-23	0	0	2946	2946	3556	3529	-27	0	0	3531	3531	3011	2988	-23	0	0	2989	2989	355	355			
<b>18 TO 24 HRS.</b>	50.02	3259	3230	-29	0	0	3231	3231	3618	3587	-32	0	0	3588	3588	2987	2961	-26	0	0	2962	2962	371	385			