

SUPPLEMENTARY AGENDA OF 70TH OCCM OF MP

SA-I :- UNEVEN POWER SALE AND EXCESS DRAWAL FROM GRID:-

The coordination with all generating utilities to ensure optimum utilization of available resources should have made. The quantum of sale / power purchase / power surrendered should be managed such a manner that MP drawal from grid should be maintained within the permissible limit as per provision of grid code. It has been observed that due to uneven power sale / power surrender the over drawl of MP shoot up to dangerous limit, which is not desirable for smooth and secure operation of grid. On dtd. 06.07.2019, at 18:47 hrs over drawal of MP increased upto 1000MW due to uneven sale of power for one block. The variation in sell quantum was observed 270 MW in block 74, 943 MW in block 75, 1721 MW in block 76 and 1220 MW in block 77. Such huge variation in sale of power and drawal schedule in not in the interest of safe and secure operation of the integrated grid. It is desired that considering sale / banking, power surrender should have managed such a manner that drawal from the grid be maintained within permissible limit. MPPMCL is requested to look into the matter so that drawal from the grid be maintained all the time within safe operating limits. Load generation balance required to be maintained invariably otherwise WRLDC may initiate reporting of grid violation to Regulators along with contingency measures by opening important lines which may create problem to our system (**ANNEXURE-SA-I**).

ANNEXURE - SA-I

Block	Time		Power Availability from ISGS / SSGS/ IPP	Power Schedule from ISGS / SSGS/ IPP	Hydel Availability	Hydel Injection	OD / UD	IEX Sale	Total Schedule	Sch. Difference	Demand	Remark
	From	To										
65	16:00	16:15	7486	4711	59	462	133	-143	2237		5943	osp 2 m/c, bargi, deolone continuously running & ISP 1 m/c taken from 18.00 & BRS HPS taken from 18.15
66	16:15	16:30	7486	4885	59	462	-31	0	2544	307	6009	
67	16:30	16:45	7486	5006	59	461	-62	0	2636	91	6034	
68	16:45	17:00	7486	4995	59	461	70	0	2619	-17	6160	
69	17:00	17:15	7508	5032	79	461	131	0	2757	138	6287	
70	17:15	17:30	7511	5032	79	457	221	0	2753	-4	6329	
71	17:30	17:45	7514	5082	79	458	237	0	2797	44	6405	
72	17:45	18:00	7517	5214	79	460	312	0	2916	119	6398	
73	18:00	18:15	7696	5535	119	576	120	0	3220	304	6516	
74	18:15	18:30	7699	5962	119	589	-64	-270	3335	115	6555	
75	18:30	18:45	7502	6179	119	591	355	-943	2835	-500	6659	
76	18:45	19:00	7503	6543	119	589	4	-1721	2378	-457	6713	
77	19:00	19:15	7503	6959	227	591	-305	-1220	3095	716	6533	
78	19:15	19:30	7508	7173	227	591	-207	-1129	3184	90	6719	
79	19:30	19:45	7526	7307	335	591	-416	-936	3474	290	6786	
80	19:45	20:00	7526	7421	282	591	-611	-1048	3451	-23	6816	